


## Key Document Revision Details – Revision 2.0 to 2.1

- **Section 1.4:** Defined the TIIR effective date in Ohio as the later of November 1, 2026, or the date dictated by the PUCO.
- **Section 2.0:** Added definitions for *DNP3* and *EPRI Common File Format*.
- **Section 4:15:** Restructured the section to increase clarity by splitting the content into subheadings of limited export and non-export. These terms better align with industry and state code terminology. Added use of Directional Power Protection as an approved option for limiting DER capacity. Clarified use of a DER Facility’s nameplate rating and limited export capacity value.
- **Section 11.3.2:** Clarified that AEP supports serial *IEEE Std 1815 (DNP3)* protocol for use as the communication interface for DER integration.
- **Appendix A:** Add links to the publicly available versions of *IEEE Std 1547-2018* and the *EPRI Common File Format* document.

 AMERICAN ELECTRIC POWER <small>BOUNDLESS ENERGY™</small>	DER Technical Interconnection and Interoperability Requirements (TIIR) for the AEP System	Rev. 2.1 Effective 8/1/26	
	CAUTION: Printed copies of this document are uncontrolled and may be obsolete. Always check for the latest revision prior to use.		Page 1