

HISTORY OF CONSTRUCTION

CFR 257.73(c)(1)

East & West Bottom Ash Pond Complex

Pirkey Plant
Hallsville, Texas

October, 2016

Prepared for: AEP/SWEPCO - Pirkey Plant
Hallsville, Texas

Prepared by: American Electric Power Service Corporation
1 Riverside Plaza
Columbus, OH 43215



GERS – 16 – 032

Table of CONTENTS

1.0 OBJECTIVE.....	3
2.0 DESCRIPTION OF CCR THE IMPOUNDMENT.....	3
3.0 SUMMARY OF OWNERSHIP 275.73(c)(1)(i)	3
4.0 LOCATION OF THE CCR UNIT 275.73 (c)(1)(ii).....	3
5.0 STATEMENT OF PURPOSE 275.73 (c)(1)(iii)	4
6.0 NAME AND SIZE OF WATERSHED THE CCR UNIT IS LOCATED 275.73 (c)(1)(iv)	4
7.0 DESCRIPTION OF THE FOUNDATION AND ABUTMENT MATERIALS 275.73(c)(1)(v)	4
8.0 DESCRIPTION OF EACH CONSTRUCTED ZONE OR STAGE OF THE CCR UNIT 275.73 (c)(1)(vi).....	4
9.0 ENGINEERING STRUCTURES AND APPURTENANCES, 275.73 (c)(1)(vii)	5
10.0 SUMMARY OF POOL SURFACE ELEVATIONS, AND MAXIMUM DEPTH OF CCR, 275.73 (c)(1)(vii)	6
11.0 FEATURES THAT COULD ADVERSELY AFFECT OPERATION DUE TO MALFUNCTION OR MIS-OPERATION (275.73 (c)(1)(vii))	6
12.0 DESCRIPTION OF THE TYPE, PURPOSE AND LOCATION OF EXISTING INSTRUMENTATION 275.73 (c)(1)(viii)	7
13.0 AREA – CAPACITY CURVES FOR THE CCR UNIT 275.73 (c)(1)(ix)	7
14.0 275.73 (c)(1)(x) DESCRIPTION OF EACH SPILLWAY AND DIVERSION	7
15.0 SUMMARY CONSTRUCTION SPECIFICATIONS AND PROVISIONS FOR SURVEILLANCE, MAINTENANCE AND REPAIR 275.73 (c)(1)(xi)	7
16.0 RECORD OR KNOWLEDGE OF STRUCTURAL INSTABILITY 275.73 (c)(1)(xii)	8

Attachments

- Attachment A – Location Map
- Attachment B – Design Reports
- Attachment C – Design Drawings
- Attachment D – Instrumentation Location Map
- Attachment E – Hydrology and Hydraulic Report

1.0 OBJECTIVE

This report was prepared by AEP- Geotechnical Engineering Services (GES) section to fulfill requirements of CCR 257.73(c)(1) with an evaluation of the facility.

2.0 DESCRIPTION OF CCR THE IMPOUNDMENT

The Henry W. Pirkey Power Station is located at 2400 FM 3251 and south of Hallsville, Texas. It is owned and operated by Southwest Electric Power Company (SWEPCO). The facility operates two surface impoundments for storing CCR materials called the East Bottom Ash Pond (East BAP) and the West Bottom Ash Pond (West BAP).

The East BAP is located directly adjacent to and east of the West BAP. The East BAP receives sluiced bottom ash and has a surface area of 30.9 acres and a storage capacity of 188 acre-feet. The pond is almost entirely incised, with a reported maximum embankment height of 4 feet.

The West BAP, which also receives sluiced bottom ash, is located northwest of the main plant buildings and shares its eastern border with the western border of the East BAP. The West BAP receives sluiced bottom ash and has a surface area of 30 acres and a storage capacity of 188 acre-feet. The maximum embankment height is 25 feet. Design material include in the provided documentation indicate that the main upstream embankment slopes are 3 feet horizontal to 1 foot vertical (3:1 H:V); while the main downstream slopes area 2.5:1 H:V.

3.0 SUMMARY OF OWNERSHIP 275.73(c)(1)(i)

[The name and address of the person(s) owning or operating the CCR unit: the name associated with the CCR unit: and the identification number of the CCR unit if one has been assigned by the state.]

The AEP H.W. Pirkey Power station is located in southern Harrison County, approximately 5 miles southeast of Hallsville, Texas, and approximately 8 miles southwest of Marshall, Texas. The Plant Power Station Address is 2400 FM 3251, Hallsville, Texas . It is owned and operated by Southwestern Electric Power Company (SWEPCO). The facility Bottom Ash Complex operates two surface impoundments for storing CCR and a clear water pond for decant water.

4.0 LOCATION OF THE CCR UNIT 275.73 (c)(1)(ii)

[The location of the CCR unit identified on the most recent U.S. Geological Survey (USGS) 7 ½ minute or 15 minute topographic quadrangle map, or a topographic map of equivalent scale if a USGS map is not available.]

A location map is included in Attachment A.

5.0 STATEMENT OF PURPOSE 275.73 (c)(1)(iii)

[A statement of the purpose for which the CCR unit is being used.]

The Bottom Ash Pond Complex is a surface impoundment for storing CCR. The Bottom Ash Ponds within the complex are used for primary settling and storage of bottom ash. The decant water from the Bottom Ash ponds flow s into a secondary pond that provides storage of decant water.

6.0 NAME AND SIZE OF WATERSHED THE CCR UNIT IS LOCATED

275.73 (c)(1)(iv)

[The name and size in acres of the watershed within which the CCR unit is located.]

The Pirkey East BAP and West BAP are comprised of diked embankments on all sides which direct stormwater away from the impoundment and limit runoff to that which falls directly on the water surface. Therefore, the areas surrounding the impoundments do not contribute any runoff. The watershed for the ponds is equal to the surface areas of the ponds and is approximately 61 acres.

The bottom ash ponds are located within the Region 12 - Texas Gulf Region Watershed and are part of the sub group HUC = 12010002 Middle Sabine watershed area. The area is approximately 1770009.6 acres.

7.0 DESCRIPTION OF THE FOUNDATION AND ABUTMENT MATERIALS

275.73(c)(1)(v)

[A description of the physical and engineering properties of the foundation and abutment materials on which the CCR unit is located.]

The foundaion materials for the East BAP are native soils which consist of stiff to very stiff sandy lean clay (CL) and sandy fat clay (CH) with intermittent layers of medium dense to dense silty sand (SM) and clayey sand (SC). Atterburg Plasticity Indices of tested soils ranged between a low of 16 to a high of 39.

The foundation materials for the West BAP are native soils which consist primarily of medium dense to very dense clayey sand (SC) with layers of of dense clayey gravel (GC) and very dense silty clayey sand (SC-SM). Atterburg Plasticity Indices of tested soils ranged between a low of 9 to a high of 46. The engineering properties of the foundation soils had a cohesion that ranged between 290 psf and 430 psf and a friction angle that ranged between 17 degrees and 28 degrees. Additioanl details on the engineering properties of the foundaiton soils is in the design reports presented in Attachment B.

8.0 DESCRIPTION OF EACH CONSTRUCTED ZONE OR STAGE OF THE CCR UNIT 275.73 (c)(1)(vi)

[A statement of the type, size, range, and physical and engineering properties of the materials used in constructing each zone or stage of the CCR unit; and the approximate dates of construction of each successive stage of construction of the CCR unit.]

The East BAP is primarily incised into native soils with an embankment height of approximately 4 feet (AMEC, 20110). The East BAP embankments are constructed of compacted clay on a 3:1 slope (3 feet horizontal, 1 foot vertical) (Sargent & Lundy, 1983). The embankment soils are stiff to very stiff sandy lean clay (CL) and sandy fat clay (CH) with intermittent layers of medium dense to dense silty sand (SM) and clayey sand (SC). The elevation of the top of embankment around the perimeter of the East BAP is approximately 357 feet amsl, and the normal operating level is approximately 354 feet amsl (Johnson & Pace, May 2011). The interior bottom elevation of the East BAP is approximately 347 feet amsl (Sargent & Lundy, 1983; Johnson & Pace, June 2011. A copy of the referenced design documents and design drawings are presented in attachment B & C.

The West BAP embankments have maximum height of approximately 25 feet and are constructed of compacted clay on a slope ranging from 2.5:1 (2.5 feet horizontal, 1 foot vertical) to 3:1 (Sargent & Lundy). The elevation at the top of the embankment around the perimeter of the West BAP is approximately 357 feet amsl, and the normal operating level is approximately 354 feet amsl (Johnson & Pace, 2011). The embankment fill materials are stiff to very stiff lean clay (CL) and/or fat clay (CH), overlying native soils consisting of dense to very dense clayey sand (SC) with intermittent layers of dense gravel (GC) and very dense silty clayey sand (SC-SM). The interior bottom elevation of the West BAP is approximately 347 feet amsl (Sargent & Lundy, 1983; Akron Consulting, 2012). The engineering properties of embankment soils had a cohesion of 590 psf and a friction angle of 16 degrees. Additioanl details on the engineering properties of the foundaiton soils is in the design reports presented in Attachment B.

A copy of the referenced design documents and design drawings are presented in attachment B & C.

9.0 ENGINEERING STRUCTURES AND APPURTENANCES, 275.73 (c)(1)(vii)

[At a scale that details engineering structures and appurtenances relevant to the design, construction, operation, and maintenance of the CCR unit, detailed dimensional drawings of the CCR unit, including a plan view and cross sections of the length and width of the CCR unit, showing all zones, foundation improvements, drainage provisions, spillways, diversion ditches, outlets, instrument locations, and slope protection...]

The bottom ash from the plant is sluiced to the Ash Ponds using sluice pumps that convey the ash slurry through a pipeline which discharges the slurry into the middle of the pond. The slurry is sluiced at the rate of 3,000 gallons per minute (GPM) per pump. During normal operations only one pump is used at a time. The bottom ash settles, and the decant water is discharged from the Ash Ponds using either a portable pump or by overflowing into the Secondary Pond through a vertical box weir structure that contains a 36-inch diameter corrugated metal pipe (CMP) and manually operated gate valve. Additional discharge outlets convey relatively minor quantities into the ponds, including the boiler blowdown outlet which conveys about 35 GPM to the Secondary Pond. None of the ponds have a designated emergency spillway. The decant water from the Secondary Pond is re-used by pumping it out of the pond using the ash recirculation pumps (housed in a pump 4 house structure). Of the four recirculation pumps, only three are normally operated and convey average flows of about 2,000 GPM each. Flow to and from the ponds is balanced by conveying the water from the recirculation pumps to a suction tank that is used by the sluice pumps to remove the ash from the boiler and then return it to the Ash Ponds. A permitted outfall valve is located near the southwest corner of the Secondary Pond

and discharges into a runoff ditch on the south side of the pond that eventually conveys water to Hatley Creek. The gate valve is typically closed.

For location and details of all appurtenances see design drawings presented in Attachment C and for a map of the instrumentation locations see Attachment D.

10.0 SUMMARY OF POOL SURFACE ELEVATIONS, AND MAXIMUM DEPTH OF CCR, 275.73 (c)(1)(vii)

[...in addition to the normal operating pool surface elevation and the maximum pool elevation following peak discharge from the inflow design flood, the expected maximum depth of CCR within the CCR surface impoundment.]

The table below describes the normal pool elevations and maximum pool elevations as well as maximum depth of CCR within the impoundment. The Inflow Design Flood is the 100-year storm event.

	West Bottom Ash Pond	East Bottom Ash Pond
Normal Pool Elevation	354.0	354.0
Maximum Pool Elevation following peak discharge from inflow design flood	355.01	354.99
Expected Maximum depth of CCR within impoundment	7.5 ft	7.5 ft

11.0 FEATURES THAT COULD ADVERSELY AFFECT OPERATION DUE TO MALFUNCTION OR MIS-OPERATION (275.73 (c)(1)(vii))

[...and any identifiable natural or manmade features that could adversely affect operations of the CCR unit due to malfunction or mis-operation]

In the event of malfunction or mis-operation of any of the pond's appurtenances the ponds operations could be adversely affected. These structures include weir structures and piping between pond cells, low water discharge gated structures, gated weir structures, effluent return piping and pump structures and influent sluicing piping and structures. See design drawings in Attachment C for location and details of all appurtenances.

12.0 DESCRIPTION OF THE TYPE, PURPOSE AND LOCATION OF EXISTING INSTRUMENTATION 275.73 (c)(1)(viii)

[A description of the type, purpose, and location of existing instrumentation.]

The East BAP has no instrumentation.

The West BAP has 2 piezometers located within the structure of the dam. These piezometers are read every 30 days for the purpose of determining the phreatic water level within the dike. A location map is provided in Attachment D.

13.0 AREA – CAPACITY CURVES FOR THE CCR UNIT 275.73 (c)(1)(ix)

[Area-capacity curves for the CCR unit.]

The area capacity curves for the Bottom Ash Pond Complex are included in the Hydrology and Hydraulic Analysis Report by Aukland, 2015 in Attachment E.

14.0 275.73 (c)(1)(x) DESCRIPTION OF EACH SPILLWAY AND DIVERSION

[A description of each spillway and diversion design features and capacities and calculations used in their determination.]

Complete details of each spillway structure are included with the design drawings in Attachment C. Hydrology and Hydraulic Analysis which include calculations for each spillway structure are included in Attachment E.

The surface water elevation in the East BAP is controlled by a weir box and a manually operated gate valve on a 36-inch diameter discharge pipe at the southwest corner of the pond. Clear water overflow from the East BAP discharges through the 36-inch diameter pipe into a 2.7 acre Clearwater Pond located directly south of the East BAP. Water in the Clearwater Pond is either pumped (re-circulated) back into the boiler ash hopper, or gravity discharged through a pipe at the southwest corner of the Clearwater Pond into an unnamed intermittent tributary of Hatley Creek via outfall 006 in accordance with Texas Pollutant discharge Elimination system (TPDES) Permit no. WQ0002496000.

The surface water elevation in the West BAP is controlled by a weir box and a manually operated gate valve on a 36-inch-diameter discharge pipe at the southeast corner of the pond. Clear water overflow from the West BAP discharges through the 36-inch diameter pipe into a 2.7 acre Clearwater Pond located southeast of the West BAP. Water in the Clearwater Pond is either pumped (re-circulated) back into the boiler ash hopper, or gravity discharged through a pipe at the southwest corner of the Clearwater Pond into an unnamed intermittent tributary of Hatley Creek via outfall 006 in accordance with Texas Pollutant discharge Elimination system (TPDES) Permit no. WQ0002496000.

15.0 SUMMARY CONSTRUCTION SPECIFICATIONS AND PROVISIONS FOR SURVEILLANCE, MAINTENANCE AND REPAIR 275.73 (c)(1)(xi)

[The construction specifications and provisions for surveillance, maintenance, and repair of the CCR unit.]

Readily available portions of the original construction specifications are included in Appendix B.

As required by the CCR rules the East and West Bottom Ash Ponds are inspected at least every 7 days by a qualified person. Instrumentation data is collected at least every 30 days and reviewed by AEP Engineering Services. Also as a requirement of the CCR rules the impoundment is also inspected annual by a professional engineer.

If repairs are found to be necessary during any inspection they will be completed as needed.


16.0 RECORD OR KNOWLEDGE OF STRUCTURAL INSTABILITY 275.73 (c)(1)(xii)

[Any record or knowledge of the structural instability of the CCR unit.]

To date there has been no known record of knowledge of the structural instability of the CCR unit.

ATTACHMENT A

LOCATION MAP



THIS DRAWING IS CLASSIFIED AS:

AEP PUBLIC

REFERENCE AEP's CORPORATE INFORMATION SECURITY POLICY

"THIS DRAWING IS THE PROPERTY OF THE **AMERICAN ELECTRIC POWER SERVICE CORP.** AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE **AMERICAN ELECTRIC POWER SERVICE CORP.** OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST"

SOUTHWESTERN ELECTRIC POWER CO

HENRY W. PIRKEY

SOUTH HALLSVILLE TEXAS

EAST/WEST BOTTOM ASH POND
USGS TOPO MAP
7.5-MINUTE SERIES

UNIT:
1

DRAWING NUMBER:
LOCATION MAP

REV:
1

SCALE: 1"=2000'

CIVIL ENGINEERING

DR:

CH:

SUP:

ENG:

DATE: 10/12/16



AEP SERVICE CORP.
1 RIVERSIDE PLAZA
COLUMBUS, OH 43215

ATTACHMENT B

DESIGN REPORTS

HENRY W. PIRKEY POWER PLANT

DESIGN SUMMARY FOR LIGNITE STORAGE
AREA AND WASTEWATER POND FACILITIES

REPORT PREPARED FOR

SOUTHWESTERN ELECTRIC POWER COMPANY

JANUARY 31, 1983

TABLE OF CONTENTS

	PAGE
I INTRODUCTION	1
II SUMMARY AND CONCLUSIONS	2
III DESIGN OF LIGNITE STORAGE AREA AND WASTEWATER POND FACILITIES	3
A. General	3
B. Lignite Storage Area and Runoff Basin Design	5
C. Surge Pond Design	8
D. Bottom Ash Basin and Secondary Pond Design	10
E. Metal Cleaning Waste Pond Design	12
IV GROUNDWATER MONITORING PROGRAM	12
APPENDIX A - Soil Borings Logs for Lignite Storage Area and Wastewater Pond Facilities	

LIST OF EXHIBITS

- 1 - General Site Layout
- 2 - Summary of Parameters Suggested as Guidelines and Parameters Obtained for Design of Henry W. Pirkey Wastewater Ponds
- 3 - Plant Water Usage and Waste Water Scheme - Sheets 1 and 2
- 4 - Boring Location Plan
- 5 - Lignite Storage Area and Runoff Basin Plan and Cross Sections
- 6 - Summary of Laboratory Test Results on Soil Boring Samples Related to Lignite Storage Area and Wastewater Pond Design
- 7 - Surge Pond Plan and Cross Sections
- 8 - Summary of Laboratory Permeability Test Results on Cohesive Soils Intended for Use as In Situ Clay Lining
- 9 - Bottom Ash Basins and Secondary Pond Plan and Cross Sections
- 10 - Metal Cleaning Waste Pond Plan and Cross Sections
- 11 - Summary of Wastewater Pond Sizing Data
- 12 - Proposed Monitoring Well Locations and Typical Details

HENRY W. PIRKEY POWER PLANT
DESIGN SUMMARY FOR LIGNITE STORAGE
AREA AND WASTEWATER POND FACILITIES

SOUTHWESTERN ELECTRIC POWER COMPANY

I INTRODUCTION

This report is prepared by Sargent & Lundy (S&L) at Southwestern Electric Power Company's (SWEPCO) request to summarize the design of the lignite storage area and the wastewater pond facilities with regard to technical guidelines and requirements of the Texas Department of Water Resources (TDWR). The technical guidelines referenced in this report are Technical Guide Nos. 4 and 6 titled Ponds and Lagoons, and Monitoring/Leachate Collection Systems respectively. Guide No. 4 was revised March 1, 1978 and Guide No. 6 March 21, 1980. We understand that the TDWR has the responsibility of preparing and issuing document approval for disposal of wastes. Requirements concerning waste storage and disposal and concerning the design, construction, and monitoring of wastewater pond facilities are discussed in this report.

The wastewater pond facilities discussed in this report and shown in Exhibit 1 are the lignite pile runoff basin, surge pond, two

bottom ash storage basins, secondary settling pond, and the metal cleaning waste pond. Discussion of other waste treatment facilities such as the sanitary sewage treatment plant, the cooling pond, and the final treated Flue Gas Desulfurization (FGD) sludge disposal site are not within the scope of this report and, therefore, not included.

II SUMMARY AND CONCLUSIONS

Based on the evaluation of the site subsurface soil and water conditions, it is concluded that the design of the Henry W. Pirkey wastewater ponds conforms with the technical guidelines and requirements of the TDWR.

Nine groundwater monitoring wells will be located adjacent to the wastewater ponds. These wells will be designed and installed to requirements equal to or exceeding those suggested by the TDWR.

A summary of design guidelines and requirements suggested by the TDWR and those used for design of the Henry W. Pirkey wastewater ponds is given in Exhibit 2.

III DESIGN OF LIGNITE STORAGE AREA AND WASTEWATER POND FACILITIES

A. General

The general site layout is shown in Exhibit 1. The plant water usage and waste water scheme is shown on Exhibit 3. The lignite storage area, lignite pile runoff basin, metal cleaning waste pond, and surge pond have been sized to accommodate two units. Each bottom ash basin will accommodate storage of hydraulically placed ash for two units for 6 months. When one bottom ash basin is filled, storage will begin in the second basin while the first basin is being emptied and readied for reuse. The in-service bottom ash basin will also receive the discharge from the ash hopper pit sump pumps.

Effluent from the bottom ash basins will discharge to the secondary settling pond. Blowdown from the main and auxiliary boilers will also be routed to the secondary pond. Water collected in the secondary settling pond will be recirculated back to the plant to transport bottom ash. Excess water is pumped to the waste water treatment plant for treatment prior to release.

Drainage from the lignite and limestone storage areas and handling systems will be collected via ditches and routed to

the lignite pile runoff basin. The contents of the lignite pile runoff basin will normally not require more treatment than sedimentation. Once the suspended solids are within acceptable limits, the basin contents will be discharged to the cooling pond by means of a sluice gate. If treatment other than gravity settling is required, the contents of the lignite pile runoff basin will be pumped to the wastewater treatment plant prior to release.

The surge pond is divided into two sections: the main surge pond and an auxiliary surge pond. The auxiliary surge pond is a collection and settling pond for scrubber waste slurry, either from the FGD system waste slurry pumps, thickener underflow pumps, or filtrate overflow sump pumps. These slurry flows will be routed to the auxiliary surge pond only under emergency conditions and allowed to thicken by gravity settling. The sludge formed when the slurry thickens will be removed by front end loader and conveyed to the sludge treatment system for stabilization. The water decanted from the thickened slurry, and not evaporated, will drain to the surge pond. In emergencies, the auxiliary surge pond overflows to the surge pond.

The main surge pond is a collection basin for various FGD waste streams. Drains, overflows, backwash, blowdown, and surface drainage from the FGD system will drain to the surge pond. The reclaim water sump will overflow to the surge pond.

Rainwater runoff from the sludge truck load out area, from under the sludge conveyors, and from the sludge reclaim area will drain to the surge pond by gravity. The water decanted from the auxiliary surge pond will drain to the surge pond. The collected water in the surge pond will be pumped to the thickeners for removal of sediment and used as make-up for the SO₂ scrubbers. Drainage entering the surge pond will not leave the plant except as makeup to the scrubbers, as water hydrated with the stabilized FGD sludge, or through evaporation.

Waste from air heater wash, precipitator wash and boiler chemical cleaning is discharged to the metal cleaning pond for storage. This pond is designed to accommodate all the wastewater containing heavy metals generated in 24 hours by cleaning all the three air heaters associated with one unit. Water collected in the metal cleaning waste pond will be pumped to the waste water treatment system for processing before being discharged to the cooling pond.

B. Lignite Storage Area and Runoff Basin Design

The location and layout of the lignite storage area and lignite pile runoff basin are shown on Exhibit 1. Five borings have been drilled in this area and their locations are shown on Exhibits 4 and 5. Copies of the boring logs are included in Appendix A. Based on the results of the boring

)

data, the lignite storage area and lignite pile runoff basin are located over surface soil deposits of dense silty sand and sandy silt (SM and ML Unified Soil Classification). A summary of the laboratory test results on samples from these borings is given in Exhibit 6. All soil borings and soil laboratory test results given in this report, with the exception of Boring B14, have been drilled and tested by NFS/National Soil Services, Inc., Dallas, Texas. Boring B14 was drilled and tested by East Texas Testing Laboratory, Inc., Tyler, Texas. Complete laboratory index property and permeability test results for all samples from borings located in or near wastewater pond facilities are included in Exhibit 6. Also included for reference are index property and permeability values for various types of soils from other onsite borings.

)

The lignite pile runoff basin is an above and below ground pond designed to store lignite pile and limestone pile runoff. Plan and cross sections are shown in Exhibit 5. The lignite storage pile will be underlain by two feet of compacted cohesive fill (SC, CL, and CH Unified Soil Classification). The drainage ditches transporting runoff from the storage area to the basin will be lined with minimum 18 inches of compacted cohesive fill. The runoff basin will be lined on the bottom and side slopes with a minimum three feet of compacted cohesive fill. The dike fill, including lining, will be compacted as specified to a minimum 95 percent maximum density in accordance with ASTM D698. These requirements are in

)

accordance with the guidelines suggested by the TDWR for wastewater ponds.

A summary of the parameters used for the lignite pile runoff basin design in comparison to those parameters and guidelines suggested by the TDWR is given in Exhibit 2. The runoff basin design parameters equal or exceed the minimum recommended values except for depth to the water table. Average or median parameter values are given where several individual tests or measurements were made. The only suggested parameter not obtainable is the TDWR recommendation that the bottom of the basin be 10 feet above the water table. The water table varies throughout the site, and with normal pool of the cooling pond at elevation 340.0 ft., it is possible that the static water table may be located within 3 feet of the bottom of the clay lining of any of the plant's wastewater ponds. Despite this, the presence of relatively homogeneous impermeable in situ and compacted clay layers should provide sufficient lining and protection of the groundwater.

Compacted clay linings are required on the bottom and side slopes of the lignite pile runoff basin and beneath the lignite storage pile. Project specifications require these compacted linings to be cohesive soils with minimum 40% passing the no. 200 sieve and having a minimum plasticity index of 15. The linings are to be compacted to minimum 95% maximum density in accordance with ASTM D698. The perme-

ability of the compacted linings is estimated to be less permeable than or equal to 1.0×10^{-7} cm/sec. This will be verified by SWEPCO by testing field samples in the laboratory during or after construction.

C. Surge Pond Design

The location and layout of the surge pond are shown on Exhibit 1. Four borings have been drilled in this area and their locations are shown on Exhibits 4 and 7. Copies of the boring logs are included in Appendix A. Based on the results of the boring data, the surge pond is located within or above a thick surface deposit of silty and sandy clay (CL and CH Unified Soil Classification). The thickness of the in situ clay soils below the bottom of the pond (approximately elevation 350 ft) ranges from two and one half to 16 feet. A summary of the laboratory test results on samples from the surge pond borings is given in Exhibit 6.

The surge pond (including auxiliary surge pond) is an above and below ground pond. Dikes and excavated slopes are designed with three horizontal to one vertical side slopes. Dike fill will be cohesive soil compacted to a minimum 95 percent maximum density in accordance with ASTM D698. Typical surge pond cross sections are shown on Exhibit 7.

In situ cohesive soils will be used to function as the pond

) lining. Verification of the quality and thickness of the in situ lining will be made during or after construction by SWEPCO. As previously stated, the borings indicate that the thickness of the in situ lining ranges from approximately two and one half to 16 feet. Any compacted cohesive linings required will meet the density, index property, and permeability requirements as given for the lignite runoff basin.

) Exhibit 2 summarizes the TDWR suggested parameters and guidelines and those parameters used for the surge pond design. Comparison of the design parameters obtained and those suggested indicate that in almost every case the obtained parameters equaled or exceeded the suggested value. The only suggested parameter not obtainable is the recommended 10 ft. depth to the groundwater table. It is possible that the groundwater table could eventually be located within 3 ft. of the bottom of the clay lining of the pond, as previously discussed.

Six laboratory permeability tests were performed on samples of undisturbed clay soil from the surge pond area. Results are given in Exhibit 8 and indicate a median permeability value of 5.1×10^{-8} cm/sec. The permeability test values ranged from 2.1×10^{-6} cm/sec. to 7.4×10^{-9} cm/sec.

D. Bottom Ash Basin and Secondary Pond Design

The location and layout of the bottom ash basins and secondary pond are shown on Exhibit 1. Plan and cross sections are shown in Exhibit 9. Nine borings have been drilled in this area. Their locations are given in Exhibits 4 and 9. Copies of the boring logs are included in Appendix A. Based on the results of the boring data, the secondary pond, bottom ash basin no. 1 and the east half of bottom ash basin no. 2 are located within or above a thick surface deposit of silty and sandy clay. These soils are classified as SC, CL, and CH material. A summary of the laboratory test results on samples from those borings is given in Exhibit 6. Results of approximately 23 tests on cohesive soils representing in situ lining indicate average fines content and plasticity index values of 78% and 36, respectively. These values significantly exceed the minimum values suggested by the TDWR.

Bottom ash basin no. 1 is an above and below ground pond located entirely in a cohesive soil deposit. The thickness of the cohesive soil below the bottom of the pond is greater than 5 feet. The plan and cross sections are given in Exhibit 9. A compacted clay lining is shown and will be used where required. In situ lining of acceptable quality and thickness exist in most of the area. This will be verified in the field during construction by SWEPCO. Shallow borings, test pits, and laboratory testing will be performed as necessary.

Bottom ash basin no. 2 is also an above and below ground pond.

A portion of this pond (west half) will require a minimum three feet thick compacted clay lining. The location where an acceptable in situ lining does not exist and where the compacted lining begins will be determined and verified in the field by SWEPCO.

The secondary pond has a bottom elevation of 344 feet. This is three feet or more below the lowest point in either bottom ash basin. During borrow excavation and construction of the embankment, the existing clay may be completely removed from areas within the pond. Where this occurs, a three foot thick compacted clay lining will be installed to the requirements of project specifications and the technical guidelines suggested by the TDWR. This will be verified in the field by SWEPCO.

Exhibit 2 summarizes the TDWR parameters and guidelines and those parameters used for the design of the bottom ash basins and the secondary pond. As indicated in Exhibit 2, the design parameters meet or exceed nearly all of the suggested values. The only suggested parameter not obtainable is the recommended depth to the groundwater table as previously discussed. The median permeability from ten laboratory tests on samples of in situ cohesive soils (generally CH classification) is approximately 7.5×10^{-9} cm/sec. The permeability of clay soils used for compacted cohesive linings (SC, CL, and CH classification) is estimated to be less than or equal to 1.0×10^{-7} cm/sec. The permeability of the compacted lining will be verified by

SWEPCO by testing field samples in the laboratory during and after construction.

E. Metal Cleaning Waste Pond

The location and layout of the metal cleaning waste pond are shown on Exhibit 1 and 10. The pond lies between the surge pond and the bottom ash basins. Borings located near the metal cleaning waste pond are shown in Exhibit 4. Review of the boring data indicates that the pond is located within or above a thick surface deposit of silty and sandy clay. Evaluation of the boring data is similar to that of the bottom ash basins.

The metal cleaning waste basin is an above and below ground pond. Plan and cross sections are given in Exhibit 10. The pond will require a minimum three feet thick clay lining where sufficient in situ clay does not exist at the design elevation. SWEPCO will verify the quality and acceptability of the lining, whether in situ or compacted.

IV GROUNDWATER MONITORING PROGRAM

Nine groundwater monitoring wells are to be installed at locations adjacent to the wastewater pond facilities. The wells will be installed after completion of pond construction. The approximate

locations of these wells are given in Exhibit 12.

Four-inch diameter monitoring wells will be used because they permit use of a portable submersible pump for obtaining samples for water quality analysis. Each slotted screen for each well will be located in the most permeable soils occurring below the water table. A soil boring will be drilled at each well location to accurately define the soil strata adjacent to the well and to finalize the location and design of the well. The soils are very dense and range from a medium fine sand and silty sand to clayey sand and silty clay. The length of the screens have not yet been determined but are expected to range from 15 to 25 feet.

Technical Guide No. 6, published by the TDWR, presents guidelines for design and installation of monitoring wells. The H. W. Pirkey monitoring wells will equal or exceed these guidelines.

The groundwater monitoring program will consist of measuring and recording groundwater levels and obtaining samples for water quality analysis. The frequency for measuring levels and obtaining samples has not yet been determined. Measurements and samples will be obtained by SWEPCO and should begin at least two years before the power plant begins operation. This will allow for sufficient background data against which to compare all subsequent measurements and analyses of samples taken at the site.



Sargent & Lundy, by

D. G. Bodine

D. G. Bodine
Supervisor,
Geotechnical Division

Kenneth T. Kelly

SUMMARY OF PARAMETERS SUGGESTED AS GUIDELINES AND
PARAMETERS OBTAINED FOR DESIGN OF HENRY W. PIRKEY WASTEWATER PONDS

Parameter (1)	Suggested Guideline (1)	Parameter Values Used for Design of Pirkey Wastewater Ponds		Bottom Ash Basins, Secondary Settling Pond and Metal Cleaning Waste Pond
		Lignite Runoff Basin Surge Pond	Specified C _r > 95% CL, CH, and SC	
Above Ground Dikes & Berms Fill Compaction Fill Classification (5)	C _r > 95% Standard Proctor K ≤ 1x10 ⁻⁷ cm/sec Dike or Excavation Slopes	Specified C _r ≥ 95% CL, CH, and SC Km ≤ 1.0x10 ⁻⁷ cm/sec (2) 3H to 1V	Specified C _r > 95% CL & CH Km ≤ 1.0x10 ⁻⁷ cm/sec (2) 3H to 1V	Specified C _r > 95% CL & CH (lined slope) Km < 1.0x10 ⁻⁷ cm/sec (2) 3H to 1V
Pond Compacted or In situ Cohesive Lining Thickness	3 ft.	> 3 ft. (compacted) K ≤ 1x10 ⁻⁷ cm/sec	5 to 17 ft. (in situ) Km ≈ 5.1x10 ⁻⁸ cm/sec (3)	3 to 17 ft. (in situ & compacted) Km ≤ 1.0x10 ⁻⁷ cm/sec Km ≈ 7.5x10 ⁻⁹ cm/sec (in situ) (4)
Permeability, K				
Liquid Limit, LL Plasticity Index, PI Fines Content, FC Classification	LL ≥ 30% PI ≥ 15 FC ≥ 30% CL, CH, OH, and SC	LL > 30% PI > 15 FC ≥ 40% CL, CH, & SC	average LL = 54% average PI = 36 specified FC ≥ 40% CL & CH	average LL = 78% average PI = 36 average FC = 78% CL & CH
Below Ground Pond Permeability, K	K < 1x10 ⁻⁷ cm/sec	Below ground area of pond will be lined with 3 ft. of compacted cohesive material CL & CH material	Values given above are representative of insitu cohesive soils. Compacted lining 3 ft. in thickness will be placed where required	Values given above are representative of insitu cohesive soils. Compacted lining 3 ft. in thickness will be placed where required
Groundwater Monitoring Well Depth to Water Table Below Pond	Yes, Required 10 ft. Recommended	Two 4 in. Diameter Gravel Pack Wells Approximately 3 ft., See Report Text	Two 4 in. Diameter Gravel Pack Wells Approximately 3 ft., See Report Text	Two and Five 4 in. Diameter Gravel Pack Wells for Metal Cleaning Waste Pond and Bottom Ash Basins, respectively 3 ft., See Report Text

- NOTES: (1) Parameters and Guidelines given are suggestions stated
in the Texas Department of Water Resources Technical
Guides No. 4 revised March 1, 1978, and No. 6 revised
March 21, 1980.
(2) Estimated. To be verified by SWEPCo during or after
construction.
(3) Median permeability from six tests on undisturbed
cohesive soil samples.

- (4) Median permeability from ten tests on undis-
turbed soil cohesive soil samples.
(5) Classification symbols used in this Exhibit
are in accordance with the Unified Soil
Classification System and ASTM D2487.
(6) Standard Proctor Test performed in accordance
with ASTM D698.

**SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)**

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)				
B-14,	J-2	3.0-4.5				38	18	20	CL	22.0	
	T-4	9.5-11.0				56	26	30	CH	35.9	
	J-5	13.0-14.5				51	22	29	CH	29.8	
	J-6	18.0-19.5				28	22	6	SM-SC	26.6	
	J-7A	23.0-24.0				25	21	4	SM-SC	29.6	
P-108,	Bag 1	0-1.0				38	14	24	CL		
	Bag 2	1.0-3.5				65	21	44	CL	98.8	
	T-3	3.5-5.0				45	17	28	CH	26.9	
	T-4	8.5-10.0				76	21	55	CH	21.7	
	J-5	13.5-15.0							CH	35.7	
	J-6	13.5-15.0							CH		
	J-7	13.5-15.0							CH		
	J-8	18.5-20.0							CH		
	J-9	18.5-20.0							CH		
	J-10	18.5-20.0							CH		
	J-11	23.5-25.0							CH		
	J-12	23.5-25.0							SC		
	J-13	23.5-25.0							SC		
	J-14	28.5-30.0							SC		
	J-15	28.5-30.0							SC		
	J-16	28.5-30.0							SC		
	J-17	33.5-35.0							SC		
	J-18	33.5-35.0							SC		
						33			SC	25.6	

NOTES:

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas Texas for OW and P-Series Borings. Laboratory testing performed by East Texas Testing Laboratory, Inc., Tyler, Texas for B-Series Borings.
- (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.
- (5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test procedure in accordance with EM 1110-2-1906.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)				
P-108,	J-20	38.0-39.5				30	11	19	SM	25.0	
	J-21	43.5-45.0				34	18	16	SM	18.6	
	J-23	43.5-45.0				19	12	7	SC	19.8	
	J-24	48.5-50.0							SM-SC	20.3	
	J-25	53.0-54.5							SC		
	J-26	58.0-59.5							SC	22.2	
	J-27	58.0-59.5				28	13	15			
P-109, Bag 1	0-1.0								SC		
	Bag 2	1.0-3.5							SC		
	T-3	3.5-5.0							CH	20.9	
	T-4	8.5-10.0							CH	33.1	
	J-6	13.5-15.0							CH		
	J-7	13.5-15.0							CH		
	J-10	18.5-20.0							CH		
	J-11	18.5-20.0							CH		
	J-12	23.5-25.0							CH		
	J-13	23.5-25.0							CH		
	J-16	28.5-30.0							CH		
	J-18	33.5-35.0							CH		
	J-19	33.5-35.0							CH		
	J-20	38.5-40.0							CH		
	J-21	38.5-40.0							CH		

NOTES:

(1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.

(2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.

(3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.

(4) Moisture Content of Soils performed in accordance with ASTM D2216.

(5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 1110-2-1906.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)				Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index				
OW-9,	Bag 1	0-1.0							CL			
	Bag 2	1.0-3.5							CL			
T-1	3.5-5.0								CL			
T-2	7.0-8.5	100	99	51		39	15	24	CL			
T-3	9.5-11.0								CL			
T-4	13.5-14.0	97	95	57	15	37	19	18	SM			
J-5	15.5-16.5								CH			
J-6	18.5-19.5								SC			
J-7	18.5-19.5								SC			
J-8	18.5-19.5								CL			
J-9	23.5-25.0											
J-10	23.5-25.0	100	95	30								
J-11	23.5-25.0											
J-12	28.5-30.0											
J-13	28.5-30.0	100	97	45								
J-14	33.5-35.0											
J-15	38.5-40.0											
J-16	38.5-40.0	100	99	84								
P-126, T-1	0-2.0	95	93	72	51	17	34	CH				
T-2	3.0-6.0	95	93	89	62	21	41	CH				
T-3	6.0-8.0											
T-4	9.0-12.0	98	98	89	63	23	39	CH				
J-5	13.5-15.0				45	20	25	CL				

NOTES:

Exhibit 6
Page 3 of 12

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas Texas for OW and P-series Borings.
- (2) Laboratory Particle Size Analysis Tests Performed in accordance with ASTM D422 and ASTM D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.
- (5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 1110-2-1006.
- (6) Laboratory Permeability determined using remolded sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 1110-2-1906.

5.84x10⁻⁹ (6)
3.07x10⁻⁹ (5)
7.12x10⁻⁹ (5)

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)				
P-126, J-7	13.5-15.0										
J-8	18.5-20.0	59	41	22	19			CL			29.8
J-10	18.5-20.0			40				SM			28.5
J-11	23.5-24.0			7				SM			26.7
J-12	28.5-29.5							SC			22.7
J-13	33.0-34.0							SC			
J-15	34.0-35.0	99	94	24		19	15	SC			19.4
J-16	38.5-40.5							SC			26.6
J-19	43.5-44.5							SC			
P-130, T-1	0-2.0										
T-2	3.0-6.0	99	99	55	40	20	20	SM			5.1x10 ⁻⁸ (5)
T-3	6.0-9.0							CL			
T-4	9.0-12.0	98	97	96	68	27	41	CL			1.4x10 ⁻⁸ (5)
J-5	13.5-15.0							CH			33.2
J-7	13.5-15.0							CH			31.6
J-8	18.5-20.0							SC			26.7
J-10	18.5-20.0							CH			
J-11	23.5-25.0							SM			25.4
J-13	23.5-25.0							SM			27.6
J-14	28.5-30.0							SM			24.1
J-16	33.5-40.0							SM			24.1
J-18	43.5-45.0							SM			23.6
J-22	48.5-50.0							SM			

- NOTES:
- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas Texas for OW and P-series Borings.
 - (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
 - (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
 - (4) Moisture Content of Soils performed in accordance with ASTM D2216.
 - (5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 110-2-1906.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing)				Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index				
P-141, T-1	3.0-6.0	99	99	98	98	94	35	69	CH	9.3x10 ⁻¹⁰ (5)	1.3x10 ⁻⁸ (5)	
	9.0-12.0					74	25	49	SM			
	15.0-18.0					73	25	48	CH			
	18.0-19.0								CH			
	19.0-20.0					64	25	39	CH			
	23.5-25.0	100	96	87					CH			
	23.5-25.0								CH			
J-6	28.5-30.0					77	56	28	CH	16.6	37.5	
	33.5-35.0								SM			
	33.5-35.0								SC			
	44.0-45.0					22						
P-143, T-1	0-1.5					75	59	19	40	20.4	104.4	
	1.5-3.0					89	72	23	49			
	3.0-5.5					97	49	18	31			
	5.5-8.0					94	71	21	50			
	8.0-11.0					37	30	15	15			
	11.0-12.5											
	13.5-15.0					61						
	13.5-15.0									23.9	19.4	
	13.5-15.0											
	18.5-20.0											
	23.5-25.0											
	28.5-30.0											
	33.5-35.0											
	38.5-40.0											
						100	92		ML			

NOTES:

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.
- (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.
- (5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 1110-2-1906.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density 1bs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)				
P-124, T1	3.0-6.0	99	98	77	44	17	27	CL	16.6		
T2	9.0-12.0	100	99	77	53	17	36	CH	24.8		
J3	13.5-15.0				22	26	12	SC		25.5	
J5	18.5-20.0									26.9	
J7	18.5-20.0										
J8	23.5-25.0										
J10	23.5-25.0										
J11	28.5-30.0										
J13	28.5-30.0										
J14	33.5-35.0										
J16	33.5-35.0										
J17	38.5-40.0										
J19	43.5-45.0										
P-138, T1	0-2.0	94	90	30	20			SM	12.4		
T2	3.0-6.0				33			SM		110.7	
T3	9.0-12.0							SM			
J4	13.5-15.0							SC	21.1		
J6	13.5-15.0										
J7	18.5-20.0										
J9	18.5-20.0										
J10	23.5-25.0										
J12	28.5-29.5										
J13	33.5-35.0										
J14	43.5-45.0										
J16	43.5-45.0										

NOTES:

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas Texas for OW and P-Series Borings. Laboratory testing performed by East Texas Testing Laboratory, Inc., Tyler, Texas for B-Series Borings.
- (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D422.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)			Atterberg Limits (3)		Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)			
OW-10, Bag 1	0-1.5									
	1.5-3.0									
	3.0-3.5									
	3.5-5.0									
	J-3	87	75	67	40	43	17	26	SC	23.0
	J-4				35	52	19	33	SC	26.6
	J-6	13.5-15.0			36				SC	31.1
	J-8	18.5-20.0								21.4
	J-10	18.5-20.0								26.6
	J-11	23.5-25.0								22.8
J-13	23.5-25.0									
	J-14	28.5-29.5								
	J-16	33.5-35.0								
	J-18	33.5-35.0								
	J-19	38.5-39.5								
P-139, Bag 1	0-2.0									
	2.0-3.5									
	3.5-5.0									
	J-4	96	92	89	35				SM	15.0
	J-5									
	J-6	8.5-10.0								
	J-7	8.5-10.0								
	J-8	8.5-10.0								
	J-9	13.5-15.0								
	J-10	13.5-15.0								
	J-11	13.5-15.0	100	100	99	48	20	28	CL	23.6

- NOTES:
- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.
 - (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
 - (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
 - (4) Moisture Content of Soils performed in accordance with ASTM D2216.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index			
P-139, J-12	18.5-20.0	100	100	68							
J-13	18.5-20.0										
J-14	23.5-25.0										
J-15	23.5-25.0										
J-16	23.5-25.0										
J-17	28.5-29.0	100	99	99	50	11					
J-18	34.0-35.0										
J-19	34.0-35.0										
J-20	38.5-39.0										
J-21	38.5-39.0										
J-22	48.5-49.0										
J-23	53.5-54.0										
J-24	58.5-59.0										
J-25	63.5-64.0										
J-26	73.5-74.0										
J-27	73.5-74.0										
J-28	78.5-79.0										
J-29	88.5-90.0										
J-30	88.5-90.0										
J-31	88.5-90.0										
J-32	93.5-95.0										
J-33	98.5-100.0										
J-34	98.5-100.0										
J-35	98.5-100.0										
J-36	108.5-110.0										
J-37	118.0-119.0										
J-38	128.0-129.0										
J-39	128.0-129.0										
J-40	128.0-129.0										
J-41	138.5-139.0										
J-42	138.5-139.0										
J-44	148.0-149.0										

- NOTES:
(1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.
(2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
(3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
(4) Moisture Content of Soils performed in accordance with ASTM D2216.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

- ### NOTES:

- Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for UW and F-Series burnings.

- Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASIM B114U.

- Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.

- Moisture Content of Soils Performed in accordance with ASTM D2216. Laboratory Permeability Test performed on undisturbed Shelby tube sample. Test Procedure in accordance with EM 110-2-1906.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)				Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)					
P-144, Bag 1	0-2.0											
	2.0-3.0	94	91	56	32	32	14	18				
J- 3	4.0-5.0		100	99	72				CL	12.2		
J- 4	4.0-5.0								ML	12.1		
J- 5	9.0-10.0											
J- 6	10.0-11.0			100	46							
J- 7	14.0-15.0								SM	13.4		
J- 8	14.0-15.0			100	99	29			SM	22.7		
J- 9	19.0-20.0											
J-10	19.0-20.0					20				SM	19.5	
J-11	23.5-24.5											
J-12	23.5-24.5			100	99	24				SM	23.2	
J-13	29.0-30.0											
J-14	29.0-30.0					16					SM	23.7
J-15	34.0-35.0											32.6
J-16	34.0-35.0											
J-17	39.0-40.0											
J-18	39.0-40.0											
J-19	44.0-45.0											
J-20	44.0-45.0											
J-21	49.0-50.0											
J-22	49.0-50.0											
P-148, Bag 1	0-2.0											
J- 2	3.5-5.0											
J- 3	3.5-5.0			99	99	21						
J- 4	8.5-10.0			100	99	41						
J- 5	8.5-10.0											
J- 6	13.5-15.0			100	99	31						
J- 7	18.5-20.0											

NOTES:

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.
- (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.

SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (% Passing) (2)				Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index				
P-148, J-8	18.5-20.0		99	98	40				SM	21.5		
J-9	23.5-24.0									21.7		
J-10	23.5-24.0									23.3		
J-11	33.5-34.0											
J-12	33.5-34.0											
J-15	39.0-40.0											
J-16	39.0-40.0											
T-6	13.5-15.0											
OW-5,	Bag 1	0-1.5										
	Bag 2	1.5-3.5										
J-3	3.5-4.5											
J-4	8.5-10.0											
J-5	13.5-15.0											
J-7	18.5-20.0											
J-9	18.5-20.0											
J-10	23.5-24.5											
J-11	28.5-30.0											
J-13	28.5-30.0											
J-14	33.5-35.0											
J-16	33.5-35.0											
J-17	38.5-40.0											
P-119, Bag 8	10.0-11.0		99	99	35				SC	15.1	114.3	2.88x10 ⁻⁷ (6)
Bag 8a	10.0-11.0		99	99	35				SC	15.1	118.1	3.07x10 ⁻⁸ (7)
Bag 12	16.0-18.0		100	99	58				ML	16.3	116.4	7.58x10 ⁻⁸ (7)
Bag 16	22.0-24.0				40				SM	11.9	116.2	2.35x10 ⁻⁷ (7)

NOTES: (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.

(2) Laboratory Particle Size Analysis Tests Performed in accordance with ASTM D422 and ASTM D1140.

(3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and ASTM D424.

(4) Moisture Content of Soils performed in accordance with ASTM D2216.

(5) Laboratory Permeability Test performed on remolded sample using Back Pressure Method in Triaxial Test.

(6) Laboratory Permeability Test performed on sample recompacted to approximately 95 percent standard compaction.


SUMMARY OF LABORATORY TEST RESULTS ON
SOIL BORING SAMPLES RELATED TO LIGNITE STORAGE
AREA AND WASTEWATER POND DESIGN (1)
(continued)

Boring No. Sample No.	Sample Depth, Ft	Particle Size Analysis (2)				Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (0/0)(4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec	
		No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index					
P-119, Bag 20 Bag 24	28.0-30.0 34.0-36.0			47 35					SM SM	16.6 9.9	114.7 117.0	2.12x10 ⁻⁷ 2.11x10 ⁻⁷ (7)	
P-120, T-4 J-8	8.5-10.0 18.5-20.0	100	100	89 29	25	11	14	CL SM	19.7 25.2	110.3	2.3x10 ⁻⁸ (5)		
P-125, J-5 J-7	13.5-15.0 13.5-15.0			63	41	17	24	CL	24.9	106.1	2.36x10 ⁻⁸ (6)		
P-129, T-3	3.0-5.0								SM	15.8	118.2	5.7x10 ⁻⁸ (8)	
P-137, T-3	3.5-5.5				37	16	21	SC	18.7	107.5	1.1x10 ⁻⁷ (5)		
P-137A, T-4	9.5-10.5	100	99	26	31	15	16	SC	10.5		2.75x10 ⁻⁶ (5)		
OW-7, J-3 J-4	3.5-5.0 9.5-10.0				51	17	34	CH	28.2 27.2 23.2 20.8		97.6 96.3		
OW-11 J-6 J-8 J-10	13.5-15.0 18.5-20.0 18.5-20.0	99 89 89	97 84 79	85 61	68 21 40	23 45 40		CH CH CH	30.7 27.5 34.3	95.5	1.34x10 ⁻⁸ (6)		


NOTES:

- (1) Laboratory testing performed by NFS/National Soil Services, Inc., Dallas, Texas for OW and P-Series Borings.
- (2) Laboratory Particle Size Analysis Tests performed in accordance with ASTM D422 and ASTM D1140.
- (3) Laboratory Atterberg Limit Tests performed in accordance with ASTM D423 and D424.
- (4) Moisture Content of Soils performed in accordance with ASTM D2216.
- (5) Laboratory Permeability Test performed on undisturbed Shelby tube sample. Sample tested in oedometer using Falling Head Test Procedure in accordance with EM 1110-2-1906.
- (6) Laboratory Permeability Test performed on sample recompacted to approximately 95 percent standard compaction.
- (7) Laboratory Permeability Test performed on undisturbed sample using back pressure in Triaxial Test.
- (8) Laboratory Permeability Test performed on undisturbed sample using Fall Cone Test.

EXHIBIT 8



- NOTES:
- (1) KM = MEDIAN PERMEABILITY IN CM/SEC
 - (2) SEE EXHIBIT 5 FOR DESCRIPTION OF PERMEABILITY TEST PERFORMED
 - (3) ALL LABORATORY PERMEABILITY TESTING PERFORMED BY NFS/NATIONAL SOILS SERVICE, INC., DALLAS, TEXAS



**SUMMARY OF LABORATORY PERMEABILITY TEST RESULTS
ON COHESIVE SOILS INTENDED FOR USE AS INSITU
CLAY LININGS**

SUMMARY OF WASTEWATER POND SIZING DATA

Pond	Top of Dike Elevation, Ft.	Pond Design Level Ft.	Bottom Level, Ft.	Volume @ NOL or PDL Acre Ft.	NOL or PDL Acres	Sizing Basis
Bottom Ash Basin #1	357.0	354.6	347.0	188 (1)	31.0 (2)	541 TPH burn rate, 70% load factor, 20% average ash, 65pcf ash density, 1 year storage for 1 unit plus 1.5 ft. freeboard over one in 100 year rainfall
Bottom Ash Basin #2	357.0	354.6	347.0	188 (1)	30.8 (2)	
Secondary Pond	359-357	352.0	344.0	12	2.6	
Surge Pond	358-359	355.0	347 - 352	21	4.0	Waste slurry flow from one unit's scrubber at full load for 4 days; 657,148 lb/hr slurry discharge
Lignite Pile Runoff Basin	356.0	353 .0	346.0	28.6	45.0	To store 10 year - 24 hour runoff from lignite and limestone piles, material handling structures and limestone preparation area.
Metal Cleaning Waste Pond	360 .0	356.5	348.0	12.0	1.9	To store a volume of 12.0 acre-ft plus the runoff from a once-in-ten-year 24-hour rainfall event

NOTES: (1) Maximum ash capacity.
(2) Surface area at maximum pool.

EXHIBIT I






EXHIBIT 4




BORING SCHEDULE			
BORING	LOCATION	DEPTH IN FEET	REMARKS
N#	NORTH	EAST	
B-1	301,889	2,932,769	COMPLETED OCT 1977
B-2	301,889	2,931,989	
B-3	300,889	2,931,111	
B-4	300,889	2,933,269	
B-5	299,889	2,931,269	
B-6	299,889	2,931,269	
B-7	298,889	2,931,269	
B-8	293,589	2,931,269	
B-9	297,889	2,931,269	
B-10	297,889	2,931,989	
B-11	296,589	2,931,269	
B-12	299,789	2,933,269	NOT DRILLED
B-13	297,889	2,931,769	COMPLETED OCT 1977
B-14	302,889	2,931,169	COMPLETED JAN 1978
B-15	305,449	2,930,569	
B-16	302,589	2,931,969	
B-17	301,889	2,930,349	
B-18	301,449	2,932,769	COMPLETED JAN 1978
P-100	322,789	2,928,329	40
P-101	322,769	2,932,269	40
P-102	322,719	2,930,969	50
P-103	302,699	2,931,269	50
P-104	302,599	2,930,969	100
P-105	302,539	2,930,319	74
P-106	302,509	2,930,509	74
P-107	302,509	2,930,919	40
P-108	302,589	2,930,579	60
P-109	302,489	2,929,359	40
P-110	302,389	2,930,199	80
P-111	302,374	2,930,289	80
P-112	302,374	2,930,379	100
P-113	302,389	2,930,509	74
P-114	302,309	2,930,869	80
P-115	302,289	2,929,969	120
P-116	302,289	2,929,769	80
P-117	302,289	2,930,109	80
P-118	302,289	2,930,509	100
P-119	302,229	2,932,859	40
P-120	302,219	2,931,149	80
P-121	302,209	2,929,669	80
P-122	305,050	2,931,450	60
P-123	305,120	2,931,499	80
P-124	304,500	2,931,000	50
P-125	302,049	2,929,089	50
P-126	301,510	2,929,700	50
P-127	302,049	2,929,369	80
P-128	302,049	2,929,859	80
P-129	302,049	2,930,919	80
P-130	302,410	2,929,557	50
P-131	301,759	2,933,369	80
P-132	301,689	2,930,219	80
P-133	302,589	2,929,669	100
P-134	301,649	2,929,044	50
P-135	301,649	2,929,169	50
P-136	301,649	2,929,444	50
P-137	305,620	2,927,720	80
P-138	304,000	2,927,550	50
P-139	301,459	2,929,759	200
P-140	301,309	2,929,779	80
F-1	304,500	2,929,000	50
F-12	303,700	2,929,050	40
F-13	300,889	2,929,929	50
P-141	301,559	2,928,219	40
P-142	300,629	2,929,429	40
DW-1	301,339	2,930,869	1/4" DEPTH WATER TUBE
DW-2	302,289	2,929,529	1/4" DWI OBSERVATION WATER TUBE
DW-3	302,509	2,930,619	1/4" DWI OBSERVATION WATER TUBE
DW-4	302,000	2,928,250	1/4" DWI OBSERVATION WATER TUBE
DW-5	300,919	2,929,169	1/4" DWI OBSERVATION WATER TUBE
DW-6	302,630	2,928,200	1/4" DWI OBSERVATION WATER TUBE
DW-7	303,950	2,926,950	1/4" DWI WATER TUBE
DW-8	305,410	2,921,350	1/4" DWI WATER TUBE
DW-9	303,339	2,928,169	1/4" DWI WATER TUBE
DW-10	304,650	2,927,150	1/4" DWI WATER TUBE
DW-11	303,350	2,928,450	1/4" DWI WATER TUBE
A-35	302,400	2,931,750	1/4" DWI WATER TUBE
A-36	301,880	2,931,269	1/4" DWI WATER TUBE
A-37	301,330	2,931,750	1/4" DWI WATER TUBE
A-40	301,890	2,933,780	1/4" DWI WATER TUBE
A-41	301,200	2,935,540	1/4" DWI WATER TUBE
A-42	301,500	2,934,050	1/4" DWI WATER TUBE
D-2	302,599	2,930,189	35
D-3	302,289	2,930,189	35
D-4	302,300	2,931,920	35
D-5	302,459	2,933,324	35
D-6	302,444	2,933,619	55
D-7	302,369	2,931,269	45
D-9	302,411	2,933,995	50
D-10	302,559	2,930,119	40
D-11	301,339	2,932,139	50
D-12	301,159	2,932,329	120
D-13	301,104	2,930,444	120
F-1	302,752,92	2,931,636,42	75
F-2	302,806,67	2,932,046,23	75
F-3	302,705,54	2,932,549,30	75
F-4	302,492,26	2,932,830,85	75
F-5	301,168,59	2,933,129,12	70
F-6	301,848,05	2,933,689,92	45
F-7	301,316,63	2,933,851,99	45
F-8	301,673,63	2,933,580,89	45

BORING LOCATION PLAN

SARGENT & LUNDY
ENGINEERS





SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

COHESIVE LINING CONSTRUCTION VERIFICATION PROGRAM
FOR LIGNITE STORAGE AREA AND
WASTEWATER POND FACILITIES

I. INTRODUCTION

Southwestern Electric Power Company (SWEPCo) has committed to providing verification that their insitu and compacted cohesive linings for the lignite storage area and wastewater pond facilities have been constructed in accordance with project specifications and guidelines suggested by the Texas Department of Water Resources (TDWR). The wastewater pond facilities requiring verification are the lignite pile runoff basin, surge pond, two bottom ash storage basins, secondary settling pond, and the metal cleaning waste pond. Also requiring verification is the compacted cohesive lining placed beneath the lignite storage pile and for ditches transporting runoff from the pile to the runoff basin.

A summary of the design of the lignite storage area and wastewater pond facilities with respect to the guidelines suggested by the TDWR was presented in a report for SWEPCo dated January 31, 1983. In this report, which may have been submitted to the TDWR, SWEPCo has committed to the verification. This report should be reviewed concerning the applicable guidelines suggested by the TDWR and the lining and dike requirements specified. The wastewater

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

pond facilities and lignite storage area earthwork construction is included in the scope of project specification H-4533.

II. SCOPE

The cohesive lining construction verification program will include the following for each of the wastewater pond facilities and lignite storage area.

- a. A listing of all the field density tests performed on cohesive lining material during construction.
A statistical summary of field dry density, field water content, and percent compaction.
- b. Results of any laboratory testing performed on samples representing cohesive lining material during construction.
- c. Results of laboratory testing on^{continuous} undisturbed samples obtained from the in-place (compacted or insitu) cohesive lining after construction. The laboratory testing will consist of sample classification, grain size, atterberg limit, and falling or contant head permeability tests. If construction of the lining has not been completed at the time this program begins, as is the case with the Metal Cleaning Waste Pond, samples should be obtained during construction.

SARGENT & LUNDY
ENGINEERS
CHICAGO

)
Southwestern Electric Power Company
Henry W. Pirkey Power Plant

Results of the laboratory testing and field density test summary will be compared to project specifications and TDWR guidelines to document compliance. Details of the laboratory test program are given in Section III of this report.

III. LABORATORY TEST PROGRAM FOR COHESIVE LINING SAMPLES

)
Twenty-two undisturbed shelby tube samples shall be obtained from the cohesive lining of the six wastewater ponds and lignite storage area. The thin-walled shelby tube samples shall be in accordance with ASTM D1587. The tube shall be 3 inches outside diameter and having a length such that a minimum 24-inch sample can be obtained. Tubes may be field extruded, unless otherwise directed by the purchaser. If extruded, the entire sample shall be placed in approved containers, properly labeled and transported to the laboratory. A field log shall be prepared for all extruded samples.

Dwg. HP-56 shows the approximate location of all test samples. These locations will be staked and surveyed by the purchaser prior to beginning field work. Any pond containing water will have to be pumped dry. Most samples are located within the bottom lining of the pond or area. Some samples are located in the lining of the dike slope. Drilling or other suitable equipment shall be used to obtain the samples.

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

The testing contractor shall inspect the site prior to beginning the sampling, but after the locations are staked to ensure that the proper equipment is brought to the site.

After sampling each or a group of locations, each borehole shall be filled with CH clay obtained on site and compacted in 6-inch layers with suitable heavy hand tampers. Testing contractor shall make with purchaser all necessary arrangements to assure that all holes are properly filled and compacted to prevent any future pond leakage due to sampling.

) The required laboratory testing is given in Table 1. All samples shall be properly classified and test results reported as required in standards.

TABLE I - LABORATORY TEST REQUIREMENTS

Sample Number	Laboratory Classification ASTM D 2437	Atterberg Limits ASTM D 423 & D 424	Grain Size Analysis ASTM D 422 Hydrometer	Grain Size Analysis ASTM D 1140 Fines Content	Laboratory Permeability (2) EM 1110-2-1906
S-1	X	X	X		X
S-2	X	X		X	X
S-3	X	X		X	X
S-4	X	X	X		X
S-5	X	X		X	X
S-6	X	X		X	X
S-7	X	X		X	X
S-8	X	X	X		X
S-9	X	X		X	X
S-10	X	X		X	X
S-11	X	X		X	X
S-12	X	X	X		X
S-13	X	X		X	X
S-14	X	X		X	X
S-15	X	X	X		X
S-16	X	X		X	X
S-17	X	X		X	X
S-18	X	X	X		X
S-19	X	X		X	X
S-20	X	X		X	X
S-21	X	X	X		X
S-22	X	X		X	X

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

Ground Water Monitoring Program for Lignite Storage Area and
Wastewater Pond Facilities

I. INTRODUCTION

The Lignite Storage Area and Wastewater Pond Facilities at the H. W. Pirkey Station are situated generally west of the main plant area. The original topography ranges in elevation from 325 feet to 375 feet, mean sea level. The ponds are underlain by a series of stiff clay strata and dense silty sand strata. Pond and basin linings consist of in-situ cohesive soils, where available, or compacted cohesive fill where the in-situ lining thickness is less than 3 feet.

Groundwater occurs under water table conditions between elevations varying from 320 ft. in the low lying areas to 350 feet in the higher elevations. Recharge of the water table is primarily from infiltration of precipitation. Groundwater discharge is to Brandy Branch Creek, which drains the site south and east of the lignite storage area, and to Hatleys Creek, which drains the area north and west of the lignite storage area. Brandy Branch Creek will be dammed to provide a cooling pond.

The proposed ground water monitoring program consists of two phases:

- 1) A pre-operational phase during which baseline data are established and interpreted.
- 2) An operational phase during which ground water levels and ground water quality are monitored in order to identify the impact of the various ponds and drainage basins.

The proposed ground water monitoring program includes periodic measurement of groundwater levels and groundwater quality in monitoring wells installed specifically for these purposes within the area. Additional data collected for the groundwater monitoring program should include daily cooling pond level and precipitation measurements.

II. OBJECTIVES

The objectives of the proposed groundwater monitoring program are:

- 1) Identification of the potentiometric surface, general direction of groundwater movement, and hydraulic gradient for the aquifer(s), including seasonal fluctuations, in the vicinity of the ponds;

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

- 2) Establishment of baseline groundwater quality data prior to operation of the plant;
- 3) Monitoring of changes in groundwater levels that may result from infiltration from the various ponds and drainage basins;
- 4) Monitoring of groundwater quality during plant operation;
- 5) Early detection and determination of the level of contamination and general direction of movement away from the source.

III. PHYSICAL ARRANGEMENT

Single-level groundwater monitoring wells are proposed at ten locations. The locations of these monitoring wells are indicated on Dwg. HP-56. Construction details for the single-level monitoring wells are shown on Exhibit 2.

The single-level monitoring wells are screened in the upper portions of the water table or confined aquifers where the concentration of contaminants should be highest. In addition, the concentration of contaminants should decrease through the saturated thickness of the aquifer as a result of hydrodynamic dispersion.

The well locations have been chosen so that one well is located hydraulically upgradient from the active portion of the facilities and at least one monitoring well is installed hydraulically downgradient of the active area. The upgradient well will yield samples representative of the background quality of the groundwater which flows under the facility. The downgradient well is located as close as possible to the facility where it will provide the greatest opportunity for interception of migrating leachate and provide an early warning of groundwater contamination.

The proposed single-level monitoring well, shown on Exhibit 2, is a 10-inch by 4-inch, sand-pack installation. The 4-inch diameter CPVC casing is preferable to a 2-inch diameter casing because the larger diameter will facilitate collecting groundwater samples using a portable submersible pump rather than by bailing of the well. The upper portion of the annular space will be backfilled with an impermeable material to prevent surface water from entering the well bore.

IV. INSTALLATION OF GROUNDWATER MONITORING WELLS

- A. Contractor shall drill a 10-inch minimum diameter borehole as indicated on the attached exhibits. The borehole shall be fully cased during drilling with a

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

temporary 10-inch minimum diameter steel casing. Larger diameter borehole and casing may be used only if approved in advance by the Consulting Engineers and the Purchaser. The use of bentonite drilling mud to hold the borehole open will not be permitted. Once the designated depth has been reached, Contractor shall flush the casing with clear water until clear water returns to the surface. The use of biodegradable drilling mud (revert) in lieu of a fully cased borehole to hold the hole open will be permitted if Contractor can show to the satisfaction of the Purchaser and the Consulting Engineers that he can satisfactorily install and disinfect the monitoring well.

- B. Contractor shall collect representative split-spoon soil samples at five foot intervals and at changes in strata during drilling. Contractor shall prepare a boring log showing the stratigraphy and groundwater level during drilling.
- C. Option: Contractor may drill an initial borehole of diameter less than 10-inches to collect samples and then ream to a large diameter for the installation of the well screen, casing, and sand pack.
- D. Once the soil stratigraphy and groundwater level have been determined, Purchaser's representative shall confirm the intended installation details for the groundwater monitoring well as indicated in Exhibit 2. These details shall include stratigraphy, total depth, screened interval, length and depth of granular backfill, thickness and depth of the bentonite seal, and length of grout seal. Purchaser shall approve the installation details prior to the installation.
- E. Contractor shall construct the groundwater monitoring well from 4-inch diameter CPVC 4120, Schedule 40 casing as specified in ASTM F441 attached to a 20-foot length of 4-inch diameter PVC well screen with a bottom cap. Solvent cement and pipe cleaner for joining sections of CPVC pipe, fittings, and the PVC well screen shall be a type specifically intended for its use. The slot size of the well screen shall be 0.010 inch. A 9-inch diameter perforated PVC disk or equivalent device shall be attached to the bottom of the well point to permit centering of the well point in the borehole.
- F. Upon placement of the CPVC casing and well screen in the borehole, Contractor shall fill the annular space between the CPVC casing-well screen assembly and 10-inch temporary casing with clean concrete sand (graded per ASTM C-33) to 5 feet above the top of the PVC well screen. The backfill material may be allowed to settle through the water in the steel casing. The 10-inch diameter casing shall be pulled back to 3 feet above the well screen while backfilling with the clean, concrete sand. During the sand backfilling the casing shall not be pulled back above the top of the sand.

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

- G. After placement of the sand backfill, Contractor shall settle the backfill around the well point by pumping water from the PVC well screen. Sufficient sand shall be added to the annular space to maintain the level of sand backfill at 5 feet above the top of the well screen. Pumping shall continue intermittently until the discharge water is clear and soil free or until pumping is stopped by Purchaser's representative. Disposal of water discharged from the monitoring well during pumping shall be as directed by Purchaser.
- H. After settlement of the sand backfill, place two feet of bentonite in the annular space between the CPVC casing and the outer casing to prevent any movement of the cement grout into the granular backfill. If granular bentonite is used, it shall be placed through a conductor pipe using the tremie or other method as approved by the Purchaser. If bentonite pellets are used, they may be allowed to settle through the water around the CPVC casing. If the water table is below the bentonite seal, add clear water during this process to hydrate the bentonite. When bentonite pellets are used, sufficient length of time shall be allowed for the bentonite to form a seal over the sand backfill before placing grout. After placement and hydration of the bentonite seal, the outer casing shall be pulled to one foot below the top of the bentonite seal.
- I. After placement of the bentonite seal, Contractor shall fill the remaining annular space between the CPVC casing and borehole with cement-bentonite grout, placed by the tremie method from the bottom upward or by an alternative method approved by Purchaser. The 10-inch steel casing shall be pulled simultaneously with placement of the grout. A positive head of grout shall be maintained in the temporary casing at all times during the placement. The grout mix shall be approximately 7 gallons of water with 3 pounds of powdered bentonite per 94-pound sack of Portland cement. The bentonite and water shall be mixed first to provide a smooth slurry, then the cement shall be added to the slurry and blended to a smooth consistency.
- J. Contractor shall terminate the CPVC casing 3 feet above grade and shall install a vented, removable PVC cap such that the CPVC casing is not restricted by the cap or coupling. Contractor shall cut a small notch in the rim of the CPVC casing to mark the point from which all level measurements are to be made. This point shall be clearly marked on the CPVC casing with an indelible marking.
- K. Contractor shall install a 6-foot length of 8-inch diameter protective steel casing 3 feet into the cement-bentonite grout. Contractor shall fill the annular space between

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

casings with cement-bentonite grout to within 6 inches of the top of the CPVC casing. A threaded steel cap with ventilation hole shall be provided for the protective casing. An 18-inch long rebar shall be welded to the top of the steel cap to facilitate its removal during groundwater sampling. Contractor shall paint the protective casing and its cap with fluorescent type paint. Contractor shall clearly and permanently mark the protective casing with the appropriate alphanumeric designation.

- L. Contractor shall construct a concrete apron at the ground surface to provide drainage away from the monitoring well, to prevent movement of water down the side of the steel casing, to prevent erosion, and to provide permanence to the monitoring well. The concrete apron shall be at least 2 feet in diameter and 6 inches in thickness.
- M. After the monitoring wells are installed, Contractor shall survey the locations and the elevations of the measuring points on the well casings.

V. DISINFECTION OF WELLS

- A. Immediately after completion of well, disinfect it by circulating a chlorine solution through the well, let set for the period specified, then pump the solution from the well, and discharge it as directed.
- B. Disinfecting Agent:
 - a. The disinfecting agent shall be liquid sodium hypochlorite, NaOCl, or granular calcium hypochlorite, Ca(ClO)₂. Calcium hypochlorite shall not be used where the concentration of calcium in the groundwater will exceed 300 ppm after addition of the disinfecting solution. The choice of disinfecting agent is subject to approval by the Consulting Engineer.
 - b. The disinfecting agent used in the solution shall be delivered to the Project Site in the original, unopened dated containers. Prior to use, the disinfecting agent shall not be exposed to air or direct sunlight.
- C. Disinfection Procedure:
 - a. Determine depth to water and depth to the bottom of the well from a common measuring point. Calculate the height of the water column in the well (depth to bottom of well minus depth to water, in feet).
 - b. Calculate the total volume of water ($V=V_1+V_2$) in both the well (V_1 in gallons) and sand pack (V_2 in gallons)

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant


where V (in gallons) equals the height of the water column times 1.5.

- c. With the pump intake located as near the water level as possible, pump the well to remove at least 5 volumes of water, $5x(V)$. Pump until discharge water is clear. Then, lower the pump intake to the bottom of the well. Pump at least 1.5 volumes of water, $1.5x(V)$, until discharge water is clear. Additional pumping levels may be required at the discretion of the Consulting Engineer. This step may be deleted if disinfection is performed immediately after well installation.
- d. Mix a solution of disinfectant by adding a measured amount of calcium or sodium hypochlorite to a known volume of clear water to provide at least a 200 ppm chlorine solution when mixed with the total volume, V, of water in the well. The amount of disinfecting agent to be added to clear water depends on the initial concentration of hypochlorite. The volume of clear water added shall be no less than the total volume of water, V.
- e. After approval of the disinfection solution mix by the Consulting Engineer, place the solution in the well in such a manner that it is thoroughly distributed throughout the entire column of water in the well. Add an extra dosage to the bottom of the well. Make certain that the dry portion of the well casing above the water level is also wetted. This may be accomplished by tremie or by pumping the solution through a hose moved through the well from the bottom up, or by another acceptable method as approved by the Consulting Engineer. Well disinfection by pouring the solution from the top of the well is not acceptable.
- f. Recirculate the solution in the well by pumping from the bottom of the well and reintroducing the discharged solution into the top of the well. During recirculation, the portion of the well casing above the water table shall be maintained in a wet condition with the solution. The length of the recirculation period will be determined by the Consulting Engineer, but will not be less than 30 minutes nor more than two hours. Measure the residual free chlorine concentration at the end of the recirculation period.
- g. After recirculation, the solution shall remain in the well for a minimum of eight hours. Replace the well caps for this period.

SARGENT & LUNDY
ENGINEERS
CHICAGO

Southwestern Electric Power Company
Henry W. Pirkey Power Plant

- h. After the eight hour or longer period, the well shall be pumped to clean it of solution. Purchaser will determine the residual free chlorine concentration at the beginning of pumping to assure that complete disinfection has occurred. The method of determining the concentration shall be approved by the Consulting Engineer.
- i. If the residual free chlorine concentration is greater than or equal to 1.0 ppm, the disinfection of the well will be assumed to be complete. The well shall then be pumped for at least two hours, but not more than four hours, to remove the solution from the well and surrounding aquifer. Vary the depth of the pump intake in the well while pumping, from the top of the water column to the bottom of the well, and back to the top again. Dispose of the water pumped from the well as directed by Purchaser.
- j. If the residual free chlorine concentration is less than 1.0 ppm, pump the solution from the well as indicated in step "c." above and repeat the disinfection procedure.



WELL No.	EL."A"	EL."B"	EL."C"	"D"	EL."E"
MW-1	330	323	303	5'	334
MW-2	327	320	300	5'	339
MW-3	342	335	315	5'	370
MW-4	347	340	320	5'	364
MW-5	347	340	320	5'	362.5
MW-6	347	340	320	5'	361
MW-7	347	340	320	5'	358.3
MW-8	351	344	324	5'	356.3
MW-9	348	344	324	2'	353.1
MW-10	347	340	320	5'	357.6

NOTES

1. DRAWING NOT TO SCALE.
2. WELL SHALL BE DISINFECTED UPON COMPLETION.
3. LOCATION OF GROUNDWATER QUALITY MONITORING WELLS IS SHOWN ON EXHIBIT I.

EXHIBIT 2
GROUNDWATER QUALITY MONITORING
WELL DETAIL
 HENRY W. PIRKEY POWER PLANT
 SOUTHWESTERN ELECTRIC POWER CO.

W. H. HILLIX
Office of


APR 30 1984

RECORDED

J. A. Wilson (1/1)
D. G. Bodine (1/1)
E. R. Weaver (1/1)
F. J. Pruet (1/1)
A. I. Melson (1/1)
W. H. Holler (1/1)

Copies:
Enclosure
CJN: Jg

Structural Project Engineer
Charles J. Nelson


Yours very truly

use.
that we can reissue the appropriate number of copies for your review the revisions and return any comments you have to us so been indicated in the right-hand margin with an "R". Please ponds which are not bounded by the permit. The revisions have to Mr. F. J. Emmett. The revisions address overflows from the report which has been revised per your letter, dated December 20, enclosed are two copies of the wastewater ponds. Permit Data

Dear Mr. Scott:

Mr. M. J. Scott
Southwestern Electric Power Company
P. O. Box 21106
Shreveport, Louisiana 71156

Data Report - Revisions
wastewater ponds Permit

Henry W. Pirkey Power Plant
Southwestern Electric Power Company
Unit 1

File No. 5.8.1
Project No. 555-02
April 25, 1984

TWX 910-221-2807

(312) 269-2000

CHICAGO, ILLINOIS 60603

55 EAST MONROE STREET

FOUNDED 1891

SARGENT & LUNDY

ENGINEERS

REVISED: APRIL 25, 1984

JANUARY 31, 1983

SOUTHWESTERN ELECTRIC POWER COMPANY

REPORT PREPARED FOR

DESIGN SUMMARY FOR LIGNITE STORAGE
AREA AND WASTEWATER POND FACILITIES

HENRY W. PIKE POWER PLANT

TABLE OF CONTENTS

PAGE

I	INTRODUCTION
II	SUMMARY AND CONCLUSIONS
III	DESIGN OF LIGNITE STORAGE AREA AND WASTEWATER POND FACILITIES
A.	General
B.	Lignite Storage Area and Runoff Basin Design
C.	Surge Pond Design
D.	Bottom Ash Basin and Secondary Pond Design
E.	Metal Cleaning Waste Pond Design
IV	GROUNDWATER MONITORING PROGRAM
APPENDIX A -	Soil Borings Logs for Lignite Storage Area and Wastewater Pond Facilities

- 1 - General Site Layout
- 2 - Summary of Parameters Suggested as Guidelines and Parameters
Obtained for Design of Henry W. Pirkey Wastewater Ponds
- 3 - Plant Water Usage and Waste Water Scheme - Sheets 1 and 2
- 4 - Boring Location Plan
- 5 - Lignite Storage Area and Runoff Basin Plan and Cross Sections
- 6 - Summary of Laboratory Test Results on Soil Boring Samples
Related to Lignite Storage Area and Wastewater Pond Design
- 7 - Surge Pond Plan and Cross Sections
- 8 - Summary of Laboratory Permeability Test Results on Cohesive
Soils Intended for Use as In Situ Clay Linings
- 9 - Bottom Ash Basins and Secondary Pond Plan and Cross Sections
- 10 - Metal Cleaning Waste Pond Plan and Cross Sections
- 11 - Summary of Wastewater Pond Sizing Data
- 12 - Proposed Monitoring Well Locations and Typical Details

LIST OF EXHIBITS

The wastewater pond facilities discussed in this report and shown in Exhibit I are the lignite pile runoff basin, surge pond, two

This report is prepared by Sargent & Lundy (S&L) at Southwestern Electric Power Company's (SWEPCO) request to summarize the design of the lignite storage area and the wastewater pond facilities with regard to technical guidelines and requirements of the Texas Department of Water Resources (TDWR). The technical guidelines referenced in this report are Technical Guide Nos. 4 and 6 titled Ponds and Lagoons, and Monitoring/Leachate Collection Systems respectively. Guide No. 4 was revised March 1, 1978 and Guide No. 6 March 21, 1980. We understand that the TDWR has the responsibility of preparing and issuing document approval for disposal of wastes. Requirements concerning waste storage and disposal and monitoring the design, construction, and monitoring of wastewater concerning the design, construction, and monitoring of wastewater ponds are discussed in this report.

INTRODUCTION

SOUTHWESTERN ELECTRIC POWER COMPANY

AREA AND WASTEWATER POND FACILITIES

DESIGN SUMMARY FOR LIGNITE STORAGE

HENRY W. PIRKEY POWER PLANT

A summary of design guidelines and requirements suggested by the TDWR and those used for design of the Henry W. Pirkey wastewater ponds is given in Exhibit 2.

Nine groundwater monitoring wells will be located adjacent to the wastewater ponds. These wells will be designed and installed to requirements equal to or exceeding those suggested by the TDWR.

Based on the evaluation of the site subsurface soil and water conditions, it is concluded that the design of the Henry W. Pirkey wastewater ponds conforms with the technical guidelines and requirements of the TDWR.

II SUMMARY AND CONCLUSIONS

bottom ash storage basins, secondary settling pond, and the metal cleaning waste pond. Discussion of other waste treatment facilities such as the sanitary sewage treatment plant, the cooling pond, and the final treated flue gas desulfurization (FGD) sludge disposal site are not within the scope of this report and, therefore, not included.

The ash basins and secondary pond, acting as a system, have been provided with additional capacity above the normal operating level to capture and hold the 10 year-24 hour runoff from the basin and pond drainage areas. A spillway has been

R back to the plant to transport bottom ash.

Collected in the secondary settling pond will be recycled boilers will also be routed to the secondary pond. Water secondary settling pond. Blowdown from the main and auxiliary effluent from the bottom ash basins will discharge to the

sump pumps.

basin will also receive the discharge from the ash hopper pit emptied and readied for reuse. The in-service bottom ash begin in the second basin while the first basin is being months. When one bottom ash basin is filled, storage will accommodate two units. Each bottom ash basin will accommodate waste pond, and the surge pond have been sized to cleanings water and waste water scheme is shown on Exhibit 3. The lignite storage area, lignite pile runoff basin, metal

The general site layout is shown in Exhibit 1. The plant

A. General

WASTEWATER POND FACILITIES

III DESIGN OF LIGNITE STORAGE AREA AND

R Water captured in the lignite pile runoff basin will not

R level due to the 100 year-24 hour runoff.

The lignite pile runoff basin has been provided above the maximum water runoff and freeboard has been provided to discharge excess runoff from the 100 year-24 hour design to overflow, the spillway has been designed to protect against damage due to overflow, the spillway has been basins dikes from damage due to overflow, the spillway has been overflows is not subject to permit limitations. To protect in conformance with the NPDES permit. The quality of these to discharge inflows in excess of the 10 year-24 hour runoff area with no overflow. An auxiliary spillway has been provided hold the entire 10 year-24 hour runoff from the basin drainage basin has been designed to capture and

The lignite pile runoff basin.

Drainage from the lignite and limestone storage areas and handling systems will be collected via ditches and routed to wastewater treatment plant for treatment prior to discharge.

R

of the 10 year-24 hour runoff in conformance with the NPDES provided for the secondary pond to discharge inflows in excess permit limitations. To protect the basin and pond dikes from been provided above the maximum water level resulting from the 100 year-24 hour runoff. Excess water accumulated in the secondary pond due to rainfall runoff will be pumped to the handligning systems will be collected via ditches and routed to the lignite pile runoff basin.

The main surge pond is a collection basin for overflows from the auxiliary surge pond and several additional waste streams. Surface drainage from the FGD system and the reclaim water sump overflow will also drain into the surge pond. Rainwater runoff from the sludge truck load out area, from under the

The surge pond is divided into two sections: the main surge pond and the auxiliary surge pond. The auxiliary surge pond is a collection and settling pond for scrubber waste slurry, from the FGD system waste slurry pumps, thicker underflow from the EGD system waste slurry pumps, and filterate overflow sump pumps. These slurry flows will be routed to the auxiliary surge pond only under emergency conditions and allowed to thicken by gravity settling. The sludge formed when the slurry thickens will be removed by front end loader and conveyed to the sludge treatment system for stabilization. The water decanted from the thickened slurry, and not evaporated, will overflow to the thickened slurry, and not evaporated, will overflow to the

normally require more treatment than sedimentation to lower the total suspended solids content prior to release. Once the suspended solids are within acceptable limits, the basin contents will be discharged to the cooling pond by gravity in a normally closed pipe outlet. However, if treatment other than gravity settling is required, the contents of the lignite pile runoff basin will be pumped to the wastewater treatment plant prior to release.

data, the lignite storage area and lignite pile runoff basin included in Appendix A. Based on the results of the boring shown on Exhibits 4 and 5. Copies of the boring logs are borings have been drilled in this area and their locations are lignite pile runoff basin are shown on Exhibit 1. Five the location and layout of the lignite storage area and

B. Lignite Storage Area and Runoff Basin Design

before being discharged to the cooling pond.

Water collected in the metal cleaning waste pond will be pumped to the waste water treatment system for processing. Water containing all the three air heaters associated with one unit. Water containing heavy metals generated in 24 hours by water containing waste is designed to accommodate all the waste storage. This pond is designed to the metal cleaning pond for chemical cleaning is discharged to the metal cleaning pond for collection with the stabilized FGD sludge, or through evaporation.

Leave the plant except as makeup to the scrubbers, as water thickeners for removal of sediment and used as make-up for the colected water in the surge pond will be pumped to the auxiliary surge pond will drain to the surge pond. The surge pond by gravity. The water decanted from the sludge conveyors, and from the sludge reclaim area will drain hydrated with the stabilized FGD sludge, or through evaporation.

7

are located over surface soil deposits of dense silty sand and sandy silt (SM and ML Unfilled Soil Classification). A summary of the laboratory test results on samples from these borings is given in Exhibit 6. All soil borings and soil laboratory test results given in this report, with the exception of Borings BL4, have been drilled and tested by NFS/National Soil Services, Inc., Dallas, Texas. Boring BL4 was drilled and tested by East Texas Testing Laboratory, Inc., Tyler, Texas. Complete laboratory index property and permeability test results for all samples from borings located in or near waste water pond facilities are included in Exhibit 6. Also results for all samples from borings located in or near waste water pond designed to store lignite pile and limestone pile runoff. Plan and cross sections are shown in Exhibit 5. The lignite storage pile will be underlain by two feet of compacted cohesive fill (SC, CL, and CH Unfilled Soil Classification). The basin will be lined with minimum 18 inches of compacted drainage ditches transporting runoff from the storage area to the basin will be lined with minimum 95 percent maximum density compacted as specified to a minimum 95 percent maximum density in accordance with ASTM D698. These requirements are in accordance with the guidelines suggested by the TDMR for

values for various types of soils from other onsite borings. Included for reference are index property and permeability values for various properties are included in Exhibit 6. Also included for reference are index property and permeability tests of soil samples from borings located in or near waste water ponds to store lignite pile and limestone pile runoff. The lignite storage pile is an above and below ground pond designed to store lignite pile and limestone pile runoff. The lignite pile will be undrained by two feet of compacted cohesive fill (SC, CL, and CH Unfilled Soil Classification). The basin will be lined with minimum 18 inches of compacted drainage ditches transporting runoff from the storage area to the basin will be lined with minimum 95 percent maximum density compacted as specified to a minimum 95 percent maximum density in accordance with the guidelines suggested by the TDMR for

Compacted clay linings are required on the bottom and side slopes of the lignite pile runoff basin and beneath the lignite storage pile. Project specifications require these compacted lignings to be cohesive soils with minimum 40% passing the no. 200 sieve and having a minimum plasticity index of 15. The linings are to be compacted to minimum 95% maximum density in accordance with ASTM D698. The permeability of the compacted linings is estimated to be less

A summary of the parameters used for the lignite pile runoff basin design in comparison to those parameters and guidelines suggested by the TDWR is given in Exhibit 2. The runoff basin design parameters equal or exceed the minimum recommended values except for depth to the water table. Average or median parameter values are given where several individual tests or measurements were made. The only suggested parameter not obtainable is the TDWR recommendation that the bottom of the basin be 10 feet above the water table. The water table varies throughout the site, and with normal pool of the cooling pond at elevation 340.0 ft., it is possible that the static water table may be located within 3 feet of the bottom of the clay lining of any of the plant's wastewater ponds.

Despite this, the presence of relatively homogeneous impervious layers should provide sufficient protection in situ and compacted clay layers should provide sufficient protection in the plant's wastewater ponds.

Client Lining and Protection of the groundwater.

In situ cohesive soils will be used to function as the pond lining. Verification of the quality and thickness of the in

surge pond cross sections are shown on Exhibit 7. Dike fill will be cohesive soil compacted to a minimum 95 percent maximum density in accordance with ASTM D698. Typical dikes will be designed with three horizontal to one vertical side slopes. Dikes and excavated slopes are and below ground pond. Dikes and excavated slopes are designed with three horizontal to one vertical side slopes. The surge pond (including auxiliary surge pond) is an above

surge pond borings is given in Exhibit 6. Summary of the laboratory test results on samples from the clay soils below the bottom of the pond (approximately elevation 350 ft) ranges from two and one half to 16 feet. A thick surface deposit of silt and sandy clay (CL and CH Unfilled Soil Classification). The thickness of the in situ boring logs are included in Appendix A. Based on the results of the boring data, the surge pond is located within or above their locations are shown on Exhibits 4 and 7. Copies of the Exhibit 1. Four borings have been drilled in this area and Exhibit 1. The location and layout of the surge pond are shown on the boring logs are included in Appendix A. Based on the results of the boring data, the surge pond is located within or above their locations are shown on Exhibits 4 and 7. Copies of the

C. Surge Pond Design

permeable than or equal to 1.0×10^{-7} cm/sec. This will be verified by SWEPCO by testing field samples in the laboratory during or after construction.

The Location and Layout of the bottom ash basins and secondary

D. Bottom Ash Basin and Secondary Pond Design

Six Laboratory permeability tests were performed on samples of undisturbed clay soil from the surge pond area. Results are given in Exhibit 8 and indicate a median permeability value of 5.1×10^{-8} cm/sec. The permeability test values ranged from 2.1×10^{-6} cm/sec. to 7.4×10^{-9} cm/sec.

Exhibit 8 and water table could eventually be located within 3 ft. of the bottom of the clay lining of the pond, as previously suggested parameter not obtainable is the recommended 10 ft. It is possible that the depth to the groundwater table. The only suggested parameter exceeded the suggested value. The obtained parameters equalled or exceeded the suggested value. The only suggested indicate that in almost every case the obtained comparison of the design parameters obtained and those lines and those parameters used for the surge pond design. Exhibit 2 summarizes the TDWR suggested parameters and guide-

ability requirements as given for the lignite runoff basin. Required will meet the density, index property, and permeability and one half to 16 feet. Any compacted cohesive linings thickness of the in situ lining ranges from approximately two SWEPCCO. As previously stated, the borings indicate that the situ lining will be made during or after construction by

Bottom ash basin no. 2 is also an above and below ground pond. A portion of this pond (west half) will require a minimum

Bottom ash basin no. 1 is an above and below ground pond located entirely in a cohesive soil deposit. The thickness of the cohesive soil below the bottom of the pond is greater than 5 feet. The plan and cross sections are given in Exhibit 9. A compacted clay lining is shown and will be used where required. In situ lining is shown and will be used where exists in most of the area. This will be verified in the field during construction by SWEPCO. Shallow borings, test pits, and laboratory testing will be performed as necessary.

Pond are shown on Exhibit 1. Plan and cross sections are shown in Exhibit 9. Nine borings have been drilled in this area. Their locations are given in Exhibits 4 and 9. Copies of the boring logs are included in Appendix A. Based on the results of the boring data, the secondary pond, bottom ash basin no. 1 and the east half of bottom ash basin no. 2 are located within or above a thick surface deposit of silt and sandy clay. These soils are classified as SC, CL, and CH material. A summary of the laboratory test results on samples from those borings is given in Exhibit 6. Results of approximately 23 tests on cohesive soils representing in situ lining materials average fine content and plasticity index values of 78% and 36, respectively. These values significantly exceed

SWEPSCO by testing field samples in the laboratory during and permeability of the compacted lining will be verified by is estimated to be less than or equal to 1.0×10^{-7} cm/sec. The for compacted cohesive linings (SC, CL, and CH classification) median permeability of clay soils used matelty 7.5×10^{-9} cm/sec. The permeability of clay soils used situ cohesive soils (generally CH classification) is approximately to the groundwater table as previously discussed. The depth from ten laboratory tests on samples of in median permeability from the laboratory tests on samples of in depth to the groundwater table as previously discussed. The only suggested parameter not obtainable is the recommended parameters meet or exceed nearly all of the suggested values. and the secondary pond. As indicated in Exhibit 2, the design those parameters used for the design of the bottom ash basins and the secondary pond. The only suggested parameter not obtainable is the groundwater table as previously discussed. The depth from the bottom ash basin to the groundwater table is three feet or more below the lowest point in either bottom ash basin. During borrow excavation and construction of the embankment, the existing clay may be completely removed from areas within the pond. Where this occurs, a three foot thick embankment, the secondary pond has a bottom elevation of 344 feet. This is three feet or more below the lowest point in either bottom is three feet thick compacted clay lining. The location where an acceptable in situ lining does not exist and where the compacted lining begins will be determined and verified in the field by SWEPSCO.

Nine groundwater monitoring wells are to be installed at locations adjacent to the wastewater pond facilities. The wells will be installed after completion of pond construction. The approximate locations of these wells are given in Exhibit 12.

IV GROUNDWATER MONITORING PROGRAM

The metal cleaning waste basin is an above and below ground pond. Plan and cross sections are given in Exhibit 10. The pond will require a minimum three feet thick clay lining where pond will require a minimum three feet thick clay lining where sufficient in situ clay does not exist at the design elevation. SWEPCO will verify the quality and acceptability of the lining, whether in situ or compacted.

The location and layout of the metal cleaning waste pond are shown on Exhibit 1 and 10. The pond lies between the surface and the bottom ash basins. The pond lies near the pond and the bottom ash basins. Boreings located near the metal cleaning waste pond are shown in Exhibit 4. Review of the boreing data indicates that the pond is located within or above a thick surface deposit of silt and sandy clay. Evaluation of the boring data is similar to that of the bottom ash

Metal Cleaning Waste Pond

after construction.

D. G. Bodine
Supervisor,
Geotechnical Division

A. A. B. adme

Sargeant & Lundy, by



ments and analyses of samples taken at the site. background data against which to compare all subsequent measurements obtained at the power plant begins operation. This will allow for sufficient samples obtained by SWEPSCO and should begin at least two years before samples has not yet been determined. Measurements and samples will be obtained for measuring levels and obtaining quality analysis. The frequency for measuring levels and obtaining recording groundwater levels and obtaining samples for water monitoring program will consist of measuring and

monitoring wells will equal or exceed these guidelines. for design and installation of monitoring wells. The H. W. Pirkey Technical Guide No. 6, published by the TDWR, presents guidelines

determined but are expected to range from 15 to 25 feet. sand and silt clay. The length of the screens have not yet been dense and range from a medium fine sand and silt sand to clayey fine to the location and design of the well. The soils are very accurately define the soil strata adjacent to the well and to tabular. A soil boring will be drilled at each well location to locate in the most permeable soils occurring below the water table. Each slotted screen for each well will be used because they permit use of a portable submersible pump for obtaining samples for water quality analysis. Each slotted screen for each well will be located in a four-inch diameter monitoring wells will be used because they

COPY

51
SWL
Our analysis indicates that the cohesive linings for the surge Pond, metal cleaning waste pond, bottom ash basins No. 1 and No. 2 and beneath the lignite storage pile are in general accordance with the guidelines suggested by the Texas Department of Water Resources. The average permeability reported for bottom ash basins No. 1 is 2.4×10^{-6} cm/sec. This value is higher than the eight tests run. This one test yielded a 1.1×10^{-5} cm/sec rate for a CH clay sample which leads one to believe that the test may be in error due to a leak in the testing apparatus or a miscalculation. You may want to run this by the laboratory for a check.

Enclosed is a copy of table #1 which was developed by combining the information contained on the field logs and the results of the laboratory test data. From the information contained in table #1, Table #2 was prepared and summarizes our analysis of the test results for each individual pond or lined area.

We have completed our review of the boring logs and results of the laboratory tests made on samples from the borings which you transmitted to us. This work was performed as part of the liner verification program presented to Mr. R. A. Neal with a letter dated February 25, 1983.

Dear Mr. Scott:

Mr. M. J. Scott
Southwestern Electric Power Company
P. O. Box 21106
Shreveport, Louisiana 71156

Wastewater Ponds - Liner
Verification & Monitoring Wells


Henry W. Pirkey Power Plant
Southwestern Electric Power Company
Unit 1

September 14, 1984
Project No. 5555-02
File No. 5.8.1

R. A. NEAL
Chairman of
SPP 20 1984

TWX 910-221-2807
(312) 269-2000
CHICAGO, ILLINOIS 60603
35 EAST MONROE STREET
ENGINEERS
SARGENT & LUNDY

COPY



ENCLOSURE
CJN: jg

- R. A. Neat (1/1)
W. H. Hollery (1/1)
J. A. Prudette (1/1)
F. J. Hammert (1/1)
E. R. Weaver (1/1)
D. G. Bodine (1/1)
J. A. Wilson (1/1)

Hand Ground elev.
S-16
Check elev. of

CHARLES J. NELSON
CHARLES J. NELSON
Yours very truly,

AFTER YOU REVIEW THE DATA BEING TRANSMITTED TO YOU AND WITH YOUR CONCURRENCE WE WILL FORMALIZE THE DATA INTO AN APPENDIX WHICH CAN BE ADDED TO THE WASTEWATER POND DATA REPORT.

A REVIEW OF THESE LOGS INDICATES THAT IF THE WELLS ARE INSTALLED PER THE DETAIL PROPOSED IN THE MONITORING WELL PROGRAM, THEY WILL ENCOUNTER PERVIOUS SANDY SOILS. WELL MW-9 MAY, HOWEVER, NEED TO BE INSTALLED APPROXIMATELY FIVE FEET DEEPER THAN PROPOSED TO INTERSECT A THICKER LAYER OF SANDS.

WE ALSO RECEIVED THE BORING LOGS FOR THE TEN MONITORING WELLS. A REVIEW OF THESE LOGS INDICATES THAT IF THE WELLS ARE INSTALLED PER THE DETAIL PROPOSED IN THE MONITORING WELL PROGRAM, THEY WILL ENCOUNTER PERVIOUS SANDY SOILS. WELL MW-9 MAY, HOWEVER, NEED TO BE INSTALLED APPROXIMATELY FIVE FEET DEEPER THAN PROPOSED TO INTERSECT A THICKER LAYER OF SANDS.

WE HAVE ALSO ENCLOSED A MARKED UP COPY OF THE BORING LOGS CORRECTING THE SOIL CLASSIFICATION BASED ON OUR REVIEW OF THE LABORATORY TEST DATA. PLEASE HAVE THE LABORATORY MAKE THE INDICATED CORRECTIONS AND RE-ISSUE THE LOGS.

BART OF THIS VERTIFICATION PROGRAM WAS ALSO TO CONSIST OF A REVIEW OF THE FIELD DENSITY TEST RECORDS FOR THE LINING MADE DURING CONSTRUCTION SO THAT A STATISTICAL SUMMARY COULD BE PERFORMED. THIS DATA WAS INCLUDED IN YOUR PREVIOUS SUMMARY TRANSMISSION. PLEASE FORWARD US THIS DATA AT YOUR CONVENIENCE.

THE BORINGS AND TESTING FOR THE LIGNATE PILE TUNNEL WAS NOT YET COMPLETED WHEN YOU TRANSMITTED THE DATA. PLEASE FORWARD THIS DATA TO US AS SOON AS IT BECOMES AVAILABLE SO THAT THE TABLES CAN BE COMPLETED. ALSO BORING S-17 IN THE METAL CLEANING POND WAS NOT YET DRILLED.

THE COHESIVE LINING FOR THE SECONDARY POND APPEARS TO BE VERY SANDY OR CONTAINS SAND POCKETS MORE SO ON THE EAST SIDE OF THE POND. THE AREA SHOULD BE INСПЕКTED AND REPAIRED IF NECESSARY TO IMPROVE ITS COHESIVE LINING.

MR. M. J. SCOTT SEPTEMBER 14, 1984 PAGE 2

SARGENT & LUNDY
ENGINEERS CHICAGO

**SUMMARY OF LABORATORY TEST RESULTS FOR
COHESIVE LINING VERIFICATION PROGRAM (1)**

Facility	Boring No.	Sample No.	Particle Size Analysis (%) Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec		
			No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	Liquid Limit (%)	Plastic Limit (%)	Plasticity Index						
			Sample Depth, Ft	Sieve	Sieve	Sieve								
Secondary Pond	S-1	0-2	95	91	88	60	32	18	14	CL-Silty Clay	18.9	-	2.2x10 ⁻⁸	
		2-4	91	88	85	63	28	18	10	CL-Silty Clay	18.3	-	8.5x10 ⁻⁸	
		4-6	-	-	-	-	28	18	10	CL-Sandy Clay	20.3	-	-	
		6.5-8	-	-	-	-	26	18	10	SC-Clayey Sand	22.2	-	-	
		8.5-10	-	-	-	-	-	-	-	CL-Sandy Clay	27.1	-	7.2x10 ⁻⁸	
	S-2	0-2	-	-	-	-	-	29	17	12	CL-Sandy Clay	19.0	-	7.6x10 ⁻⁸
		2-4	-	-	-	-	35	18	17	CL-Sandy Clay	23.0	-	-	
		4.5-6	-	-	-	-	42	21	21	CL-Sandy Clay	23.1	-	-	
		6.5-8	-	-	-	-	33	18	15	CL-Silty Clay	24.1	-	-	
		8.5-10	-	-	-	-	35	18	17	CL-Sandy Clay	23.4	-	-	
S-3	0-2	0-2	-	-	-	-	32	28	18	SC-Clayey Sand	20.4	-	8.7x10 ⁻⁶	
		2-4	-	-	-	-	31	19	12	SC-Clayey Sand	23.7	-	1.1x10 ⁻⁵	
		4-6	-	-	-	-	37	31	18	SC-Clayey Sand	23.9	-	-	
	8.5-10	6.5-8	-	-	-	-	-	-	-	CL-Sandy Clay	26.9	-	-	
		8.5-10	-	-	-	-	-	-	-	CL-Sandy Clay	30.0	-	-	
		8.5-10	-	-	-	-	-	-	-	CL-Silty Clay	21.2	-	6.8x10 ⁻⁹	
BA-B#1	S-4	0-2	100	100	100	75	36	19	17	CL-Silty Clay	19.4	-	1.8x10 ⁻⁸	
		2-4	100	100	100	76	34	18	16	CL-Silty Clay	19.3	-	-	
	4-6	-	-	-	-	-	-	-	-	CL-Silty Clay	-	-	-	

- Notes: 1. Laboratory Testing Performed by Southwestern Laboratories, Shreveport, LA.
 2. Laboratory Particle Size Analysis Tests - ASTM D422 or D1140.
 3. Laboratory Atterberg Limit Tests - ASTM D423 and D424.
 4. Laboratory Moisture Content of Soils - ASTM D2216.

TABLE 1.

SUMMARY OF LABORATORY TEST RESULTS FOR
COHESIVE LINING VERIFICATION PROGRAM (1)

Facility	Boring No.	Sample No.	Particle Size Analysis (%) Passing) (2)			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
			No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	Liquid Limit	Plastic Limit	Plasticity Index				
			Sieve	Sieve	Sieve	(%)	(%)	(%)				
Surge Pond	S-12	0-2	-	-	99	92	39	19	20	CL-Silty Clay	23.7	-
		2-4	-	-	98	95	52	22	30	CH-Silty Clay	26.3	-
		4-6	-	-	-	-	61	23	38	CH-Silty Clay	23.2	-
Metal Cleaning Pond	S-13	0-2	-	-	-	-	76	38	18	CL-Sandy Clay	21.3	3.6×10^{-8}
		2-4	-	-	-	-	69	32	15	CL-Sandy Clay	19.1	6.6×10^{-8}
		4-6	-	-	-	-	-	-	-	CL-Sandy Clay	17.7	-
	S-14	0-2	-	-	-	99	51	20	31	CH-Silty Clay	31.4	9.2×10^{-8}
		2-4	-	-	-	98	48	20	28	CL-Silty Clay	29.8	1.3×10^{-8}
		4-6	-	-	-	-	-	-	-	CL-Silty Clay	29.2	-
	S-15	Not Drilled Yet	-	-	-	-	-	-	-	-	-	-
	S-16	0-2	-	-	59	44	21	23	CL-Sandy Clay	23.6	2.7×10^{-8}	
		2-4	-	-	80	45	20	25	CL-Sandy Clay	23.1	1.3×10^{-8}	
		4-6	-	-	-	29	19	10	SC-Clayey Sand	23.5	-	
	S-17	0-2	-	-	89	48	20	28	CL-Silty Clay	27.8	6.1×10^{-8}	
		2-4	-	-	93	49	20	29	CL-Silty Clay	27.2	4.3×10^{-8}	
		4-6	-	-	-	23	17	6	SC-Clayey Sand	18.1	-	

Notes: 1. Laboratory Testing Performed by Southwestern Laboratories, Shreveport, LA.

2. Laboratory Particle Size Analysis Tests - ASTM D422 or D1140.

3. Laboratory Atterberg Limit Tests - ASTM D423 and D424.

4. Laboratory Moisture Content of Soils - ASTM D2216.

**SUMMARY OF LABORATORY TEST RESULTS FOR
COHESIVE LINING VERIFICATION PROGRAM (1)**

Page 3

Facility	Boring No.	Sample No.	Depth, Ft	Particle Size Analysis			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Dry Density lbs/ft ³	Laboratory Permeability cm/sec
				No. 4 Sieve	No.10 Sieve	No.40 Sieve	Liquid Limit	Plastic Limit	Plasticity Index				
				4.5-6	55	54	17	15	-				
Bottom Ash Basin #1	S-5	0-2	-	-	-	81	38	19	19	CL-Sandy Clay	20.9	-	4.9x10 ⁻⁷
		2-4	-	-	-	75	36	18	18	CL-Sandy Clay	21.5	-	8.1x10 ⁻⁸
		4-5-6	-	-	-	-	-	-	-	CL-Sandy Clay	24.3	-	-
Bottom Ash Basin #2	S-6	0-2	-	-	-	32	17	15	15	CL-Silty Clay	22.4	-	7.4x10 ⁻⁶
		2-4	-	-	-	43	20	23	23	CL-Sandy Clay	22.2	-	7.1x10 ⁻⁸
		4-6	-	-	-	54	21	33	33	CH-Silty Clay	25.2	-	-
S-7	0-2	-	-	-	97	46	20	26	30.4	CL-Silty Clay	30.4	-	2.0x10 ⁻⁸
	2-4	-	-	-	90	51	20	31	30.4	CH-Silty Clay	30.4	-	1.1x10 ⁻⁵
	4-6	-	-	-	-	-	-	-	-	CL-Sandy Clay	27.7	-	-
S-8	0-2	99	98	97	65	49	20	29	15.3	CL-Silty Clay	15.3	-	4.3x10 ⁻⁸
	2-4	-	-	-	98	92	53	33	31.4	CH-Silty Clay	31.4	-	7.5x10 ⁻⁹
	4-6	-	-	-	-	33	18	15	-	CL-Sandy Clay	18.3	-	-
S-9	0-2	-	-	-	90	51	20	31	6.1x10 ⁻⁸	CH-Silty Clay	28.8	-	6.1x10 ⁻⁸
	2-4	-	-	-	80	38	19	19	3.2x10 ⁻⁸	CL-Sandy Clay	21.6	-	-
	4-6	-	-	-	-	29	18	11	-	CL-Sandy Clay	19.1	-	-
S-10	0-2	-	-	-	80	34	18	16	6.5x10 ⁻⁸	CL-Silty Clay	18.2	112	1.2x10 ⁻⁸
	2-4	-	-	-	74	38	19	19	18.9	CL-Silty Clay	18.9	115	-
	4-6	-	-	-	-	30	18	12	-	CL-Silty Clay	19.1	112	-
S-11	0-2	-	-	-	81	41	20	21	1.5x10 ⁻⁷	CL-Silty Clay	28.8	96	-
	2-4	-	-	-	94	43	20	23	1.8x10 ⁻⁸	CL-Silty Clay	31.4	91	-
	4-6	-	-	-	-	-	-	-	-	CL-Silty Clay	28.8	95	-

Notes: 1. Laboratory Testing Performed by Southwestern Laboratories, Shreveport, LA.

2. Laboratory Particle Size Analysis Tests - ASTM D422 or D1140.

3. Laboratory Atterberg Limit Tests - ASTM D423 and D424.

4. Laboratory Moisture Content of Soils - ASTM D2216.

**SUMMARY OF LABORATORY TEST RESULTS FOR
COHESIVE LINING VERIFICATION PROGRAM (1)**

Page 4

Facility	Boring No.	Sample No.	Particle Size Analysis			Atterberg Limits (3)			Unified Soil Classification Symbol	Field Water Content (%) (4)	Field Dry Density lbs/ft ³	Laboratory Permeability cm/sec
			(%) Passing) (2)			Liquid Limit	Plastic Limit (%)	Plasticity Index				
			No. 4 Sieve	No. 10 Sieve	No. 40 Sieve	No. 200 Sieve						
S-18	0-2	91	90	89	48	33	18	15	SC-Clayey Sand	13.4	-	1.3x10 ⁻⁶
	2-4	-	-	99	97	78	35	18	CL-Silty Clay	20.4	-	7.2x10 ⁻⁸
	4-6	-	-	-	-	-	-	-	CL-Sandy Clay	17.9	-	-
S-19	0-2	-	-	-	-	-	37	17	CL-Sandy Clay	20.5	-	8.7x10 ⁻⁸
	2-4	-	-	-	-	-	24	17	SC-Clayey Sand	11.6	-	2.4x10 ⁻⁷
	4-5-6	-	-	-	-	-	33	18	CL-Sandy Clay	13.3	-	-
S-20	0-2	-	-	-	-	-	33	18	CL-Sandy Clay	16.3	-	3.7x10 ⁻⁸
	2-4	-	-	-	-	-	25	18	ML-CL Clayey Silt	14.9	-	3.8x10 ⁻⁷
	4-6	-	-	-	-	-	33	18	CL-Sandy Clay	17.7	-	-
S-21	Not Drilled Yet											
S-22	Not Drilled Yet											
Lignite Run-off Pond												

- Notes:
1. Laboratory Testing Performed by Southwestern Laboratories, Shreveport, LA.
 2. Laboratory Particle Size Analysis Tests - ASTM D422 or D1140.
 3. Laboratory Atterberg Limit Tests - ASTM D423 and D424.
 4. Laboratory Moisture Content of Soils - ASTM D2216.

SUMMARY OF ANALYSTS OF LABORATORY TEST
RESULTS FOR COHESIVE LINING VERIFICATION PROGRAM

Facility	Lining Soil Type	Lining Thickness Ft	Average Permeability k , cm/sec	Average Fines Content FC, %	Average Liquid Limit LL, %	Average Plasticity Index PI
Surge Pond	CL&CH	≥ 4	3.8×10^{-8}	88	43	24
Secondary Pond	SC&CL	≥ 4	3.8×10^{-6}	52	30	12
Bottom Ash Basin #1	CL&CH	≥ 4	2.4×10^{-6}	92	40	21
Bottom Ash Basin #2	CL&CH	≥ 4	4.8×10^{-8}	82	43	24
Metal Cleaning Waste Pond	CL&CH	≥ 4	3.8×10^{-8}	80	46	26
Lignite Runoff Pond	Boring	Not	Drilled	Yet		
Lignite Storage Pile	SC, CL ML&CL	≥ 4	3.5×10^{-7}	63	31	14
Suggested Guideline (TDWR)	CL, CH & SC	≥ 3	$\leq 1 \times 10^{-7}$	≥ 30	≥ 15	

TABLE 2

Southwestern Electric Power Company

FOR COMPANY BUSINESS ONLY
Waste Water Ponds Lining Verification
and Monitoring Wells

SUBJECT _____

DATE February 6, 1984

LOCATION Henry W. Pirkey Power Plant, Unit #1


Mr. Jay Pruett

Attached please find one copy of the "Waste Water Ponds Lining Verification and Monitoring Wells" report of work performed to date. In order to complete this project, the following must be accomplished:

- A. perform borings S-21 and S-22 in lignite pile run-off basin
- B. perform boring S-15 in metal waste cleaning pond
- C. re-drill borings S-1, S-2 and S-3 in secondary pond.

This work will be performed during the summer of 1984.

Please advise if you have any comments regarding this report.



W. H. Holley

WHH/bs

Attachment

cc: C. J. Nelson (S&L) w/attachment



SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

September 7, 1984

Southwestern Electric Power Company
P.O. Box 21106
Shreveport, Louisiana 71156

Attention: Mr. Winston Holley

Reference: Subsurface Exploration
Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

Attached is our Subsurface Exploration Report for the above referenced project.

It has been a pleasure to perform this work for you. If, during the course of this project, we can be of any further assistance, please do not hesitate to call on us.

Very truly yours,

SOUTHWESTERN LABORATORIES

Gene Gardner, P.E.

GG:awd
Attachment
3 cc: Southwestern Electric Power Company

RECEIVED

SEP 13 1984

OFFICE OF
W. H. HOLLEY

SWL

SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

August 20, 1984

File No. 832964

Southwestern Electric Power Company
P. O. Box 21106
Shreveport, LA 71156

Attention: Mr. Winston Holley

Reference: Subsurface Exploration
Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

Enclosed is our Subsurface Exploration Report on Borings S-1, S-2 and S-3. These are redrilled for verification of the lining for the pond. The locations of the borings are shown on your drawing number HP-56A.

It has been a pleasure to perform this work for you. If, during the course of this project, we can be of any further assistance, please do not hesitate to call on us.

Very truly yours,

SOUTHWESTERN LABORATORIES

Gene Gardner

Gene Gardner, P.E.

GG:kw
Enclosure
3 cc: Southwestern Electric Power Company

RECEIVED

AUG 29 1984

OFFICE OF
W. H. HOLLEY

Bill Porter
SWL

SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

December 27, 1983

File No. 832964

Southwestern Electric Power Company
P. O. Box 21106
Shreveport, LA 71156

Attention: Mr. Winston Holley

Reference: Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

The above referenced report was dated October 5, 1983.
In accordance with Bill Porter's request dated December 22,
I have revised the boring schedule for this report.

These revisions are based on the revised survey by
Hart Engineering which was reported to you on October 11,
1983, by Mr. Nealy of Hart Engineering.

Data on the following borings was revised: S-10,
S-11, MW-2, MW-4 and MW-10.

Very truly yours,

SOUTHWESTERN LABORATORIES

Gene Gardner

Gene Gardner, P.E.

GG:kw

Enclosure

RECEIVED

DEC 29 1983

Winston Holley

SWL

SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

December 19, 1983

File No. 832964

Southwestern Electric Power Company
P.O. Box 21106
Shreveport, Louisiana 71156

Attention: Mr. Winston Holley

Reference: Subsurface Exploration
Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

Enclosed is our Summary of Laboratory Test Data and Log of Boring for Boring MW-3 of the above referenced project.

To summarize, all borings for this project have been completed, with the exception of S-15, S-21, and S-22, and the re-drills of S-1, S-2, and S-3. These borings are on indefinite hold at your request.

The ten (10) monitor wells have been installed. However, the steel protective caps have not been installed.

It has been a pleasure to perform this work for you. If we can be of any further assistance, please do not hesitate to call on us.

Very truly yours,

SOUTHWESTERN LABORATORIES

Gene Gardner

Gene Gardner, P.E.

RECEIVED

DEC 20 1983

GG:jwe

Enclosure

3 cc: Southwestern Electric Power Company

OFFICE OF
W. H. HOLLEY

SWL

SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

October 21, 1983

File No. 832964

Southwestern Electric Power Company
P.O. Box 21106
Shreveport, Louisiana 71156

Attention: Mr. Winston Holley

Reference: Subsurface Exploration
Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

Enclosed is our Subsurface Exploration Report for the above referenced project. Monitor well MW-3 has not yet been installed. It will be installed soon. At that time, we will also re-drill Borings S-1, S-2 and S-3. Borings S-15, S-21 and S-22 have not been drilled and are on hold at your request.

It has been a pleasure to perform this work for you. If we can be of any further assistance, please do not hesitate to call on us.

Very truly yours,

SOUTHWESTERN LABORATORIES

Roy D. Jones, P.E.
Geotechnical Manager

Gene Gardner
Gene Gardner, P.E.

RDJ;GG:jwe
Enclosure
3 cc: Southwestern Electric Power Company

RECEIVED

OCT 26 1983

OFFICE OF
W. H. HOLLEY

SWL

SOUTHWESTERN LABORATORIES



Materials, environmental and geotechnical engineering, nondestructive, metallurgical and analytical services
P.O. Box 37577 • 7222 Greenwood Rd. • Shreveport, LA 71103 • 318/636-3673

October 5, 1983

File No. 832964

Southwestern Electric Power Company
P.O. Box 21106
Shreveport, Louisiana 71156

Attention: Mr. Winston Holley

Reference: Waste Water Ponds
Pirkey Power Plant
Hallsville, Texas

Gentlemen:

Enclosed is our Subsurface Exploration Report for the above referenced project. Borings S-10, S-11, S-15, S-21 and S-22 have not yet been drilled at this time. Results from those borings will be sent to you at a later date. Boring Logs and Summaries of Laboratory Test Data for the monitor well installations (MW-1 through MW-10) will also be sent to you at a later date.

It has been a pleasure to perform this work for you. If, during the course of this project, we can be of any further assistance, please do not hesitate to call on us.

Very truly yours,

SOUTHWESTERN LABORATORIES

Roy D. Jones, P.E.
Geotechnical Manager

Gene Gardner

Gene Gardner, P.E.

RECEIVED

RDJ;GG:jwe

Enclosure

3 cc: Southwestern Electric Power Company

OCT 10 1983

OFFICE OF
W. H. HOLLEY

BORING SCHEDULE

Boring No.	Location*		Depth	Surface Elevation
S-1	N9+69.8	W18+99.5	10	343.6
S-2	N10+20	W17+30.8	10	343.9
S-3	N9+12.6	W16+13.6	10	343.8
S-4	N14+99.3	W17+01	6	347.3
S-5	N15+ 00.8	W11+30.6	6	347.1
S-6	N19+99.9	W16+99.9	6	353.6
S-7	N20+00.2	W11+29.9	6	346.9
S-8	N14+88.3	W32+91	6	347.1
S-9	N20+11.4	W32+74.9	6	348.1
S-10	N15+00	W26+00	6	347.4
S-11	N20+00	W26+00	6	347.0
S-12	N0+00.2	W16+99.9	6	348.3
S-13	N3+00.3	W17+91.5	6	348.9
S-14	S1+38.2	W13+70.5	6	352.9
S-15	N2+00	W8+80	6	
S-16	N1+36	W11+52.9	6	357.0
S-17	N2+12.6	W12+86.2	6	348.1
S-18	S15+27	W8+89.3	6	357.2
S-19	S19+01.1	W6+05.3	6	356.7
S-20	S18+01.7	W13+55.4	6	357.6
S-21	S23+20	W16+20	6	
S-22	S23+20	W13+50	6	
MW-1	N18+55.2	W38+59.8	33	334.0
MW-2	N9+88.5	W25+85.4	41	341.0
MW-3	N19+99.7	W22+75	57	370.0
MW-4	N13+76.4	W8+34.4	46	363.4
MW-5	N2+61.5	W7+82.2	44.5	362.5
MW-6	S1+84.6	W10+60.5	43	361.0
MW-7	S2+23.9	W17+24.45	40.5	358.3
MW-8	S21+04.6	W16+11.9	34.5	356.3
MW-9	S15+48	W1+88.5	31	353.1
MW-10	N6+56.9	W18+31.3	39.5	358.6

* Locations are based on the power plant grid coordinate system.

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

COMPRESSION TEST									
BOREING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT	DRY DENSITY PCF	ATTENBERG LIMITS			TYPE FAILURE	REMARKS
					LATERAL PRESSURE psi	STRAIN %	COMPRESSSION DSF		
S-1	0 - 2	Silty sandy clay w/iron ore	18.9	32	18	14		*	**
	2 - 4	Silty sandy clay w/iron ore	18.3	28	18	10		*	**
	4½ - 6	Very silty sandy clay	20.3	28	18	10		28 B/F	
	6½ - 8	Clayey silty sand	22.2	28	18	10		26% Finer 50 B/10"	
	8½ - 10	Silty sandy clay w/gravel	27.1					50 B/3½"	
S-2	0 - 2	Silty sandy clay	19.0	29	17	12		*	**
	2 - 4	Silty sandy clay w/iron ore	23.0	35	18	17		*	**
	4½ - 6	Silty sandy clay	23.1	42	21	21		23 B/F	
	6½ - 8	Sandy silt clay	24.1	33	18	15		50 B/11"	
	8½ - 10	Silty sandy clay w/gravel	23.4	35	18	17		24 B/F	

* Hydrometer analysis results attached.

** Permeability results attached.

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

BOREING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	COMPRESSION TEST			TYPE FAILURE	REMARKS
					P ₁	P ₂	P ₃		
S-3 0 - 2	Clayey silty sand w/iron ore	20.4	28	18	10			32% Finer **	
2 - 4	Sandy silty clay w/iron ore	23.7	31	19	12				
4 - 6	Silty sandy clay w/iron ore	23.9	31	18	13			37% Finer **	
6½ - 8	Silty sandy clay w/iron ore	26.9						50 B/F	
8½ - 10	Silty sandy clay	30.0						50 B/11"	
S-4 0 - 2	Silty sandy clay	21.2	36	19	17			*	**
2 - 4	Silty sandy clay	19.4	34	18	16			*	**
4 - 6	Silty sandy clay w/iron ore	19.3							
S-5 0 - 2	Silty sandy clay w/iron ore	20.9	38	19	19			81% Finer **	
2 - 4	Silty sandy clay w/iron ore	21.5	36	18	18			75% Finer **	
4½ - 6	Silty sandy clay	4.3						28 B/F	

* Hydrometer analysis results attached.
** Permeability results attached.

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

BOREING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	ATTERBERG LIMITS			COMPRESSION TEST		TYPE FAILURE	LATERAL PRESSURE PSI	STRAIN	REMARKS
					LL	PI	PI	Type	Test				
S-6	0 - 2	Sandy silty clay lenses w/iron ore	22.4		32	17	15			**			
	2 - 4	Silty sandy clay w/iron ore	22.2		43	20	23			55% Finer			
	4 - 6	clay	25.2		54	21	33			**			
S-7	0 - 2	Silty clay	30.4		46	20	26			97% Finer			
	2 - 4	Clay w/silt lenses and iron ore	30.4		51	20	31			**			
	4 - 6	Silty sandy clay	27.7										
S-8	0 - 2	Slightly silty sandy clay	15.3		49	20	29			*			
	2 - 4	Clay w/silt lenses	31.4		53	20	33			*			
	4 - 6	Silty sandy clay	18.3		33	18	15			**			
S-9	0 - 2	Clay w/silty sand	28.8		51	20	31			90% Finer			
	2 - 4	Silty sandy clay	21.6		38	19	19			**			
	4 - 6	Silty sandy clay	19.1		29	18	11			80% Finer			

* Hydrometer analysis results attached.
** Permeability results attached.

SOUTHWESTERN LABORATORIES

SUMMARY OF LABORATORY TEST DATA									
PROJECT		TEST							
DATE	Waste Water Ponds Pirkey Power Plant								
BORING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	ATTERBERG LIMITS LL PL PI	COHESION DYN/CM²	STRAIN % ^a	LATERAL PRESSURE PSI	TYPE FAILURE
									REMARKS
S-12	0 - 2	Sandy silty clay	23.7		39 19 20				*
	2 - 4	Clay w/silt lenses	26.3		52 22 30				**
	4 - 6	Clay	23.2		61 23 38				*
									**
S-13	0 - 2	Silty sandy clay	21.3		38 20 18				76% Finer
	2 - 4	Silty sandy clay	19.1		32 17 15				69% Finer
	4 - 6	Silty sandy clay	17.7						*
									**
S-14	0 - 2	Clay w/silt lenses	31.4		51 20 31				99% Finer
	2 - 4	Slightly silty clay	29.8		48 20 28				**
	4 - 6	Sandy silty clay	29.2						98% Finer
									*
S-16	0 - 2	Silty sandy clay w/iron ore	23.6		44 21 23				59% Finer
	2 - 4	Silty sandy clay	23.1		45 20 25				80% Finer
	4 - 6	Clayey silty sand	23.5		29 19 10				*

* Hydrometer analysis results attached.
** Permeability results attached.

832964

SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

BOREING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY P.S.I.	ATTERBERG LIMITS LL PI PL	COMPRESSION TEST		TYPE FAILURE	LATENT PRESSURE P.S.I.	REMARKS
						COMPRESSION TEST S.T. P.S.I.	STRAIN %			
S-17 0 - 2		Slightly silty clay w/iron ore	27.8	48	20 28					89% Finer **
2 - 4		Slightly silty clay w/iron ore	27.2	49	20 29					93% Finer **
4 - 6		Clayey silty sand	18.1	23	17 6					
S-18 0 - 2		Silty sandy clay w/iron ore	13.4	33	18 15					*
2 - 4		Sandy silty clay	20.4	35	18 17					**
4 - 6		Silty sandy clay w/gravel	17.9							
S-19 0 - 2		Silty sandy clay	20.5	37	17 20					75% Finer **
2 - 4		Clayey silty sand	11.6	24	17 7					26% Finer **
4½ - 6		Silty sandy clay	13.3	33	18 15					37 B/F
S-20 0 - 2		Silty sandy clay w/gravel	16.3	33	18 15					53% Finer **
2 - 4		Clayey sandy silt w/gravel	14.9	25	18 7					61% Finer **
4 - 6		Silty sandy clay w/iron ore	17.7	33	18 15					

* Hydrometer analysis results attached.

** Permeability results attached.

SOUTHWESTERN LABORATORIES

SUMMARY OF LABORATORY TEST DATA

Waste Water Ponds

8/20/84

PROJECT DATE	COMPRESSION TEST									
	BOREHOLE NO.	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY G/CU FT	ATTENING LIMITS			LATERAL PRESSURE psi	TYPE FAILURE
						PSI	PSI	PSI		
S1	0-2	Medium slightly silty clay	32.2	85	48	20	28	1762	5.0	Vert. Shear
	2-4	Stiff silty sandy clay	17.7	105	30	18	12	2096	6.0	Vert. Shear
	6-8	Clayey silty sand w/iron ore	22.8	24	18	6				
S2	0-2	Medium slightly silty clay	35.3	82				1030	5.0	Vert. Shear
	2-4	Silty sandy clay w/iron ore	21.7	32	18	14				
	4-6	Stiff silty sandy clay w/iron ore	21.6	110	33	18	15	2825	5.0	Vert. Shear
S3	0-2	Silty sandy clay w/iron ore	23.8							
	2-4	Medium slightly silty clay	34.6	82	49	20	29	1230	6.0	Vert. Shear
	4-6	Medium silty sandy clay w/iron ore	29.4	92						

SUMMARY OF LABORATORY TEST DATA

832964 PROJ C1 Waste Water Ponds Pirkey Power Plant

DATE 09-29-83

SUMMARY OF LABORATORY TEST DATA									
PROJECT			TEST DATA						
Waste Water Ponds Pirkey Power Plant									
DATE 09-29-83									
BORING NO.	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT	DRY DENSITY	ATTENUATION LIMITS	LL	PL	PI	
S-4	0-2	Silty sandy clay							6.8×10^{-9}
	2-4	Silty sandy clay							1.8×10^{-8}
S-5	0-2	Silty sandy clay w/iron ore							4.9×10^{-7}
	2-4	Silty sandy clay w/iron ore							8.1×10^{-8}

832964

SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

BORING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	COMPRESSION TEST			TEST FAILURE	k' , Coefficient of Permeability cm/sec
				STRAIN	TYPE OF PRESSURE	LATERAL PRESSURE		
S-6	0 - 2	Sandy silty clay lenses w/iron ore						7.4×10^{-6}
	2 - 4	Silty sandy clay w/iron ore						7.1×10^{-8}
S-7	0 - 2	Silty clay						2.0×10^{-8}
	2 - 4	Clay w/silt lenses and iron ore						1.1×10^{-5}
S-8	0 - 2	Slightly silty sandy clay						4.3×10^{-8}
	2 - 4	Clay w/silt lenses						7.5×10^{-9}
S-9	0 - 2	Clay w/silty sand						6.1×10^{-8}
	2 - 4	Silty sandy clay						3.2×10^{-8}
S-12	0 - 2	Sandy silty clay						1.4×10^{-8}
	2 - 4	Clay w/silt lenses						1.1×10^{-8}

832964

SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

BOARING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT	DRY DENSITY Pcf	TEST			k, Coefficient of permeability cm/sec
					TYPE	TRAILING	LATERAL PRESSURE psi	
S-13	0 - 2	Silty sandy clay						3.6×10^{-8}
	2 - 4	Silty sandy clay						6.6×10^{-8}
S-14	0 - 2	Clay w/silt lenses						9.2×10^{-8}
	2 - 4	Slightly silty clay						1.3×10^{-8}
S-16	0 - 2	Silty sandy clay w/iron ore						2.7×10^{-8}
	2 - 4	Silty sandy clay						1.3×10^{-8}
S-17	0 - 2	Slightly silty clay w/iron ore						6.1×10^{-8}
	2 - 4	Slightly silty clay w/iron ore						4.3×10^{-8}
S-18	0 - 2	Silty sandy clay w/iron ore						1.3×10^{-6}
	2 - 4	Sandy silty clay						7.2×10^{-8}

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 9-29-83

COMPRESSION TEST				K, Coefficient of Permeability cm/sec
BORING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	STRAIN
				LATERAL PRESSURE psi
				TYPE FAILURE
S-19	0 - 2	Silty sandy clay		8.7 x 10 ⁻⁸
	2 - 4	Clayey silty sand		2.4 x 10 ⁻⁷
S-20	0 - 2	Silty sandy clay w/gravel		3.7 x 10 ⁻⁸
	2 - 4	Clayey sandy silt w/gravel		3.8 x 10 ⁻⁷

SUMMARY OF LABORATORY TEST DATA

PROJECT 832964

DATE 9-4-84

BOREH ING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT PER CENT	DRY DENSITY PCF	ATTERBERG LIMITS			TEST	COMPRESSION TEST	
					L.L.	P.L.	P.I.			
S-21	0-2	Stiff silty clay with iron ore	26.6	95				2160	6.0	Vert. Shear
	2-4	Stiff silty clay with iron ore	22.9	100	39	19	20	3222	4.0	Vert. Shear
	4-6	Very stiff silty clay w/iron ore	21.3	81	38	19	19	4910	3.0	Vert. Shear
S-22	0-2	Stiff clay with iron ore	26.7	93	51	21	30	3947	5.0	Vert. Shear
	2-4	Stiff silty clay w/ iron ore	22.3	102	39	19	20	3153	6.0	Vert. Shear
	4-5	Firm clayey sand w/ iron ore	18.8	106	22	18	4	1785	3.0	Vert. Shear
S-23	0-2	Stiff slightly sandy clay w/ore	28.6	92				2285	5.0	Vert. Shear
	2-4	Stiff slightly sandy clay w/ore	27.5	88	48	20	28	3222	4.0	Vert. Shear
	4-6	Stiff sandy clay with iron ore	19.5	104	35	19	16	2212	4.0	Vert. Shear
S-24	0-2	Stiff silty sandy clay w/iron ore	27.5	100				2841	5.0	Vert. Shear
	2-4	Stiff sandy clay with iron ore	20.4	105	37	19	18	3765	3.0	Vert. Shear
	4-6	Firm very sandy clay w/iron ore	14.4	28	17	11				1.6 x 10 ⁻⁸

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds, Pirkey Power Plant

DATE 10-11-83

SAMPLING NO	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	ATTERBERG LIMITS LL PI PL PI	COMPRESSION TEST		REMARKS
						LATERAL PRESSURE psi	STRAIN %	
MW-1	3½-5	Very dense clayey silty sand w/clay seam	13.5					50 B/7"
	8½-10	Very stiff very sandy clay w/iron ore	17.6					30 B/F
	13-15	Stiff silty sandy clay	21.2	113		2842	4.8	Vert. Shear
	18-20	Loose clayey silty sand	22.5	102		694	2.0	Vert. Shear
	23½-25	Hard silty sandy clay lenses	14.9					50 B/11½"
	28½-30	Very dense clayey sandy silt	19.7					
MW-2	3 - 5	Firm clayey silty sand	12.2					
	8 - 10	Medium very sandy silty clay	18.0	116		1726	3.0	Vert. Shear
	13-15	Dense clayey silty sand	23.3					
	18½-20	Dense clayey silty sand	22.2					31 B/F
	23-25	Dense silty sand	19.2					
	28½-30	Very dense clayey silty sand	24.7					50 B/F
	33½-35	Very dense clayey silty sand	23.5					50 B/9"
	38½-40	Hard sandy silty clay	17.7					50 B/F

832964 SUMMARY OF LABORATORY TEST DATA

PROJECT Waste Water Ponds Pirkey Power Plant

DATE 11-15-83

SAMPLING NO.	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	COMPRESSION STRAIN %	TEST		
						LATERAL PRESSURE psi	Type of Failure	REMARKS
MW-3	3 - 5	Stiff sandy silty clay	21.0	107		2394	2.7	Vert. Shear
	8 - 10	Stiff silty clay lenses w/iron ore	29.4	95		2981	3.0	Vert. Shear
	13-15	Stiff sandy silty clay	25.7	103		1972	3.3	Vert. Shear
	18-20	Firm sand w/clay lenses	30.2	95		800	2.3	45 Vert. Shear
	23-25	Stiff clay	31.2	91		3485	3.0	Slickinsided
	28-30	Stiff clay w/silt lenses	28.3	95		3686	4.5	
	33-35	Firm clayey silty sand	20.5	103		1447	4.0	Vert. Shear
	43½-45	Hard clay w/silty sand lenses	31.0					50 B/6"
	48½-50	Hard silty sandy clay	20.3					50 B/F
	53½-55	Hard silty sandy clay	20.4					50 B/10"


832964 SUMMARY OF LABORATORY TEST DATA


PROJECT Waste Water Ponds, Pirkey Power Plant

DATE 10-11-83


TESTING NO.	DEPTH IN FEET	TYPE OF MATERIAL	MOISTURE CONTENT %	DRY DENSITY PCF	ATTERBERG LIMITS LL PI PL	COMPRESSION TEST		TYPE FAILURE	REMARKS
						LATERAL PRESSURE PI	STRAIN %		
MW-8	3 - 5	Stiff silty sandy clay w/iron ore	18.1	112		3183	2.7	Vert. Shear	
	8 - 10	Stiff silty sandy clay w/iron ore	13.3	118		3240	4.0	Vert. Shear	
	13-15	Firm clayey silty sand	20.6	103		1929	2.0	Vert. Shear	
	18-20	Medium very silty sandy clay w/iron ore	16.7	121		1385	3.0	Vert. Shear	
	23-25	Very stiff silty clay lenses	23.0	106		5468	5.0	Vert. Shear	
	33½-35	Very dense silty sand	18.5					50 B/5½"	
MW-9	3 - 5	Stiff silty sandy clay w/iron ore	13.6						
	8½-10	Very stiff silty sandy clay	15.2						
	13½-15	Medium very silty clay	20.2						
	18-20	Stiff silty clay lenses	23.3	107		2153	5.0	Vert. Shear	
	23-25	Stiff very silty clay lenses	21.6						
	28½-30	Very dense silty sand	22.9					50 B/11"	

ATTACHMENT C
DESIGN DRAWINGS






COMPILED BY PHOTOGRAVIMETRIC METHOD BY
TIGER RESEARCH, INC., SAN ANTONIO, TEXAS
DATE OF PHOTOGRAPHY 2-12-79
DATE OF COMPILEATION 7-17-79
VERTICAL ACCURACY OF CONTROLLED
90% = ± 3.5' 10' = ± 10'
HORIZONTAL ACCURACY AT WELL DEFINED POINTS
90% = ± 1.5' 10' = ± 3'
GRID BASED ON TEXAS STATE PLANE COORDINATE
SYSTEM NORTH CENTRAL ZONE
ELEVATIONS ARE BASED ON 1929 MEAN SEA LEVEL
DATUM



PURPOSE	FILE#	DATE FILED	PREPARED	REVIEWED	DRAWING RELEASE RECORD		PURPOSE
					APPROVED	REF ID#	
POND 24 REVISION DRAWINGS	A	09-05-78	11-10-78	11-10-78	W. G. SAWYER	FOR BIDS, SPEC. H-1520	
SAND LICKS - PHASE II - FOR BIDS	B	09-12-79	11-10-78	11-10-78	W. G. SAWYER	FOR CONSTRUCTION, SPEC. H-1520	
GRASSING - PHASE I, PHASE II, AREA	C	04-16-79	11-10-78	11-10-78	W. G. SAWYER	INCREASED PLANTATION BY 2-1/2", SPEC. H-1520	
ALL SURVEYS	D	05-01-79	11-10-78	11-10-78	W. G. SAWYER	TECH. BIDS, SPEC. H-1520	
	E	08-01-79	11-10-78	11-10-78	W. G. SAWYER	FOR CONSTRUCTION, SPEC. H-1520	
	F	9-1-80	11-10-78	11-10-78	W. G. SAWYER	REF. FOR COUNT OF TREES APPROACHED	
	G	10-10-80	11-10-78	11-10-78	W. G. SAWYER	REF. FOR COUNT OF TREES APPROACHED	
	H	10-10-80	11-10-78	11-10-78	W. G. SAWYER	REF. FOR COUNT OF TREES APPROACHED	

SCALE 1:500'-0"	SITE DEVELOPMENT GRADING & DRAINAGE PLAN - SHEET 3	
PROJECT NUMBER 5555-03	HENRY W. FIRKEY POWER PLANT UNIT 1 SOUTHWESTERN ELECTRIC POWER CO. SOUTH HALLETTVILLE, TEXAS	
	DRAWING NO. C-12	REV. M
	SHEET OF	

COMPILED BY PHOTGRAMMETRIC METHODS BY
TOBIN RESEARCH, INC. SAN ANTONIO, TEXAS
DATE OF PHOTOGRAPHY 2-12-75
DATE OF COMPILATION 5-1-75
VERTICAL ACCURACY OF POINTS
50% = 2.5' & 10% = 5.0'
DASHED CONTOURS ARE OUTSIDE THE VERTICAL
ACCURACY, BECAUSE OF TREES
HORIZONTAL ACCURACY OF WELL DEFINED POINTS:
50% = 6' & 10% = 12'
Elevations based on Texas State Plane Coordinate
System North Central Zone
ELEVATIONS BASED ON 1929 MEAN SEA LEVEL DATUM



DRAWING RELEASE RECORD					
REV.	DATE REL'D.	PREPARED	REVIEWED	APPROVED	PURPOSE
H	2-16-81	G. R. GORE	R. J. HOLLOWAY	W.H. PIRKEY	FOR CONSTRUCTION, DITCHES, DRAINS
J	3-12-83	R.A. GORE	R.J. HOLLOWAY	W.H. PIRKEY	FOR SP-1 GORE EARTHWORK, PHASE II (For Basins)
K	4-26-83	R.A. GORE	R.J. HOLLOWAY	W.H. PIRKEY	REVISED ASH SLUICE RECIRC. PUMPS FDN.
L	7-7-83	R.A. GORE	R.J. HOLLOWAY	W.H. PIRKEY	REVISED ASH SLUICE RECIRC. PUMPS FDN.

DRAWING RELEASE RECORD					
REV.	DATE REL'D.	PREPARED	REVIEWED	APPROVED	PURPOSE
B	08-01-79	R. J. Holloway	R. J. Holloway	R. J. Holloway	FOR CONSTRUCTION, SPEC. H-4533
C	12-16-79	R. J. Holloway	R. J. Holloway	R. J. Holloway	ADDED COORDINATES, SPEC. H-4530 & H-4533
D	12-16-80	R. J. Holloway	R. J. Holloway	R. J. Holloway	FOR CLIENTS COMMENTS
E	1-16-80	R. J. Holloway	R. J. Holloway	R. J. Holloway	REVISED ASH POND & ADDED DITCH, SPEC. H-4533
F	1-12-81	R. J. Holloway	R. J. Holloway	R. J. Holloway	W.H. PIRKEY (For Construction)
G	1-26-81	R. J. Holloway	R. J. Holloway	R. J. Holloway	W.H. PIRKEY (For Construction)

SCALE	T-50'-0"
FILE NUMBER	5555-03

BOTTOM ASH BASIN
PLAN - SHEET 1
HENRY W. PIRKEY
POWER PLANT UNIT 1
SOUTHWESTERN ELECTRIC POWER CO.
SOUTH HALLSVILLE, TEXAS


DRAWING NO. C-19

SHEET OF

COMPILED ST-PHOTOPRIMETRIC METHODS BY
 TIBURIO REYES, SAN ANTONIO, TEXAS
 DATE OF PHOTOGRAPHY 2-12-75
 DATE OF COMPLETION 5-1-76
 VERTICAL ACCURACY OF CONTOURS -
 90% = ± 2.5 ft 10% = ± 50 '
 DASHED CONTOURS ARE OUTSIDE THE VERTICAL
 ACCURACY BECAUSE OF TREES
 HORIZONTAL ACCURACY OF WELL DEFINED POINTS -
 90% = $\pm 10\%$ * $\pm \frac{25}{100}$
 GRID BASED ON TEXAS STATE - PLANE COORDINATE
 SYSTEM NORTH CENTRAL ZONE
 ELEVATIONS BASED ON 1929 MEAN SEA LEVEL DATUM

C-21

W 40+00



DRAWING RELEASE RECORD						
REV.	DATE	REF'D	PREPARED	REVIEWED	APPROVED	PURPOSE
H	3-30-95		R. A. SIEGMUND <i>[Signature]</i>	<i>[Signature]</i>	M. H. BELLAMY <i>[Signature]</i>	FOR SPAC 5000 Fairway Park II Five River P. Counter 6090
J	3-30-95					
K	3-30-95					
L	3-30-95					
M	3-30-95					
N	3-30-95					
O	3-30-95					
P	3-30-95					
Q	3-30-95					
R	3-30-95					
S	3-30-95					
T	3-30-95					
U	3-30-95					
V	3-30-95					
W	3-30-95					
X	3-30-95					
Y	3-30-95					
Z	3-30-95					


DRAWING RELEASE RECORD		
REVIEWED	APPROVED	PURPOSE
Taylor	FOR BIDS, SPEC. H-4555	
W. H. Johnson	FOR CONSTRUCTION, SPEC. H-4535	
W. H. Johnson	FOR CONTRACTOR'S SPEC., H-4512	
W. H. Johnson	FOR CLIENT'S COMMENT	
L. J. H. (Vice)	REVISED ASH POND, SPEC. H-4555	
Release Date: May 10, 1970 Gen. Rev. For Const.		
Record Date: [unclear] at [unclear]		

BOTTOM-AGU-BASIN

PROJECT
NUMBER
1-03

HENRY W. PIRKEY
POWER PLANT UNIT 1
SOUTHWESTERN ELECTRIC POWER CO.
SOUTH HALLSMILE, TEXAS

DRAWING NO.	REV.
C-21	J
SHEET OF	



DRAWING RELEASE RECORD						DRAWING RELEASE RECORD						DRAWING RELEASE RECORD					
REV.	DATE RELE.	PREPARED	REVIEWED	APPROVED	PURPOSE	REV.	DATE RELE.	PREPARED	REVIEWED	APPROVED	PURPOSE	REV.	DATE RELE.	PREPARED	REVIEWED	APPROVED	PURPOSE
H	3-30-75	DR	DR	DR	REVISED ASH SECTIONS REVISED 30' SECTION FIRE ROUTING & SLOPE TREATMENTS	A	02-01-75	DR	DR	DR	FOR E-10, REV H-4550	B	02-01-75	DR	DR	DR	FOR E-10, REV H-4550
J	12-1-85	DR	DR	DR		B	02-01-75	DR	DR	DR	FOR CONSTRUCTION, SPEC H-4550	C	12-16-79	DR	DR	DR	AS-402 DETAILS ON PUMP INLET STRUCTURE, SPEC H-4550 & H-4552
						C	12-16-79	DR	DR	DR		D	02-15-80	DR	DR	DR	REVISED ASH POND LINES & ADDED SECTIONS E-10 TO E-10, SPEC H-4553
						E	02-27-80	DR	DR	DR		F	10-20-81	DR	DR	DR	REVISED SEC 1, FOR CONSTRUCTION, SPEC H-4570
						G	02-10-83	DR	DR	DR						REVISED AS PER ASH PIPE CULVERTS, SPEC H-4550.	
																	DETAILS - REVISED 8651, 11-3-84 DR, VERS 8651 5-247, SPEC H-4550.

NOTES:

1. FOR GENERAL NOTES SP-24-4550 SEE DRAWINGS E-20.
2. COMPACTED COHESIVE LINING AT THE BOTTOM OF THE POND AND BASINS MAY BE OMITTED IF THE PURCHASER APPROVES THE USE OF A COHESIVE LINING AS DETERMINED BY PURCHASER AND/OR THE CONTRACTOR. IF THE COHESIVE LINING IS OMITTED UNLESS IT IS APPROVED IN ADVANCE.
3. COMPACTED COHESIVE SOIL USED FOR LINING SHALL HAVE A MINIMUM OF 40% PASSING NO. 200 U.S. STANDARD SIEVE AND A MINIMUM PLASTICITY INDEX (PI) OF 15%.
4. PIPING DESIGN: 30' DIAMETER (STD. 30") (STD. WT) PIPE PER 5' STD. PIPING DESIGN.
5. PIPING DESIGN: 30' DIAMETER (STD. 30") (STD. WT) PIPE PER 5' STD. PIPING DESIGN.
6. ALL BURIED PIPE SHALL BE COATED & WRAPPED.

REFERENCE DRAWINGS

- C-19 BOTTOM ASH BASIN PLAN - SHEET 1
- C-20 BOTTOM ASH BASIN PLAN - SHEET 2
- C-21 BOTTOM ASH BASIN PLAN - SHEET 3
- C-22 CONDUIT SCHEMATIC

**BOTTOM ASH BASIN
SECTIONS & DETAILS**
HENRY W. PIRKEY
POWER PLANT UNIT 1
SOUTHWESTERN ELECTRIC POWER CO.
SOUTH HALLSVILLE, TEXAS

DRAWING NO. C-22
REV. J
SHEET 1 OF 1



DRAWING RELEASE RECORD				PURPOSE
REV.	DATE RELEASD	PREPARED	REVIEWED	APPROVED
9-1-71-21	9-1-71	9-1-71	9-1-71	RELEASED FOR RIFERWORK
9-7-72	9-7-72	9-7-72	9-7-72	REVISED DISCHARGE CHANNEL
10-9-71	10-9-71	10-9-71	10-9-71	FOR BIO. SITE. 104
3-9-73	3-9-73	3-9-73	3-9-73	FOR BIO. SITE. 104 TURNAROUND & PAIC
5-12-72	5-12-72	5-12-72	5-12-72	WATER TOWER LINING VERIFICATION & MIGR.
A	10-18-72	10-18-72	10-18-72	REV'D TO SHOW ACTUAL LOCATIONS OF STORES
B	10-18-72	10-18-72	10-18-72	REV'D TO SHOW ACTUAL LOCATIONS OF STORES
C	6-10-73	6-10-73	6-10-73	REV'D TO SHOW ACTUAL LOCATIONS OF STORES

DRAWING RELEASE RECORD					
REF.	DATE RELEASED	PREPARED	REVIEWED	APPROVED	RELEASER
1-100	12-2-84	12-2-84			12-2-84 M-24
	12-2-84	M-24			12-2-84 M-24
	12-2-84	M-24			12-2-84 M-24
DATE	4-7-85	M-24			4-7-85 M-24
WELLS FOR DESTRUCTION					
WELLS					
MW-2 & MW-10					

REPORT	FILE	SCALE	WASTE WATER FOR LIVING VERIFICATION AND TESTING
WATER		TEMP.	
DATE, DAY, MONTH, YEAR		PH	
C		DO	
C		SG	
C		ECO	
C		CHLORINE	
C		CHLORIDE	

HORIZONTAL ACCURACY OF STATE SURVEY POINTS
80% - 2" ± 10% ± 10'
GRID BASED ON TEXAS STATE PLANE COORDINATE
SYSTEM NORTH CENTRAL ZONE
ELEVATIONS ARE BASED ON 1960 MEAN SEA LEVEL

SPEC. H-4530

GENERAL NOTES

REFERENCE DRAWINGS

- ANALYSIS SHEET
NAME OF PUPPY
DATE ACQUIRED
SEX
SECTION SHEET
DETECTION CAPTURE
DOCKLEAN
P-A-N-D
CHANNEL PROFILE
AGE STRAINED PLATE
HATRED AND ANGER

ATTACHMENT D
INSTRUMENTATION LOCATION MAP



Provided by Google Earth.

New Piezometer Location Map – West Bottom Ash Pond

Scale: N/A	Pirkey Power Generating Station New Piezometer Location – 2015 Hallsville, Texas
Auckland Project No. 2015-016	

ATTACHMENT E

HYDROLOGY AND HYDROLOGIC REPORT

Auckland Consulting LLC

December 17, 2015

Mr. Brett Dreger, P.E.
American Electric Power Company
1 Riverside Plaza
Columbus, Ohio 43215
Email: badreger@aep.com

**RE: West Ash and East Ash Pond – Hydrology and Hydraulic Analysis
Pirkey Power Generating Station
Hallsville, Texas**

Dear Mr. Dreger:

Auckland Consulting, LLC (Auckland) is pleased to provide the attached Hydrology and Hydraulic Report for both the West Ash and East Ash Ponds located at the Pirkey Power Generating Station near Hallsville, Texas. The analysis covers both the 25-year, 24-hour and 100-year, 24-hour storm events as required by 40 CFR §257.82(a). As indicated through various phone conversations and email correspondence, the West Ash and East Ash Ponds were identified as the only CCR impoundments requiring this demonstration.

Please do not hesitate to contact us with any questions or comments.

Best regards,



John J. Tayntor, P.E.
Auckland Consulting LLC
TBPE Firm Registration No. F-16721, Expires 2/29/2016

Attachments

HYDROLOGY & HYDRAULIC REPORT
EAST & WEST ASH PONDS
H.W. PIRKEY POWER PLANT – HALLSVILLE, TX
December 2015

Prepared for:



H.W. Pirkey Power Plant
2400 FM 3251
Hallsville, Texas 75650

Prepared by:



Akron Consulting, LLC
431 N. Center St.
Longview, Texas 75601
TBPE Firm # 14014



12/15/15 e

TABLE OF CONTENTS

HYDROLOGY & HYDRAULIC REPORT

	<u>Page No.</u>
Introduction	1
Hydrologic Methodology.....	1
Hydraulic Methodology.....	1
East Ash Pond	2
West Ash Pond	3
Summary	3

LIST OF TABLES

Table 1	Runoff Curve Numbers for Hydrologic Soil-Cover Complexes	4
Table 2	East Ash Pond Elevation-Area-Storage Table	5
Table 3	West Ash Pond Elevation-Area-Storage Table.....	6

LIST OF FIGURES

Figure 1	100-year, 24-hour Runoff Depth	7
Figure 2	25-year, 24-hour Runoff Depth	8

HYDROLOGIC & HYDRAULIC CALCULATIONS

100-Year, 24-Hour Rainfall Event
25-Year, 24-Hour Rainfall Event

APPENDIX - A

Exhibits

Introduction

H.W. Pirkey Power Plant which is located in Hallsville, Texas is a subsidiary of American Electric Power. Plant operation requires a series of water impoundments utilized in the process of power generation, including the bottom ash ponds. The purpose of this report is to analyze and document the Hydrologic & Hydraulic characteristics of the East and West Bottom Ash Ponds at Pirkey Power Plant.

Hydrologic Methodology

This section describes the general outline of the hydrologic methodologies used to evaluate the total runoff tributary to the ponds. Specific characteristics of each pond are discussed under individual subheadings later in this report.

The East & West Ash Ponds are total containment ponds. Watershed areas contributing to the flow into these ponds are the ponds and berms/access roads themselves; in other words, these ponds have no additional runoff areas tributary to them. Therefore, a conservative approach is to adopt a curve number 100 and to consider that every inch of rainfall will directly increase the water surface elevation.

According to Natural Resource Conservation Service (formerly SCS) Technical Release 55, the peak flow is calculated using the formula:

$$Q = (P - 0.2S)^2 / (P + 0.8S)$$

where,

Q = runoff (inches)

P = rainfall (inches)

S = potential maximum retention after runoff begins (inches) = (1000/curve number) – 10

Applying a curve number of 100 to the formula above will ultimately result in Q = P (because S=0); which implies that the total runoff contributing to the flow in each of the ponds is directly a function of the rainfall event.

Hydraulic Methodology

This section describes the general outline of the hydraulic methodologies used to analyze the storage capacity of the ponds. Specific characteristics of each pond are discussed under individual subheadings later in this report.

The plant's CCR rules require that the ponds be able to accommodate the rainfall volume from a

100 year 24 hour storm without over topping. The normal operating level for each pond is established by other regulations, and it is set to 3 feet below the top of the embankment. Using actual field survey data, an elevation-area-storage table was developed for the ponds and is included in the tables section of this report. Hydraflow Hydrographs was utilized to evaluate storage capacity and the water surface elevations in each pond during the 100 year 24 hour rainfall event. The 25 year 24 hour rainfall event was analyzed as well.

Detailed Hydrologic & Hydraulic characteristics of the ponds are discussed below.

EAST ASH POND:

The East Ash Pond is located to the east of the rail road track and north of the Pirkey Power Plant. This is a coal combustion waste pond used to settle bottom ash that has been sluiced from the plant boiler. Field survey of the embankment around the impoundment indicates that the top of the embankment is at a minimum elevation of 357.0msl, which is consistent with original design drawings. Therefore, based on this top of embankment elevation, the normal operating level was established at 354.0msl. The watershed area contributing to the flow into this pond was estimated to be 29.63 acres.

The storage capacity for each pond was analyzed for a 100-yr, 24-hr rainfall event, which is 10.3 inches. Multiplying the acreage times the inches, the calculated volume of the rainfall event is 1,107,836 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,142,455 cf.

The storage capacity was also analyzed for a 25-yr, 24-hr rainfall event, which is 8.2 inches. The calculated volume of the rainfall event is 881,967 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 909,528 cf.

Water surface elevation was then calculated for the 100-yr, 24-hr rainfall event with a normal operating level (354.0msl) as the baseline elevation. Results from Hydraflow Hydrograph indicates that the water surface elevation during the 100-yr, 24-hr rainfall will be 354.99msl which is less than 357.0msl (embankment top). Results from the 25-yr, 24-hr rainfall event indicate the water surface elevation will be 354.79msl which is also less than 357.0msl (embankment top).

WEST ASH POND:

The West Ash Pond is located to the west of the rail road track and adjacent to the east ash pond. This is a coal combustion waste pond used to settle bottom ash that has been sluiced from the plant boiler. Field survey of the embankment around the impoundment indicates that the top of the embankment is at a minimum elevation of 357.0msl, which is consistent with original design drawings. Therefore, based on this top of embankment elevation, the normal operating level was established at 354.0msl. The watershed area contributing to the flow into this pond was estimated to be 33.44 acres.

As mentioned earlier the storage capacity for each pond was analyzed for a 100-yr, 24-hr rainfall event, which is 10.3 inches. Multiplying the acreage times the inches, the calculated volume of the rainfall event is 1,250,228 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,289,360 cf.

The storage capacity was also analyzed for a 25-yr, 24-hr rainfall event, which is 8.2 inches. The calculated volume of the rainfall event is 995,376 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,026,480 cf.

Water surface elevation was then calculated for the 100-yr, 24-hr rainfall event with a normal operating level (354.0msl) as the baseline elevation. Results from Hydraflow Hydrograph indicates that the water surface elevation during the 100-yr, 24-hr rainfall will be 355.01msl which is less than 357.0msl (embankment top). Results from the 25-yr, 24-hr rainfall event indicate the water surface elevation will be 354.81msl which is also less than 357.0msl (embankment top).

Summary

Water surface elevations calculated from Hydraflow Hydrographs are tabulated below:

SUMMARY OF POND HYDRAULIC CHARACTERISTICS				
	TOP OF EMBANKMENT	OPERATING LEVEL	100YR-24HR WSEL	25YR-24HR WSEL
EAST ASH POND	357.0	354.0	354.99	354.79
WEST ASH POND	357.0	354.0	355.01	354.81

As evident from the table above, it is the opinion of Akron Consulting that the East & West Ash Ponds will serve to adequately contain the calculated rainfall events.

TABLE 1

Runoff Curve Numbers for Hydrologic Soil-Cover Complexes
 (Antecedent Moisture Condition II, and $I_a = 0.2 S$)
 (Adapted from NRCS Technical Release 55)

Land Use	Treatment or Practice	Hydrologic Condition	Hydrologic Soil Group			
			A	B	C	D
Fallow	Straight Row	---	77	86	91	94
Row Crops	Straight Row	Poor	72	81	88	91
	Straight Row	Good	67	78	85	89
	Contoured	Poor	70	79	84	88
	Contoured	Good	65	75	82	86
	Contoured and Terraced	Poor	66	74	80	82
	Contoured and Terraced	Good	62	71	78	81
	Contoured and Terraced	Good	62	71	78	81
Small Grain	Straight Row	Poor	65	76	84	88
	Straight Row	Good	63	75	83	87
	Contoured	Poor	63	74	82	85
	Contoured	Good	61	73	81	84
	Contoured and Terraced	Poor	61	72	79	82
	Contoured and Terraced	Good	59	70	78	81
	Contoured and Terraced	Good	59	70	78	81
Close-Seeded, Legumes, Rotation Meadow	Straight Row	Poor	66	77	85	89
	Straight Row	Good	58	72	81	85
	Contoured	Poor	64	75	83	85
	Contoured	Good	55	69	78	83
	Contoured and Terraced	Poor	63	73	80	83
	Contoured and Terraced	Good	51	67	76	80
	Contoured and Terraced	Good	51	67	76	80
Pasture Or Range		Poor	68	79	86	89
		Fair	49	69	79	84
		Good	39	61	74	80
Meadow		Good	30	58	71	78
Woods		Poor	45	66	77	83
		Fair	36	60	73	79
		Good	25	55	70	77
Farmsteads Roads/Facilities	----	----	59	74	82	86
	----	----	74	84	90	92

TABLE 2
EAST ASH POND ELEVATION-AREA-STORAGE TABLE
H.W. PIRKEY POWER PLANT
EXISTING CONDITION
NORMAL OPERATING POOL AT 354.0

ELEVATION (ft)	AREA (Acres)	STORAGE (Ac-Ft)	STORAGE (Cubic Feet)	STORAGE (Million Gallons)
352.00	25.70	na	na	na
353.00	25.99	na	na	na
354.00	26.29	0.00	0	0.00
355.00	26.59	26.44	1,151,730	232.61
356.00	26.88	53.18	2,316,300	467.82
357.00	27.19	80.21	3,493,950	705.67







TABLE 3
WEST ASH POND ELEVATION-AREA-STORAGE TABLE
H.W. PIRKEY POWER PLANT
EXISTING CONDITION
NORMAL OPERATING POOL AT 354.0

ELEVATION (ft)	AREA (Acres)	STORAGE (Ac-Ft)	STORAGE (Cubic Feet)	STORAGE (Million Gallons)
352.00	28.43	na	na	na
353.00	28.74	na	na	na
354.00	29.05	0.00	0	0.00
355.00	29.36	29.21	1,272,170	256.94
356.00	29.67	58.72	2,557,840	516.61
357.00	30.47	88.79	3,867,690	781.16





25-YEAR 24-HOUR RAINFALL (INCHES)



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9

Tuesday, 00 3, 2015

Hyd. No. 1

East Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 310.73 cfs
Storm frequency	= 100 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,142,455 cuft
Drainage area	= 29.630 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 10.30 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9


Tuesday, 00 3, 2015

Hyd. No. 2

East Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 100 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - East Ash Pond	Max. Elevation	= 354.99 ft
Reservoir name	= East Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9

Tuesday, 00 3, 2015

Hyd. No. 1

West Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 350.69 cfs
Storm frequency	= 100 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,289,360 cuft
Drainage area	= 33.440 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 10.30 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9


Tuesday, 00 3, 2015

Hyd. No. 2

West Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 100 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - West Ash Pond	Max. Elevation	= 355.01 ft
Reservoir name	= West Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9

Tuesday, 00 15, 2015

Hyd. No. 1

East Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 247.38 cfs
Storm frequency	= 25 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 909,528 cuft
Drainage area	= 29.630 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 8.20 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9


Tuesday, 00 15, 2015

Hyd. No. 2

East Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 25 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - East Ash Pond	Max. Elevation	= 354.79 ft
Reservoir name	= East Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9

Tuesday, 00 15, 2015

Hyd. No. 1

West Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 279.19 cfs
Storm frequency	= 25 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,026,480 cuft
Drainage area	= 33.440 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 8.20 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9


Tuesday, 00 15, 2015

Hyd. No. 2

West Ash Pond


Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 25 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - West Ash Pond	Max. Elevation	= 354.81 ft
Reservoir name	= West Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.






0 300' 600'
1"=300'



LEGEND

WATERSHED BOUNDARY


PLAN VIEW
SCALE: 1"=200'



LEGEND

TOP OF EMBANKMENT ELEV.= 357.00
100 YEAR 24 HOUR WSEL ELEV.= 354.99
25 YEAR 24 HOUR WSEL ELEV.= 354.79
NORMAL OPERATING LEVEL= 354.00



EAST ASH POND WATER SURFACE EXHIBIT




AKRON CONSULTING, LLC.
431 N. CENTER ST.
LONGVIEW, TX 75601
TBPE Firm Reg. # 14014
(O) 903-236-9744
(F) 903-236-9745
www.akron-consulting.com



PLAN VIEW
SCALE: 1"=300'



SECTION B-B
HORIZ. SCALE: 1"=300'
VERT. SCALE: 1"=30'



AKRON CONSULTING, LLC.
431 N. CENTER ST.
LONGVIEW, TX 75601
TBPE Firm Reg. # 14014
(O) 903-236-9744
(F) 903-236-9745
www.akron-consulting.com

WEST ASH POND WATER
SURFACE EXHIBIT