



**American Electric Power Service  
Corporation**

**East Bottom Ash Pond - CCR  
Location Restriction Evaluation**

H. W. Pirkey Power Plant  
2400 FM 3251  
Harrison County  
Hallsville, Texas

July 6, 2016



*Kenneth Brandner*

Kenneth Brandner, P.E., P.G.  
Senior Project Engineer

*Matthew J. Lamb*

Matthew J. Lamb  
Project Manager

*John W. Holm*

John Holm, P.E.  
Principal Engineer

**East Bottom Ash Pond – CCR  
Location Restriction Evaluation**

H.W. Pirkey Power Plant  
2400 FM 3251  
Harrison County  
Hallsville, Texas

Prepared for:  
AEP

Prepared by:  
ARCADIS U.S., Inc.  
100 E Campus View Blvd  
Suite 200  
Columbus  
Ohio 43235-1447  
Tel 614 985 9100  
Fax 614 985 9170

Our Ref.:  
OH015976.0010

Date:  
July 6, 2016

<b>1. Objective</b>	<b>1</b>
<b>2. Background Information</b>	<b>2</b>
2.1 Facility Location Description	2
2.2 Description of East Bottom Ash Pond CCR Unit	2
2.2.1 Embankment Configuration	2
2.2.2 Area/Volume	2
2.2.3 Construction and Operational History	2
2.2.4 Surface Water Control	3
2.3 Previous Investigations	3
2.4 Hydrogeologic Setting	4
2.4.1 Climate and Water Budget	5
2.4.2 Regional and Local Geologic Setting	5
2.4.3 Surface Water and Surface Water Groundwater Interactions	5
2.4.4 Water Users	6
<b>3. Isolation from the Uppermost Aquifer</b>	<b>7</b>
3.1 Uppermost Aquifer and Piezometric Analysis	7
3.1.1 Piezometric Analysis	7
3.1.1.1 Horizontal and Vertical Position Relative to CCR Unit	7
3.1.1.2 Overall Flow Conditions	7
3.1.2 Uppermost Aquifer	7
3.1.2.1 CCR Rule Definition	7
3.1.2.2 Common definitions	8
3.1.3 Identified onsite hydrostratigraphic unit	8
3.2 Compliance with Isolation Distance	8
<b>4. Wetlands</b>	<b>9</b>
4.1 Local Wetlands	9
4.2 Compliance with Wetland Restrictions	9

<b>5. Fault Areas</b>	<b>10</b>
5.1 Description of Regional Geologic Structural Features	10
5.2 Compliance with Fault Area Restrictions	10
<b>6. Seismic Impact Zone</b>	<b>11</b>
6.1 Definition of Seismic Impact Zone	11
6.2 Compliance with Seismic Impact Zone Restriction	11
<b>7. Unstable Areas</b>	<b>12</b>
7.1 Definition of Unstable Area and local Conditions	12
7.1.1 CCR Rule Definition	12
7.1.2 Poor Foundation Soils	12
7.1.3 Mass Movements	12
7.1.4 Karst	13
7.1.5 Subsurface Mining	13
7.2 Compliance with Unstable Areas Restriction	13
<b>8. Summary, Conclusions, and PE Certification</b>	<b>14</b>
<b>9. References</b>	<b>15</b>

**Tables**

Table 1	Water Level Data
---------	------------------

**Figures**

Figure 1	Site Location Map
Figure 2	Plant and CCR Unit Location Map
Figure 3	Site Layout and Well Locations
Figure 4	Cross Section A-A'
Figure 5	Cross Section B-B'
Figure 6	Cross Section C-C'
Figure 7	Cross Section D-D'

Figure 8	Cross Section E-E'
Figure 9	Potentiometric Surface Map, January 20, 2016
Figure 10	Wetland Location Map
Figure 11	Nearby Fault Locations
Figure 12	Nearby Seismic Impact Zones

## Appendices

A	Boring/Well Construction Logs
B	Photographic Log

## Acronyms and Abbreviation

AEP	American Electric Power Service Cooperation
amsl	above mean sea level
ARCADIS	ARCADIS U.S., Inc.
BAP	bottom ash pond
CCR	Coal Combustion Residual
CFR	Code of Federal Regulations
EPRI	Electric Power Research Institute
FAP	fly ash pond
FGD	flue gas desulfurization
ft	feet
PTI	Permit to Install
TAC	Texas Administrative Code
TCEQ	Texas Commission on Environmental Quality



## **1. Objective**

This report was prepared by ARCADIS U.S., Inc. (ARCADIS) for American Electric Power Service Corporation (AEP) to assess the location of the East Bottom Ash Pond relative to the location restrictions included in the Coal Combustion Residual (CCR) requirements, as specified in the Code of Federal Regulations (CFR) 40 CFR 257.60 to 257.64, at the AEP H.W. Pirkey Generating Plant (Plant) located at 2400 FM 3251 in Hallsville, Harrison County, Texas (**Figure 1**). The CCR requirements include an evaluation of the adequacy of the groundwater monitoring well network to characterize groundwater quality up and down gradient of the CCR unit and an evaluation of whether the CCR unit meets up to 5 location restrictions, which include: the base of the CCR unit is 5 feet (ft) above the uppermost aquifer, the CCR unit may not be located in a wetland, within 200 ft of the damage zone of a fault that has displacement during the Holocene, within a seismic impact zones, or in an unstable area.

Four regulated CCR units associated with the Plant were identified for review, which include the West Bottom Ash Pond (BAP), East BAP, Stack Out Area, and Landfill (**Figure 2**). This report summarizes the evaluation of the location restriction criteria at the East BAP (Site). The evaluation of the groundwater monitoring well network in the uppermost aquifer for the East BAP is not included in this report and will be completed under separate cover.

This evaluation included a review of AEP-provided data associated with previously completed subsurface investigation activities in the vicinity of the East BAP CCR unit, as well as publically-available geologic and hydrogeologic data. The following report also presents the current Conceptual Site Model based on documents reviewed and will further describe the uppermost aquifer.

## **2. Background Information**

The following section provides background information for the AEP H.W. Pirkey Generating Plant East BAP.

### **2.1 Facility Location Description**

The AEP H.W. Pirkey Plant is located in southern Harrison County, approximately 5 miles southeast of Hallsville, Texas, and approximately 8 miles southwest of Marshall, Texas. The East BAP CCR unit is located at the north end of the Plant and approximately 2,000 feet north-northwest of Brandy Branch Reservoir (**Figures 1 and 2**).

### **2.2 Description of East Bottom Ash Pond CCR Unit**

The following section will discuss the embankment configuration, area, volume, construction and operational history, and surface water control associated with the East BAP.

#### **2.2.1 Embankment Configuration**

The East BAP is partially incised into native soils with an embankment height of approximately 4 feet (AMEC, 2011). The East BAP embankments are constructed of compacted clay on a 3:1 slope (3 feet horizontal, 1 foot vertical) (Sargent & Lundy, 1983). The elevation of the top of the embankment around the perimeter of the East BAP is approximately 357 feet amsl, and the normal operating level is approximately 354 feet amsl (Johnson & Pace, May 2011). The interior bottom elevation of the East BAP is approximately 347 feet amsl (Sargent & Lundy, 1983; Johnson & Pace, June 2011).

#### **2.2.2 Area/Volume**

The East BAP is approximately 31.5 acres in size. The design maximum ash storage capacity of the East BAP is 188 acre feet (Sargent & Lundy, 1983). Johnson & Pace calculated the East BAP ash storage capacity in 2011 at 161 acre feet at an elevation of 355 feet amsl (maximum operating level) (Johnson & Pace, June 2011).

#### **2.2.3 Construction and Operational History**

The H.W. Pirkey Power Plant East BAP was constructed in 1983 and 1984, and began operation in 1985. Throughout the life of the Plant, CCR materials (fly ash, bottom ash, economizer ash, flue gas desulfurization sludge) have been generated. The East BAP, which was placed into operation in 1985, receives bottom ash and economizer ash

sluiced from the power plant boiler (**Figure 3**). Clear water overflow from the East BAP discharges into the Clearwater Pond located directly south of the East BAP. Bottom ash and economizer ash are periodically excavated from the East BAP and hauled by truck to either the on-site landfill for disposal, or for beneficial re-use.

The base of the East BAP was constructed in 1983 with a compacted clay liner (Sargent & Lundy, 1983). Following installation of the compacted clay liner, soil borings S-4 through S-7 were advanced below the base of the East BAP to total depths of six feet in September 1983 (Southwestern Laboratories, 1984). The lithologic data from soil borings S-4 through S-7 confirm at least six feet of clay is present below the base of the East BAP (Sargent & Lundy, 1984).

#### 2.2.4 Surface Water Control

Surface water elevation in the East BAP is controlled by a weir box and a manually operated gate valve on a 36-inch-diameter discharge pipe at the southwest corner of the pond. Clear water overflow from the East BAP discharges through the 36-inch-diameter pipe into the 2.7-acre Clearwater Pond located directly south of the East BAP (**Figure 3**). Water in the Clearwater Pond is either pumped (re-circulated) back into the boiler ash hopper, or gravity discharged through a pipe at the southwest corner of the Clearwater Pond into an unnamed intermittent tributary of Hatley Creek via Outfall 006 in accordance with Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0002496000.

### 2.3 Previous Investigations

The initial soils investigation and design of the East BAP was provided in a January 31, 1983 report prepared by Sargent & Lundy entitled "*Henry W. Pirkey Power Plant, Design Summary for Lignite Storage Area and Wastewater Pond Facilities*". This investigation included advancement of soil borings throughout the Plant, and design of the East BAP. As discussed above in Section 2.2.3, the design included installation of a clay liner below the East BAP.

In September-October 1983, Southwestern Laboratories conducted a soil investigation at the Plant, including advancement of four soil borings (S-4 through S-7) below the East BAP (Southwestern Laboratories, 1984).

In 1984, Sargent & Lundy conducted an evaluation of the East BAP. This report included evaluation of soil sample geotechnical data, and concluded a low-permeability clay liner was present below the East BAP (Sargent & Lundy, 1984).

In 2009, E TTL Engineers & Consultants (E TTL) conducted a geotechnical investigation of the East BAP earthen embankment. The investigation included installation of two



soil borings through the embankment (E1, E2), completion of the soil borings as piezometers PE-1 and PE-2, respectively, and collection of soil samples for geotechnical analyses. The report concluded the embankment was stable and the existing embankment slopes were acceptable if conditions are maintained (ETTL, 2010). The conditions to be maintained included embankment protection from erosion (vegetative cover), removal of brush and trees two feet or more in height, and control of animal burrowing.

In 2010 and January 2011, Apex Geoscience expanded the groundwater monitoring well system at the Plant, including installation of monitoring wells AD-16 through AD-29. Apex Geoscience also conducted video surveillance of the existing monitoring wells and plugged monitoring wells MW-1, MW-5, MW-6, MW-9, MW-11, MW-14, MW-15, M-2, and M-3 (Apex Geoscience, 2011).

In 2011, Johnson & Pace performed a hydraulic analysis of the East BAP for a 10-year, 24-hour rainfall event in accordance with the TCEQ TPDES permit design criteria. The report concluded the storage capacity of the East BAP is hydraulically adequate (Johnson & Pace, May 2011).

In 2015, Auckland Consulting further expended the groundwater monitoring well system at the Plant, including installation of monitoring wells AD-30 through AD-35 (Auckland Consulting, 2016).

#### 2.4 Hydrogeologic Setting

The site area is located within the West Gulf Coastal Plain. Cretaceous formations crop out in belts that extend in a northeasterly direction parallel to the Gulf of Mexico, and dip gently southeast. The central and northern portions of the Plant are located on the outcrop of the Eocene-age Recklaw Formation. The Recklaw Formation consists predominantly of clay and fine grained sand, and attains a maximum thickness of approximately 100 feet (Broom, 1966).

The Recklaw Formation is underlain by the Eocene-age Carrizo Sand, which outcrops in the topographically low southern portion of the Plant. The Carrizo Sand consists of fine to medium grained sand interbedded with silt and clay, and attains a thickness of approximately 100 feet (Broom, 1966).

These features are further illustrated on five lines of cross section that were prepared through the East BAP area, with three lines trending from west to east (A-A'; B-B'; C-C'), and the other two lines trending from north to south (D-D'; E-E'). The cross section location map is included as **Figure 3** and the lines of cross section are included as **Figure 4 (A-A')** through **Figure 8 (E-E')**.

#### 2.4.1 Climate and Water Budget

Average temperatures in Harrison County, Texas range from 47.1° Fahrenheit (F) in January to 83.8°F in July, and the mean annual growing season is 238 days. Average annual precipitation (including liquid water equivalent from snowfall) is approximately 47 inches (Broom, 1966).

#### 2.4.2 Regional and Local Geologic Setting

The central and northern portions of the Plant, including the East BAP, are located on the outcrop of the Eocene-age Recklaw Formation. The Recklaw Formation is underlain by the Eocene-age Carrizo Sand, which outcrops in the topographically low southern end of the Plant (Broom, 1966; Flawn, 1965).

Detailed regional geologic characterization can be found in several published reports including Texas Water Development Report 27 "Ground-Water Resources of Harrison County, Texas" (Broom, 1966), The University of Texas at Austin Bureau of Economic Geology "Geologic Atlas of Texas – Tyler Sheet" (Flawn, 1965), and U.S. Geological Survey Open-File Report 88-450K "Petroleum Geology and the Distribution of Conventional Crude Oil, Natural Gas, and Natural Gas Liquids, East Texas Basin" (USGS, 1988).

Detailed regional and site geologic characterization can also be found in the 2010 E TTL report entitled "Geotechnical Investigation, Pirkey Power Station, Existing Ash, Surge, Lignite and Limestone Runoff, and Landfill Stormwater Ponds Embankment Investigation, Hallsville, Texas" (E TTL, 2010).

#### 2.4.3 Surface Water and Surface Water Groundwater Interactions

**Figure 9** is a potentiometric surface map based on January 2016 water level data for the uppermost water bearing unit at the Site, and water level elevations in the Site monitoring wells are summarized on **Table 1**. As shown on **Figure 9**, shallow groundwater flow direction in the area of the East BAP is west-southwesterly at an average hydraulic gradient of approximately 0.01 foot per foot.

The East BAP is located approximately 2,000 feet north-northwest of Brandy Branch Reservoir, which was dammed during Plant construction in the 1980's. The normal pool level of Brandy Branch Reservoir is approximately 340 feet amsl. As shown on **Figure 9**, shallow groundwater flow direction at the Site generally follows surface topography to the west and southwest toward Hatley Creek, which is located in a topographically low area approximately one mile west of the Site. Therefore shallow groundwater in the area of the East BAP does not discharge into Brandy Branch Reservoir. Brandy Branch Reservoir likely recharges the uppermost water bearing unit



in the southern portion of the Plant, where the pool level in the Reservoir (340 feet amsl) is higher than water level elevations in monitoring wells located southwest (downslope) of the Reservoir.

#### 2.4.4 Water Users

A water well inventory conducted by Banks Information Solutions showed 12 water wells had been drilled within a ½-mile radius of the Site (Banks, 2015). The nearest water well was reportedly drilled approximately 500 feet south (side gradient) of the East BAP in 2004 by Bennett Drilling for use as a rig supply well. The water well was screened from 350 to 430 feet below ground surface, therefore this water well is completed in a deeper water bearing unit relative to the uppermost water-bearing unit at the Site.

The second closest water well was reportedly drilled approximately ¼-mile southwest (downgradient) of the East BAP for NFR Energy in 2008 for use as a rig supply well. The water well was screened from 250 to 310 feet below ground surface, therefore this water well is completed in a deeper water bearing unit relative to the uppermost water-bearing unit at the Site.

All of the water wells identified within a ½-mile radius of the Site were drilled to total depths of 160 feet or deeper except one water well (Well ID: 35-37-4E) that was drilled to a total depth of 55 feet in 1982. This water well was completed with concrete tile from the surface to total depth, and is located approximately ¼-mile east (up gradient) of the Pirkey Power Plant.

### 3. Isolation from the Uppermost Aquifer

CCR Rule 40 CFR Part 257.60 requires that the base of new and existing CCR surface impoundments be constructed such that the base of the unit is no less than 5 ft above the top of the uppermost aquifer, or that if the base is within 5 ft of the uppermost aquifer, that there will not be hydraulic connection between the base of the unit and the uppermost aquifer.

#### 3.1 Uppermost Aquifer and Piezometric Analysis

##### 3.1.1 Piezometric Analysis

###### 3.1.1.1 *Horizontal and Vertical Position Relative to CCR Unit*

Geologic data from soil borings, piezometers, and monitoring wells installed at the Site show the uppermost water bearing unit in the area of the East BAP is a very fine to fine grained clayey and silty sand stratum with an average thickness of approximately 15 feet that is located between an elevation of approximately 325 and 340 feet amsl (**Appendix A**). The base of the East BAP is at an elevation of 347 feet amsl. Therefore the separation distance between the uppermost water-bearing unit and the base of the East BAP is approximately seven feet. This separation distance is further illustrated on cross section A-A' (**Figure 4**) and cross section E-E' (**Figure 8**).

###### 3.1.1.2 *Overall Flow Conditions*

Groundwater is recharged from regional precipitation infiltration. The uppermost water bearing unit (clayey and silty sand) is expected to have a hydraulic conductivity of approximately  $10^{-4}$  centimeters per second (Fetter, 1980). Based on the hydraulic conductivity and saturated thickness (approximately 15 feet), the yield of the uppermost water-bearing unit is anticipated to exceed the TCEQ non-useable (Class 3) limit of 150 gallons per day (TCEQ, 2010).

Available groundwater elevations are summarized on **Table 1** for 2011 through 2016. The most recent comprehensive groundwater data set from January 2016 is depicted on **Figure 9**. The groundwater flow is west-southwesterly towards Hatley Creek, which is located approximately one mile west of the Site.

##### 3.1.2 Uppermost Aquifer

###### 3.1.2.1 *CCR Rule Definition*

The CCR rule definitions for an aquifer and the uppermost aquifer as specified in 40 CFR 257.53 indicates an aquifer is a geologic formation capable of yielding usable

quantities of groundwater to wells or springs while an uppermost aquifer is defined as the geologic formation nearest the natural ground surface that is an aquifer, as well as lower aquifers, that are hydraulically interconnected with this aquifer within the facility's property boundary. Upper limit is measured at a point nearest to the natural groundwater surface to which the aquifer rises during the wet season.

#### 3.1.2.2 *Common definitions*

An aquifer is commonly defined as a geologic unit that stores and transmits water (readily or at sufficient flow rates) to supply wells and springs (USGS, 2015; Fetter, 2001). The uppermost aquifer is considered the first encountered aquifer nearest to the CCR unit.

#### 3.1.3 Identified onsite hydrostratigraphic unit

The identified Site hydrostratigraphic unit in the area of the East BAP is the clayey and silty sand stratum that is located between an elevation of approximately 325 and 340 feet amsl.

### 3.2 Compliance with Isolation Distance

The uppermost water-bearing unit underlying the East BAP meets the regulatory definition of an aquifer. As shown on the cross-sections presented on **Figures 4 and 8**, the base of the East BAP is six feet or more above this aquifer. Therefore, this CCR Unit complies with the requirement for placement above the uppermost aquifer. Also, four soil borings (S-4 through S-7) were advanced six feet below the base of the East BAP in 1983 following installation of the clay liner, and these four soil borings confirm the presence of the clay liner below the East BAP.



#### **4. Wetlands**

CCR Rule 40 CFR Part 257.61 requires that existing and new CCR surface impoundments must not be located in wetlands.

##### **4.1 Local Wetlands**

Based on the August 19, 2015 site visit and review of available published information, the East BAP is not located within an area that exhibited wetland characteristics that might be classified as a regulated wetland. Photos of the East BAP area are included in **Appendix B**, and **Figure 10** is a map showing wetlands locations in the CCR unit area.

##### **4.2 Compliance with Wetland Restrictions**

Based on the August 19, 2015 site visit and review of available information, the East BAP does not contain wetlands. Therefore, this CCR Unit complies with the requirement for not being located in a wetlands.

## 5. Fault Areas

CCR Rule 40 CFR Part 257.62 requires that existing and new CCR surface impoundments must not be located within 200 feet of the outermost damage zone of a fault that has had displacement in Holocene time unless the owner or operator demonstrates that an alternate setback will prevent damage to the structural integrity of the CCR unit.

### 5.1 Description of Regional Geologic Structural Features

Regional geologic publications were reviewed to determine structural features for the Site. A regional fault map is provided on **Figure 11**. The U.S. Geological Survey Open File Report 88-450K shows the Site is located within the East Texas Basin, with faulting north of the basin (Talco Fault Zone) and south of the basin (Elkhart-Mt. Enterprise Fault Zone). No faulting was identified in the Site area (USGS, 1988). Texas Water Development Board Report 27, and the University of Texas at Austin Bureau of Economic Geology Geologic Atlas of Texas – Tyler Sheet show no faulting at the Site (Broom, 1966; Flawn, 1965).

A previous evaluation of geologic structural features at the Site was conducted by ETTL, and no evidence of faulting was identified (ETTL, 2010).

### 5.2 Compliance with Fault Area Restrictions

A review of available geologic reports and maps has indicated that the Site is not located near any faults with displacement in the Holocene. Therefore, the CCR unit complies with the requirement for not being located within 200 feet of the outermost damage zone of a fault that has had displacement in Holocene time.

## **6. Seismic Impact Zone**

CCR Rule 40 CFR Part 257.63 requires that existing and new CCR surface impoundments must not be located within a seismic impact zone unless the owner or operator demonstrates that all structural components of the CCR unit are designed to withstand the maximum horizontal acceleration in lithified earth material for the site.

### **6.1 Definition of Seismic Impact Zone**

CCR Rule 40 CFR Part 257.53 defines a seismic impact zone as an area having a 2% or greater probability that the maximum horizontal acceleration expressed as a percentage of the earth's gravitational pull (g) will exceed 0.10 g in 50 years.

### **6.2 Compliance with Seismic Impact Zone Restriction**

**Figure 12** presents the seismic hazard map for Texas, as published by the USGS. As shown on **Figure 12**, the Site falls within the zone having a maximum horizontal acceleration of 0.04 to 0.06 g. Therefore, the CCR unit complies with the requirement for not being located in a seismic impact zone.



## **7. Unstable Areas**

CCR Rule 40 CFR Part 257.64 requires that existing and new CCR surface impoundments must not be located within an unstable area unless the owner or operator demonstrates that the design of the unit will ensure the integrity of the structural components of the unit.

### **7.1 Definition of Unstable Area and local Conditions**

#### **7.1.1 CCR Rule Definition**

CCR Rule 40 CFR Part 257.53 defines an unstable area as a location that is susceptible to natural or human-induced events or forces capable of impairing the integrity of the CCR unit. These may include poor foundation conditions, areas susceptible to mass movements (landslides), and karst terrains.

#### **7.1.2 Poor Foundation Soils**

The East BAP design report was prepared by Sargent & Lundy in 1983 (Sargent & Lundy, 1983). The East BAP was constructed in 1983 using compacted clay. The specifications included installation of clay embankments with 3:1 slopes (3 feet horizontal, 1 foot vertical) around the perimeter of the pond with a crest (top of embankment) elevation of 357 feet amsl, and compaction of the clay embankments to ≥95% standard proctor density. The specifications also included emplacement of a compacted cohesive clay lining below the pond base elevation of 347 feet amsl.

ETTL conducted a geotechnical investigation of the East BAP earthen embankment in 2009. The investigation included installation of two soil borings through the embankment (E1, E2), completion of the soil borings as piezometers PE-1 and PE-2, respectively, and collection of soil samples for geotechnical analyses. The report noted the East BAP was cut (incised) into native soils with minimal embankment heights. The report concluded the embankment was stable and the existing embankment slopes were acceptable if conditions are maintained (ETTL, 2010). The conditions to be maintained included embankment protection from erosion (vegetative cover), removal of brush and trees two feet or more in height, and control of animal burrowing.

#### **7.1.3 Mass Movements**

The East BAP is not located within an area subject to mass movements. This conclusion is supported by the ETTL soil stability report (ETTL, 2010).



#### 7.1.4 Karst

The site area is located on the outcrop of unconsolidated Cretaceous Formations consisting predominantly of sand and clay (Broom, 1966; Flawn, 1965). The East BAP is not located in a karst area.

#### 7.1.5 Subsurface Mining

No subsurface mines are known to exist below the CCR units at the Site.

### **7.2 Compliance with Unstable Areas Restriction**

Based on our site visit and review of available information, the East BAP is not located within unstable areas. Therefore, this CCR unit complies with the requirement of not being located in an unstable area.



**East Bottom Ash Pond-  
CCR Location Restriction  
Evaluation**

H.W. Pirkey Power Plant  
2400 FM 3251  
Harrison County  
Hallsville, Texas

**8. Summary, Conclusions, and PE Certification**


I, Kenneth J. Brandner, certify that this report was prepared under my direction and supervision, and that the information contained herein is true and accurate to the best of my knowledge. Based on my experience and knowledge of the site, as well as the evaluations discussed within this report, the H.W. Pirkey Power Plant East Bottom Ash Pond complies with the requirements of the location restrictions sections of 40 CFR 257 Subpart D that apply to surface impoundments and therefore the CCR unit is not located in a restricted location.

Kenneth J. Brandner

Printed Name of Registered Professional Engineer

Kenneth J. Brandner

Signature



69586

Registration No.

Texas

Registration State

7-6-16

Date

## 9. References

AMEC, "Report of Dam Safety Assessment of Coal Combustion Surface Impoundments, American Electric Power (AEP) and Southwest Electric Power Company (SWEPCO) H.W. Pirkey Power Plant, Hallsville, TX", August 2011.

Apex Geoscience Inc., "USWAG Monitoring Wells and Groundwater Evaluation, AEP Pirkey Power Station, Hallsville, Texas", March 2011.

Auckland Consulting LLC, "Monitoring Well Installation – 2015, Pirkey Generating Station, Hallsville, Texas", January 26, 2016.

Banks Information Solutions, "Water Well Report, Pirkey Power Plant, 2400 FM 3251, Hallsville, Texas, Harrison County", October 8, 2015.

Broom, M.E., and B. N. Myers, "Ground-Water Resources of Harrison County, Texas", Texas Water Development Board Report 27, August 1966.

ETTL Engineers & Consultants Inc., "Geotechnical Investigation, Pirkey Power Station, Existing Ash, Surge, Lignite and Limestone Runoff, and Landfill Stormwater Ponds Embankment Investigation, Hallsville, Texas", October 2010.

Fetter, C.W., "Applied Hydrogeology", University of Wisconsin – Oshkosh, 1980.

Flawn, Peter T., "Geologic Atlas of Texas, Tyler Sheet", The University of Texas at Austin Bureau of Economic Geology, March 1965.

George, Peter G., et. al., "Aquifers of Texas", Texas Water Development Board Report 380, July 2011.

Johnson & Pace Incorporated, "Hydrology & Hydraulic Report, North Surge Pond, East & West Ash Ponds, Secondary Ash Pond, Landfill Pond, H.W. Pirkey Power Plant, Hallsville, Texas", May 2011.

Johnson & Pace Incorporated, "East Bottom Ash Pond June 2011 As-Built Plan & Profile, H.W. Pirkey Power Plant, Hallsville, Texas", June 2011.

Sargent & Lundy, "Henry W. Pirkey Power Plant, Design Summary for Lignite Storage Area and Wastewater Pond Facilities", January 31, 1983.

Sargent & Lundy, "Henry W. Pirkey Power Plant Unit 1, Wastewater Ponds – Liner Verification & Monitoring Wells", September 14, 1984.



**East Bottom Ash Pond-  
CCR Location Restriction  
Evaluation**

H.W. Pirkey Power Plant  
2400 FM 3251  
Harrison County  
Hallsville, Texas

Southwestern Laboratories, "Subsurface Exploration, Waste Water Ponds, Pirkey Power Plant, Hallsville, Texas", September 7, 1984.

Texas Commission on Environmental Quality, "Groundwater Classification, RG-366/TRRP-8", March 2010.

USGS, Aquifers and Groundwater. 2015. Available online at [www.usgs.gov](http://www.usgs.gov).

USGS, "Petroleum Geology and the Distribution of Conventional Crude Oil, Natural Gas, and Natural Gas Liquids, East Texas Basin", Open-File Report 88-450K, 1988.

USGS, "Texas Seismic Hazard Map", 2014.

**Table 1  
Water Level Data  
AEP Pirkey Power Plant - CCR Storage Areas  
Hallsville, Harrison County, Texas**

Well ID	Latitude	Longitude	Ground Surface Elevation <sup>(a)</sup>	Top of Casing Elevation <sup>(a)</sup>	Borehole depth ft. bls	Date Installed	Screen Material	Well diameter inches	Top of Screen <sup>(b)</sup>		Bottom of Screen <sup>(b)</sup>		4/13/2011	12/15/2011	6/20/2012	1/23/2013	7/7/2013	1/22/2014	7/9/2014	1/28/2015	1/20/2016
									Depth ft. bls	Elevation ft. msl	Depth ft. bls	Elevation ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl	GW Elev. ft. msl
<b>Monitoring Wells</b>																					
MW-2/AD-2	32° 27' 54.753"	94° 29' 25.282"	341.25	344.04	40	10/7/83	Sch. 40 PVC	4	20	321.25	40	301.25	326.90	327.12	327.17	327.26	326.62	327.70	327.19	328.62	328.55
MW-3/AD-3	32° 28' 6.829"	94° 29' 21.498"	372.76	375.30	57	11/4/83	Sch. 40 PVC	4	37	335.76	57	315.76	342.95	341.59	343.70	341.10	343.27	341.42	343.96	345.01	347.03
MW-4/AD-4	32° 27' 59.247"	94° 29' 4.692"	363.69	366.79	46	10/10/83	Sch. 40 PVC	4	26	337.69	46	317.69	351.45	351.24	352.44	354.42	349.22	355.58	353.33	359.00	359.16
MW-7/AD-7	32° 27' 43.611"	94° 29' 15.611"	359.61	362.79	40	10/3/83	Sch. 40 PVC	4	20	339.61	40	319.61	344.34	343.75	344.15	344.90	343.35	346.61	346.23	349.17	349.31
MW-8/AD-8	32° 27' 25.095"	94° 29' 14.925"	356.92	359.84	35	10/4/83	Sch. 40 PVC	4	20	336.92	35	321.92	341.65	340.29	341.65	340.72	341.25	341.67	343.36	344.03	347.21
MW-10/AD-10	32° 27' 52.446"	94° 29' 16.545"	359.48	362.21	40	10/10/83	Sch. 40 PVC	4	20	339.48	40	319.48	342.03	341.90	342.19	341.41	339.85	342.27	342.22	344.39	343.97
MW-12/AD-12	32° 27' 51.702"	94° 29' 3.238"	378.84	381.99	51	1/30/86	Sch. 40 PVC	4	31	347.84	51	327.84	358.95	357.99	359.33	368.07	357.41	369.97	367.04	372.75	371.05
MW-13/AD-13	32° 27' 46.002"	94° 29' 5.71"	361.98	364.76	40.5	2/23/88	Sch. 40 PVC	4	30.5	331.48	40.5	321.48	349.46	348.91	349.52	350.81	348.61	351.97	351.29	354.47	354.15
AD-16	32° 27' 40.871"	94° 29' 38.637"	356.81	360.05	35	12/30/10	Sch. 40 PVC	2	15.0	341.81	35.0	321.81	338.08	335.50	337.58	335.43	336.67	339.53	340.84	343.34	347.68
AD-17	32° 28' 2.315"	94° 29' 39.45"	342.65	346.09	30	12/30/10	Sch. 40 PVC	2	10.0	332.65	30.0	312.65	322.66	322.29	323.31	323.51	323.06	325.19	324.15	328.42	326.78
AD-18	32° 28' 9.245"	94° 29' 6.469"	360.48	363.42	25	1/3/11	Sch. 40 PVC	2	15.0	345.48	25.0	335.48	355.53	351.54	357.21	355.47	357.23	360.03	358.06	359.88	360.52
AD-19	32° 27' 50.512"	94° 29' 13.973"	359.50	362.82	30	12/30/10	Sch. 40 PVC	2	10.0	349.50	30.0	329.50	344.07	343.58	344.29	344.62	342.60	345.11	345.76	347.92	347.40
AD-20	32° 27' 51.346"	94° 29' 21.576"	352.30	355.79	35	12/28/10	Sch. 40 PVC	2	15.0	337.30	35.0	317.30	334.50	334.63	334.69	334.78	333.38	335.38	334.87	336.88	336.07
AD-21	32° 27' 45.403"	94° 29' 19.195"	347.23	350.72	30	12/27/10	Sch. 40 PVC	2	10.0	337.23	30.0	317.23	340.43	340.02	340.22	341.57	339.16	342.36	341.67	345.45	343.82
AD-22	32° 27' 41.349"	94° 29' 17.779"	355.57	358.51	30	12/16/10	Sch. 40 PVC	2	10.0	345.57	30.0	325.57	343.64	343.16	343.74	344.83	342.90	346.49	345.77	350.24	350.29
AD-23	32° 27' 3.384"	94° 29' 41.258"	346.72	350.10	35	12/15/10	Sch. 40 PVC	2	15.0	331.72	35.0	311.72	319.65	318.94	319.29	318.66	318.87	319.80	319.79	319.84	321.23
AD-24	32° 27' 1.455"	94° 29' 56.388"	287.68	291.14	20	12/27/10	Sch. 40 PVC	2	5.0	282.68	20.0	267.68	282.92	284.29	285.10	285.63	285.06	288.30	287.10	288.56	---
AD-25	32° 27' 17.187"	94° 29' 58.998"	334.15	337.09	30	12/14/10	Sch. 40 PVC	2	10.0	324.15	30.0	304.15	324.51	321.90	323.14	321.94	322.15	322.56	324.24	326.42	327.00
AD-26	32° 27' 25.426"	94° 29' 54.775"	342.41	345.25	40	12/14/10	Sch. 40 PVC	2	10.0	332.41	40.0	302.41	324.53	323.77	323.62	322.32	322.09	323.24	322.51	323.04	326.06
AD-27	32° 27' 36.66"	94° 29' 47.272"	349.83	352.62	37.5	12/15/10	Sch. 40 PVC	2	17.5	332.33	37.5	312.33	325.82	324.54	326.13	325.39	325.35	326.39	327.91	329.69	330.89
AD-28	32° 27' 55.439"	94° 29' 39.418"	335.92	339.40	40	12/28/10	Sch. 40 PVC	2	15.0	320.92	35.0	300.92	319.67	319.16	319.92	320.21	319.69	320.65	320.22	322.16	321.39
AD-29	32° 28' 8.271"	94° 29' 31.939"	350.21	353.37	30	1/3/11	Sch. 40 PVC	2	10.0	340.21	30.0	320.21	334.68	333.37	334.74	337.47	336.84	338.55	335.85	340.57	338.48
AD-30 <sup>(d)</sup>	32° 27' 56.49"	94° 29' 32.53"	339.04	342.02	25	12/8/15	Sch. 40 PVC	2	10.0	329.04	25.0	314.04	---	---	---	---	---	---	---	---	323.70
AD-31 <sup>(d)</sup>	32° 28' 02.48"	94° 29' 20.90"	357.75	360.75	35	12/8/15	Sch. 40 PVC	2	20.0	337.75	35.0	322.75	---	---	---	---	---	---	---	---	346.60
AD-32 <sup>(d)</sup>	32° 27' 56.20"	94° 29' 11.86"	357.23	359.18	33	12/11/15	Sch. 40 PVC	2	13.0	344.23	33.0	324.23	---	---	---	---	---	---	---	---	352.32
AD-33 <sup>(d)</sup>	32° 27' 38.70"	94° 29' 15.82"	359.30	362.37	30	12/11/15	Sch. 40 PVC	2	15.0	344.30	30.0	329.30	---	---	---	---	---	---	---	---	351.13
AD-34 <sup>(d)</sup>	32° 27' 10.13"	94° 29' 57.93"	304.64	307.61	25	12/11/15	Sch. 40 PVC	2	10.0	294.64	25.0	279.64	---	---	---	---	---	---	---	---	307.61
AD-35 <sup>(d)</sup>	32° 27' 09.64"	94° 29' 42.74"	316.01	318.95	20	12/11/15	Sch. 40 PVC	2	3.0	313.01	18.0	298.01	---	---	---	---	---	---	---	---	309.85
<b>Piezometers<sup>(c)</sup></b>																					
W-3 (PW-3)	32° 27' 57.6"	94° 29' 31.8"	356.30	356.30	38	10/20/09	Sch. 40 PVC	2	28.0	328.30	38.0	318.30	NM	NM	NM	NM	NM	NM	NM	NM	NM

(a) Source: Apex Geoscience Inc. (March 23, 2011).


(b) Screen length and screened intervals for AD-2 through AD-12 estimated from video surveillance (Apex Geoscience Inc., March 23, 2011).

(c) Source: EETL (October 2010).



(d) Source: Auckland Consulting LLC (January 26, 2016). Monitoring wells AD-30 through AD-35 installed during December 2015.

Groundwater Elevation Source: AEP, Pirkey Monitoring Well Groundwater Elevations through January 2015.

NM - Not Measured



Source:  
7.5 minute topographic quadrangle  
Darco, Texas, 2013  
Easton, Texas, 2013



PIRKEY POWER PLANT  
2400 FM 3251  
HALLSVILLE, HARRISON COUNTY, TEXAS

**SITE LOCATION MAP**





PIRKEY POWER PLANT  
 2400 FM 3251  
 HALLSVILLE, HARRISON COUNTY, TEXAS


**PLANT AND CCR UNIT LOCATION MAP**

FIGURE  
**2**



**Legend**  
 Coal Combustion Residual (CCR) Unit





**Legend**

- COR Boundary
- + Monitoring Well/Piezometer
- + Plugged Monitoring Well/Piezometer
- Soil Boring
- Line of Geologic Cross Section

\* Non-CCR Unit

0 750 1,500  
SCALE IN FEET

PIRKEY POWER PLANT  
2400 FM 3251  
HALLSVILLE, HARRISON COUNTY, TEXAS

**SITE LAYOUT AND WELL LOCATIONS**

FIGURE 3

**ARCADIS**














PIRKEY POWER PLANT  
 2400 FM 9251  
 HALLSVILLE, HARRISON COUNTY, TEXAS

**WELL ELEVATIONS AND POTENTIOMETRIC  
 MAP - JANUARY 20, 2016**

FIGURE **9**

- Legend**
- CCR Boundary
  - Monitoring Well/Piezometer
  - Plugged Monitoring Well/Piezometer
  - Soil Boring
  - 328.55 Water Level Elevation (feet MSL)
  - Groundwater Contour
  - Groundwater Flow Direction
  - Non-CCR Unit



0 500 1,000 2,000 Feet

PIRKEY POWER PLANT  
 2400 FM 3251  
 HALLSVILLE,  
 HARRISON COUNTY, TEXAS

POTENTIAL WETLAND LOCATIONS

FIGURE  
 10



**Legend**


 Potential Wetlands

Brandy Branch  
 Reservoir

Source: Esri, DigitalGlobe, GeoEye, Earth  
 StarOpen, and the IGNIS Data Community







2014 Seismic Hazard



SOURCE:  
USGS Earthquake Hazards Program,  
Texas: 2014 Seismic Hazard Map



SCALE IN MILES  
SCALE IS APPROXIMATE

AEP PIRKEY PLANT ASH POND  
AUGUST 2014  
HALLETSVILLE, TX

NEARBY SEISMIC IMPACT ZONES



FIGURE  
**12**

**Appendix A**

**Boring/Well Construction Logs**

832964

### LOG OF BORING

PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: MW-2  
LOCATION: Hallsville

Date: 10-7-83

Type: Auger

Ground Elevation:

Depth, Feet	Symbol	Sample	Legend:		
			■ Sample	X Penetration	▼ Water
Description of Stratum					
5		■	Firm tan clayey silty sand		
10		■	Medium tan and grey very sandy silty clay		
15		■	Dense tan and grey clayey silty sand		
20		X	Dense tan clayey silty sand 10-15-16 31 B/F		
25		■	Dense tan silty sand		
30		X	Very dense grey clayey silty sand 15-35=12" 50 B/F		
35		X	Very dense grey clayey silty sand 21-29=9" 50 B/9"		
40		X	Hard grey sandy silty clay 20-30=12" 50 B/F		
45			Bottom of boring at 40 feet.		
50			Water encountered at 25 feet.		

832964

### LOG OF BORING


PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: MW-3  
LOCATION: Hallsville, TX

Date: 11-4-83

Type: Auger

Ground Elevation:



832964

LOG OF BORING


PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: MW-3  
LOCATION: Hallsville, TX

Date: 11-4-83

Type: Auger

Ground Elevation:

Depth, Feet	Symbol	Sample	Legend:
			■ Sample                      X Penetration                      ▼ Water
Description of Stratum			
55		X	Hard grey silty sandy clay 28-22=10" 50 B/10"
60			Bottom of boring at 57 feet.
65			Water encountered at 42 feet.
70			
75			
80			
85			
90			
95			
100			

832964

LOG OF BORING

PROJECT: Waste Water Ponds  
 CLIENT: SWBPCO

BORING NO.: MW-4  
 LOCATION: Hallsville

Date: 10-10-83

Type: Auger

Ground Elevation:

Depth, Feet	Symbol	Sample	Legend:		
			■ Sample	X Penetration	▼ Water
Description of Stratum					
5		■	Stiff tan and grey silty sandy clay w/iron ore		
10		■	Very stiff tan and grey clay		
15		■	Very stiff tan and grey clay w/iron ore seam		
20		■	Stiff tan and grey silty sandy clay lenses		
25		■	Firm grey silty sand		
30		X	Very dense grey silty sand 30-20=12" 50 B/F		
35		X	Hard grey silty sandy clay 30-20=8" 50 B/8"		
40		X	Hard grey silty sandy clay 25-25=8" 50 B/8"		
45		X	Hard grey silty sandy clay 25-25=10½" 50 B/10½"		
50			Bottom of boring at 46 feet.		

APEX PROJECT NO.: 119-089  BORING  MONITOR WELL  
 BORING NUMBER: \_\_\_\_\_ MONITOR WELL NUMBER: AD-18

FACILITY NAME: AEP- Pirkey Power Plant FACILITY ID NO.: N/A

FACILITY ADDRESS: Hallsville, Texas

DRILLING COMPANY/METHOD/RIG: Apex Geoscience Inc. / Hollow-stem Auger/ CME-55 Track Rig

DRILLER: Ed Wilson, Apex Geoscience Inc. COMPLETION DATE: 1/3/2011

PREPARED BY: Jeff Sammons LOGGED BY: Matt Lyon/Jeff Sammons

LATITUDE: N 32°28.154' Datum: WGS-84 WELL LOCATION: Northeast of Bottom Ash Pond #1  
 LONGITUDE: W94°29.108'

DEPTH (FEET)	PTD (PPM)	SAMPLE INTERVAL	WELL LOG AND COMPLETION DETAILS	USCS CODE	SOIL DESCRIPTION AND COMMENTS	Odor	Moisture		
1				0-7	SM	Sandy Silt, some clay, very fine grained, gray, light brown, light brownish red, yellowish brown	None	Dry	
2				8	7-16	CL	Clay, some sand, light gray, reddish gray, stiff, yellowish brown -iron oxide fracture at 9.5'	None	Dry
3									
4									
5									
6									
7									
8				7-16	CL	Clay, some sand, light gray, reddish gray, stiff, yellowish brown -iron oxide fracture at 9.5'	None	Dry	
9									
10									
11									
12									
13									
14									
15						-increasing sand content at 14', thin lenses of iron-oxide cemented sand at 14.5', 15', 15.5', stiff		Moist	
16				16-25	SM	Silty sand, some clay, gray, yellowish brown, dense, abundant gypsum crystals, abundant iron oxide cemented sandstone gravel in layers, saturated 19-21'	None	Moist to V. Moist	
17							None		
18							None		
19							None		
20							None		
21						-dark gray at 21'	None		
22						-clayey at 21-23'	None		
23						-greenish gray, trace clay, at 23'	None		
24							None		
25						-clay lense, hard, dry, (shale), at 24.5-25'	None	Dry	
26									
27						Boring Terminated at 25'			
28									
29									
30									
31									
32									
33									
34									
35									
36									
37									
38									
39									
40									

Cement Bentonite Filter Sand Water Level



Total Depth: 25 feet Riser Interval: +3 (agg)-15'  
 Filter Sand (Size/Interval): 13-25' Screen Interval: 15-25'  
 Grout (Type/Interval): Grout from 0-2', Bentonite from 2-13' Water level: \_\_\_\_\_  
 Surface Completion  Flush  Above Ground 3'


Note: This log is not to be used separate from this report.





# Monitor Well

Monitor Well No.: AD-31



## PROJECT INFORMATION

PROJECT: Pitney Power Plant  
 PROJECT NO.: I-44-1021  
 LOGGED BY: Jeffrey D. Sammons, P.G.  
 SUPERVISING PG: Jeffrey D. Sammons, P.G.  
 COMPLETION: 12/08/2018  
 DEVELOPMENT: 12/10/2018  
 SITE LOCATION: 3400 FM 3251, Hallsville, Texas  
 WELL OWNER: AEP

## DRILLING INFORMATION

DRILLER: Buford Collier  
 DRILLER'S LICENSE NO.: 80089  
 RIG TYPE: Geoprobe 3238DT  
 METHOD OF DRILLING: Hollow Stem Auger  
 SAMPLING METHODS: Split Core  
 SURFACE ELEVATION: 360.75 (Top of Casing)  
 HOLE DIAMETER: 8.50"  
 LATITUDE 32 28' 2.48" LONGITUDE 94 29' 20.96"

Water Level Upon Installation

Water Level at Time of Drilling

Geotechnical Lab Sample

TBPG No. 50027


DESCRIPTION	USCS	SOIL SYMBOLS	DEPTH	WATER LEVEL	SAMPLE	% MOISTURE	% FINES	LL	PL	PI	WELL CONSTRUCTION
			0								Locking Well Casing Cover Locking Well Cap Protective Well Casing Concrete Pad Ground Surface Cement
SANDY CLAY AND GRAVEL: dark reddish brown, moist	CH		1								
FAT CLAY WITH SAND: some laminations of very fine to fine sand, reddish brown and light gray	CH		2			22	81	51	15	36	
FAT CLAY: some silt with trace very fine to fine sand laminations, reddish brown, yellowish brown and light gray	CH		3								
			4								
			5								
			6								
			7								
			8								
			9								
			10								Bentonite
			11								2" Sch. 40 PVC Riser
- light gray with laminations of light reddish brown silt and very fine sand at 11'			12			28	85	68	31	37	
			13								
			14								
			15								
			16								
			17								
			18								
CLAYEY SAND: very fine to fine sand, light reddish brown and light gray, very moist to saturated	SC		19								
			20								
- dark gray and gray clay with thin seams of light reddish brown very fine sand at 22' to 23'			21			28	44	36	21	16	
			22								
			23								
			24								
			25								20/40 Silica Sand
			26								
			27								
			28								
SILTY SAND: fine to very fine sand, some clay lenses and thin layers of partially cemented sandstone, gray and dark gray with light reddish brown, very moist to saturated	SM		29								
- dark gray and reddish brown at 29', saturated			30								
- trace clay, light brown at 30'			31								
			32			24	5	24	NP		
			33								
			34								
CLAYEY SAND: very fine sand, dark gray, very moist to saturated	SC		35								
			36								
			37								
			38								PVC Bottom Cap

NOTES: This log should not be used separately from the original report. Not all USCS descriptions were laboratory verified.



# Monitor Well

Monitor Well No.: AD-32



**PROJECT INFORMATION**


PROJECT: Pirbey Power Plant  
 PROJECT NO.: 1-04-1021  
 LOGGED BY: Jeffrey D. Sammons, P.G.  
 SUPERVISING PG: Jeffrey D. Sammons, P.G.  
 COMPLETION: 12/11/2018  
 DEVELOPMENT: 12/18/2018  
 SITE LOCATION: 2400 FM 3281, Hallsville, Texas  
 WELL OWNER: AEP

**DRILLING INFORMATION**

DRILLER: Buford Collier  
 DRILLER'S LICENSE NO.: 60889  
 RIG TYPE: Geoprobe 2230DT  
 METHOD OF DRILLING: Hollow Stem Auger  
 SAMPLING METHODS: Split Core  
 SURFACE ELEVATION: 388.18 (Top of Casing)  
 HOLE DIAMETER: 8.58"  
 LATITUDE 32 27' 55.20" LONGITUDE 94 29' 11.86"

Water Level Upon Installation    
  Water Level at Time of Drilling    
  Geotechnical Lab Sample    
 TBPB No. 50027

DESCRIPTION	USCS	SOIL SYMBOLS	DEPTH	WATER LEVEL	SAMPLE	% MOISTURE	% FINES	LL	PL	PI	WELL CONSTRUCTION
			0								Locking Well Casing Cover Locking Well Cap Protective Well Casing Concrete Pad Ground Surface Cement
<b>CLAYEY SAND:</b> very fine to fine sand, dark reddish brown, moist - interbeds of sand and clay, yellowish brown and light gray at 1' - reddish brown and light gray at 2' - light gray and yellowish brown at 4' - grayish brown and light gray at 6' - grayish brown, light gray, and reddish brown at 7'	SC		1 2 3 4 5 6 7	M	25	46	35	22	13		Bentonite
<b>SANDY LEAN CLAY:</b> some gravel seams and thin interbeds of cemented sand, light yellowish brown and light gray, moist to saturated within gravel seams - some iron ore gravel at 16', very moist to saturated	CL		13 14 15 16 17	M	28	54	37	22	15		2" Sch. 40 PVC Riser
<b>SILTY SAND:</b> very fine to fine sand, trace clay, brownish gray and dark brownish gray, saturated - reddish brown and brown at 20'	SM		18 19 20								
<b>SANDY LEAN CLAY:</b> gray and dark gray, very moist	CL		21 22 23 24		26	61	37	24	13		20/40 Silica Sand
<b>CLAYEY SAND:</b> fine to very fine sand, gray and dark gray, very moist to saturated	SC		25 26 27 28 29 30		28	47	41	22	19		0.010" Slotted Sch. 40 PVC Well Screen
<b>SANDY LEAN CLAY:</b> gray and dark gray, very moist	CL		31 32 33		25	59	35	21	14		PVC Bottom Cap



**ETTL  
ENGINEERS &  
CONSULTANTS**

MAIN OFFICE  
1717 East Erwin  
Tyler, Texas 75702  
(936) 282-4421


**LOG OF BORING E-1**

PROJECT: Pitkey Power Plant  
Halleville, Texas

PROJECT NO.: G3241-095


BORING TYPE: Flight Auger

DATE: 10/20/09  
SURFACE ELEVATION:



MATERIAL DESCRIPTION	
CL	RANDY LEAN CLAY (CL) stiff; yellow and gray -very stiff; yellow and white
CH	RANDY FAT CLAY (CH) very stiff; yellow and tan; with ferric joints
SM	SILTY SAND (SM) yellow
CH	FAT CLAY WITH SAND (CH) hard; brown and yellow; with ferric joints; with iron oxide cemented sandstone -very stiff; brownish yellow; with ferric joints
SC	CLAYEY SAND (SC) medium dense; gray
CL	LEAN CLAY (CL) hard; gray

FIELD STRENGTH DATA	BLOW COUNT				DRY DENSITY (pcf)	COMPRESSION STRENGTH (q <sub>s</sub> )	FAILURE STRAIN (%)	COMPRESSION PRESSURE (psf)	Natural Moisture Content and Atterberg Limits			MOISTURE CONTENT (%)	ATTERBERG LIMITS (%)			OTHER TESTS PERFORMED (Page Ref. #)	
	1	2	3	4					PL	LL	PI		LI	PL	PI		
N=6	●											24	42	22	20	68	+40 Sieve=0%, +4 Sieve=0%
P=2.75	■											25	53	22	31	63	+40 Sieve=13%, +4 Sieve=1%
P=2.75	■																
SF												27				41	+40 Sieve=0%, +4 Sieve=1%
P=4.5+	■											24	62	24	36	74	+40 Sieve=10%, +4 Sieve=0%
P=3.75	■																
N=25	●																
N=43	●																



Water Level:  No  Measured  Fictitious   
 Water Characteristics: Seepage @ 10' while drilling.

Key to Abbreviations:  
 N - SPT Data (Blows/F)  
 P - Point Penetration (psf)  
 T - Torque (ft)  
 L - Lab Test Name (Ref.)

Notes:



**ETL  
ENGINEERS &  
CONSULTANTS**

MAIN OFFICE  
1717 East Erwin  
Tyler, Texas 75702  
(800) 890-4421

**LOG OF BORING E-2**


PROJECT: Pirkey Power Plant  
Hallsville, Texas

PROJECT NO.: G3241-095

BORING TYPE: Flight Auger

DATE: 10/20/09

SURFACE ELEVATION



**MATERIAL DESCRIPTION**

**LEAN CLAY (CL)** hard; gray and red; with gravel  
-very stiff; tan and red

**SANDY FAT CLAY (CH)** stiff; red and tan  
-red and gray

**LEAN CLAY (CL)** stiff; red and gray  
-very stiff; red, gray, and tan

**SILTY SAND (SM)** very dense; gray, red, and tan; saturated

**CLAYEY SAND (SC)** medium dense; greenish gray

Bottom of Boring @ 30'

FIELD STRENGTH DATA	BLOW COUNT				DRY DENSITY (pcf)	COMPRESSIONIVE STRENGTH (psf)	FAILURE STRAIN (%)	COMPACTION PRESSURE (psf)	Natural Moisture Content and Atterberg Limits			
	20	30	40	50					Plastic Limit	Moisture Content	Liquid Limit	
P=4.5+												
P=2.5												
P=1.75												
P=2.0												
P=2.25												
P=1.5												
N=74												
N=16												

MOISTURE CONTENT (%)			ATTERBERG LIMITS (%)			MINUS #200 SIEVE (%)	OTHER TESTS PERFORMED (Page Ref. #)
LL	PL	PI	LL	PL	PI		
18	47	17	30	29	14%	+40 Sieve-14%	
21	50	18	34	28	14%	+40 Sieve-8%	
23	57	18	38	71	1%	+40 Sieve-6%	

Water Level:  Measured  Permitted   
 Water Observations: Seepage @ 5' while drilling.

Key to Abbreviations:  
 M - SPT Data (Blows/Ft)  
 P - Pocket Penetrometer (psf)  
 T - Torque (ft)  
 L - Lab Vane Shear (psf)

Notes:

832964

LOG OF BORING

PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: S-4  
LOCATION: Hallsville, TX

Date: 9-14-83

Type:

Ground Elevation: 347.3

Depth,  
Feet

Symbol

Sample

Legend:

■ Sample

X Penetration

▼ Water

Description of Stratum

Red and grey sandy silty clay

Red and grey sandy silty clay

Red and grey sandy silty clay w/iron ore

Bottom of boring at 6 feet.

No water encountered.

5

10

15

20

25

30

35

40

45

50

832964

### LOG OF BORING

PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: S-5  
LOCATION: Hallsville, TX

Date: 9-14-83

Type:

Ground Elevation: 347.1

Depth, Feet	Symbol	Sample	Legend:		
			■ Sample	X Penetration	▼ Water

Description of Stratum

0-1			Red and grey silty sandy clay w/iron ore
1-2			Red and grey silty sandy clay w/iron ore
2-3			Red and grey silty sandy clay w/iron ore
3-4			Red and grey silty sandy clay w/iron ore
4-5			Red and grey silty sandy clay 7-13-15 28 B/F

Bottom of boring at 6 feet.

No water encountered.

10

15

20

25

30

35

40

45

50

832964

### LOG OF BORING

PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: S-6  
LOCATION: Hallsville, TX

Date: 9-14-83

Type:

Ground Elevation: 353.6

Depth,  
Feet

Symbol

Sample

Legend:

■ Sample

X Penetration

▼ Water

Description of Stratum

0-1	[Symbol]	Red and grey silty clay lenses w/iron ore
1-2		Red and grey silty sandy clay w/iron ore
2-5		Red and grey silty clay

Bottom of boring at 6 feet.  
No water encountered.

5

10

15

20

25

30

35

40

45

50

832964

### LOG OF BORING

PROJECT: Waste Water Ponds  
CLIENT: SWEPCO

BORING NO.: S-7  
LOCATION: Hallsville, TX

Date: 9-14-83

Type:

Ground Elevation: 346.9

Depth, Feet	Symbol	Sample	Legend:
			<span style="display: inline-block; width: 10px; height: 10px; background-color: black; margin-right: 5px;"></span> Sample <span style="margin-left: 100px;">X Penetration</span> <span style="margin-left: 100px;">▼ Water</span>

Description of Stratum


			Red, brown and grey silty clay
5	/	/	Red, brown and grey silty clay w/silt lenses and iron ore
5	/	/	Red, brown and grey silty sandy clay


10			Bottom of boring at 6 feet.  No water encountered.
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			



**Appendix B**

**Photographic Log**

<b>Project Name:</b> AEP – Pirkey Power Plant		<b>Location:</b> Hallsville, Harrison County, Texas	<b>Project No.</b> OH015976.0001
<b>Photo No.</b> 1	<b>Date:</b> 8/19/2015		
<b>Direction Photo Taken:</b> South			
<b>Description:</b> P8190374 Vegetative strip adjacent to East Ash Pond. Under new rule this potential wetland is likely non-jurisdictional.			

<b>Project Name:</b> AEP – Pirkey Power Plant		<b>Location:</b> Hallsville, Harrison County, Texas	<b>Project No.</b> OH015976.0001
<b>Photo No.</b> 2	<b>Date:</b> 8/19/2015		
<b>Direction Photo Taken:</b>			
<b>Description:</b> P8190372 AD- 4 Ground water monitoring well. East Bottom Ash Pond embankment in background.			

**Project Name:**  
 AEP – Pirkey Power Plant

**Location:**  
 Hallsville, Harrison County, Texas

**Project No.**  
 OH015976.0001

**Photo No.**  
**3**
**Date:**  
 8/19/2015

**Direction Photo Taken:**  
 South

**Description:**  
 P8190378  
 View across East and  
 West Botton Ash Pond.

**Project Name:**  
 AEP – Pirkey Power Plant

**Location:**  
 Hallsville, Harrison County, Texas

**Project No.**  
 OH015976.0001

**Photo No.**  
**4**
**Date:**  
 8/19/2015

**Direction Photo Taken:**  
 Southeast

**Description:**  
 P8190379  
 Road side ditch, not  
 considered a wetland,  
 due to lack of hydric  
 vegetation and  
 connectivity.


**Project Name:**  
AEP – Pirkey Power Plant

**Location:**  
Hallsville, Harrison County, Texas

**Project No.**  
OH015976.0001

**Photo No.**  
5

**Date:**  
8/19/2015

**Direction Photo Taken:**  
North

**Description:**  
P8190380  
AD-18 Ground water monitoring well.



**Project Name:**  
AEP – Pirkey Power Plant

**Location:**  
Hallsville, Harrison County, Texas

**Project No.**  
OH015976.0001

**Photo No.**  
6

**Date:**  
8/19/2015

**Direction Photo Taken:**  
North

**Description:**  
P8190381  
AD-18 Ground water monitoring well.

