

Pirkey Plant

Notice for Initiating an Assessment of Corrective Measures

CCR Unit – East Bottom Ash Pond

As required by 40 CFR 257.95(g)(5), this is a notification that an Assessment of Corrective Measures was initiated on March 26, 2019 for Pirkey Plant's East Bottom Ash Pond due to the statistically significant level detected above the established groundwater protection standard for lithium. This notification is being placed in the plant's operating record, as required by 40 CFR 257.105(h)(9).