



An **AEP** Company

BOUNDLESS ENERGY™

## Pirkey Plant

### Notice of Statistically Significant Level (SSL) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – West Bottom Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on January 3, 2020 cobalt was detected at an SSL above the GWPS. This notification is being placed in the plant's operating record as required by 40 CFR 257.105(h)(8).

BOUNDLESS ENERGY™