



An **AEP** Company

BOUNDLESS ENERGY™

Welsh Power Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

CCR Unit – Primary Bottom Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on September 1, 2020 it was certified that lithium was detected at a SSL above the GWPS. This notification is being placed in the plant's operating record, as required by 40 CFR 257.105(h)(8).

BOUNDLESS ENERGY™