

March 9, 2023

Ms. Jill Parker-Witt, P.E.
American Electric Power
502 North Allen Avenue
Shreveport, LA 71101

Re: Alternate Source Demonstration for Fluoride and Lithium Exceedance –Bottom Ash Pond
Public Service Company of Oklahoma (PSO) – Northeastern Power Station (NPS)
Bottom Ash Pond (BAP), Rogers County
Solid Waste Permit No. None

Dear Ms. Parker-Witt:

On July 15, 2021, the Oklahoma Department of Environmental Quality (DEQ) approved the revised alternate source demonstration (ASD) for lithium and fluoride detected in monitoring well SP-10 for the Bottom Ash Pond (BAP). On January 10, 2023, DEQ received from NPS an Alternate Source Demonstration (ASD) for barium at SP-10.

During the first semi-annual 2022 assessment monitoring event for the BAP, potential statistically significant levels (SSLs) were identified for lithium, fluoride, and barium at SP-10. Barium (7.59 mg/L) in SP-10 had a statistical exceedance of the groundwater protection standard (GWPS) of 2.60 mg/L.

A Mann-Kendall statistical analysis of the time series plot determined that concentrations at SP-10 display a statistically significant increasing trend. However, a Schoeller diagram showing select events where major cations and anions were sampled, the holistic geochemistry at SP-10 does not change over time as would be expected if a release occurred from the BAP. Moving forward, samples from SP-10 will be collected and analyzed for the full suite of major ion chemistry. Concentrations of barium in sediment and porewater collected from the BAP were roughly an order of magnitude lower than barium concentrations collected from monitoring well SP-10.

The release of lithium is attributed to the clay minerals in the shale lens located at 46 ft below ground surface in the screened interval of SP-10. Analytical results suggest that naturally occurring barium and fluoride are also associated with the shale lenses and are contributing to barium and fluoride concentrations at SP-10. DEQ suggests that a split sample of water from SP-10 be filtered prior to acidification and analysis to obtain the dissolved concentrations of Appendix B parameters for comparison to the total concentrations. If the dissolved (filtered) concentrations are much less than the totals, then it would provide additional supporting evidence that the high lithium, barium and fluoride concentrations are from entrained solids in the water sample sourced by the shale lens and not from a BAP release.

Ms. Jill Parker-Witt, P.E.

American Electric Power


March 9, 2023

Page 2 of 2

If lithium, fluoride, and barium continue to exceed their relative GWPS at SP-10 in the future and conditions have not changed, NPS may refer to the October 29, 2019 ASD approval for lithium, the June 4, 2021 ASD approval for fluoride, and this ASD approval for barium and continue assessment monitoring for the BAP in accordance with Oklahoma Administrative Code 252:517-9-6(g)(3)(B).

The ASD for barium is approved. If you have any questions, please contact Kaylee Daneshmand at (405) 702-5196 or Kaylee.daneshmand@deq.ok.gov.

Sincerely,



Hillary Young, P.E.

Chief Engineer

Land Protection Division

HY/kd



American Electric Power
502 North Allen Avenue
Shreveport, LA 71101
AEP.com

January 5, 2023

Via electronic mail

Ms. Hillary Young
Oklahoma Department of Environmental Quality (ODEQ)
707 North Robinson, P.O. Box 1677
Oklahoma City, OK 73101-1677

Re: Alternate Source Demonstration (ASD)
Bottom Ash Pond (BAP)
Public Service Company of Oklahoma (PSO) - Northeastern Power Station (NPS)
Roger County
Solid Waste Permit No. Pending

Dear Ms. Young,

AEP/PSO received ODEQ's correspondence dated June 4, 2021, in which ODEQ accepted the ASD for the lithium and fluoride detected in SP-10 during the October 28, 2020, sampling event. ODEQ indicated that if lithium and fluoride continue to exceed the groundwater protection standards (GWPS) in the future and conditions have not changed, NPS may refer to the October 24, 2019, ASD approval for lithium and June 4, 2021, ASD approval for fluoride and continue assessment monitoring for the BAP in accordance with OAC 252:517-9-6(g)(3)(B).

On October 7, 2022, the statistical evaluation of the first semi-annual 2022 assessment monitoring event (June 14, 2022) for the BAP was certified and in that statistical evaluation report, potential SSLs were identified for lithium, fluoride, and barium at SP-10.

The statistical findings are summarized as follows:

The Lower Confidence Level (LCL) for lithium (0.24 mg/L) exceeded the GWPS (a calculated Upper Tolerance Limit (UTL)) of 0.14 mg/L at SP-10. The actual detected lithium concentration in SP-10 was 0.289 mg/l.

The LCL for fluoride (5.17 mg/L) exceeded the GWPS (UTL of 4.39 mg/L) was exceeded as at SP-10. The actual detected fluoride concentration in SP-10 was 6.3 mg/L.

The LCL for barium (3.46 mg/L) exceeded the GWPS (UTL of 2.60 mg/L) was exceeded as at SP-10. The actual detected barium concentration in SP-10 was 7.59 mg/L.

Attached are the alternative source demonstrations for your review outlining the lines of evidence that these exceedances are the result of natural variations occurring in the groundwater at SP-10 and that the conditions at the BAP have not changed.

Please do not hesitate to contact me if you have any questions or would like to discuss. I can be reached by email at: jcparker-witt@aep.com or by phone at: (318) 673-3816.

Sincerely,



Jill Parker-Witt, P.E.

AEP, Engineer Principal

Attachments

Memorandum

Date: January 4, 2023

To: Jill Parker-Witt, American Electric Power (AEP)

From: Beth Gross, Ph.D., P.E. (OK) and Allison Kreinberg, Geosyntec

Subject: Alternative Source Demonstration Update
Northeastern Power Station Bottom Ash Pond
Oologah, Rogers County, Oklahoma

The Bottom Ash Pond (BAP) is a regulated coal combustion residual (CCR) management unit at the Northeastern Power Station (NPS) in Oologah, Oklahoma. A semiannual assessment monitoring event was completed at the BAP on June 14, 2022 in accordance with the assessment monitoring requirements of Oklahoma Administrative Code OAC 252:517-9-6. Analysis of the June 2022 data identified statistically significant levels (SSLs) above the groundwater protection standards (GWPSs) for lithium, fluoride, and barium at SP-10 (Attachment B). The following SSLs were identified at the Northeastern BAP:

- The lower confidence limit (LCL) for lithium exceeded the GWPS of 0.140 milligrams per liter (mg/L) at SP-10 (0.240 mg/L).
- The LCL for fluoride exceeded the GWPS of 4.39 mg/L at SP-10 (5.17 mg/L).
- The LCL for barium exceeded the GWPS of 2.60 (mg/L) at SP-10 (3.66 mg/L).

As described in previous ASDs (Geosyntec, 2019; Geosyntec, 2021a,b,c; Geosyntec, 2022), lower concentrations of lithium, fluoride, and barium in the BAP water (including pore water) and BAP sediments than those observed at SP-10 suggest that the BAP is not the source of these exceedances. Key analytical results for samples collected from the BAP and from SP-10 are provided in **Table 1**. Instead, the release of lithium from the clay minerals in the shale lens located at 46 ft below ground surface in the screened interval of SP-10 is the likely source of lithium in groundwater at that location. Analytical results suggest that naturally occurring barium and fluoride are also associated with the shale lenses and are contributing to aqueous barium and fluoride concentrations at SP-10.

Oklahoma Department Environmental Quality (DEQ) previously noted in a letter to the NPS dated June 4, 2021 that “If lithium and fluoride continue to exceed their relative GWPS in the future and conditions have not changed, NPS may refer to the October 29, 2019 ASD approval for lithium and this (*June 4, 2021*) approval for fluoride and continue assessment monitoring for the BAP in accordance with OAC 252:517-6(g)(3)(B)” (DEQ, 2021). DEQ provided a similar letter to the NPS dated September 20, 2022 that indicated that “The (*July 14, 2022*) ASD is applicable for Ba exceedance in SP-10 of the GWPS if conditions do not change. AEP may refer to the ASD approval for Ba and continue assessment monitoring for the BAP in accordance with OAC 252:517-9-6(g)(3)(B)” (DEQ, 2022). This ASD update presents an evaluation of the BAP for changing conditions that may affect previously approved ASDs for lithium, fluoride, and barium exceedances at SP-10.

The sample collected from the June 2022 monitoring event at SP-10 contained a lithium concentration of 0.289 mg/L, fluoride concentration of 6.30 mg/L, and barium concentration of 7.59 mg/L. The lithium and fluoride concentrations are consistent with previous results collected during the assessment monitoring period and continue to show no statistically significant positive trends (**Figure 1** and **Figure 2**, respectively). This is an indication that conditions have not changed substantially since the preceding ASD was submitted (Geosyntec, 2022) and the arguments presented in the previous ASDs are still valid. Thus, the lithium and fluoride concentrations at SP-10 during the June 2022 assessment monitoring event are not attributed to a release from the BAP.

A time series plot of the barium concentrations at SP-10 and a Mann-Kendall statistical analysis of the reported barium results over time is shown in **Figure 3**. The analysis determined that barium concentrations at SP-10 display a statistically significant increasing trend. However, based on a Schoeller diagram showing select events where major cations and anions were sampled (**Figure 4**)¹, the holistic geochemistry at monitoring well SP-10 does not change over time in a manner indicative of a release from the BAP. The June 2022 sample is displayed on the plot as the bold black line. **Figure 4** demonstrates that the geochemistry of SP-10 has remained consistent over the past several years, indicating conditions at SP-10 have not changed. Moving forward, samples from SP-10 will be collected and analyzed for the full suite of major ion chemistry. This will facilitate the preparation of more robust data visuals such as Piper plots and Stiff diagrams to better support the finding that groundwater at SP-10 is geochemically stable in future ASD memoranda.

¹ Piper diagrams were previously used to visualize the geochemical composition of SP-10 over time (Geosyntec, 2019; Geosyntec, 2021a; Geosyntec, 2022). Alkalinity data was unavailable for the June 2022 sampling event, precluding the use of a Piper diagram to show the results of the most recent sampling event.

As mentioned in the previous ASD completed for barium at SP-10 (Geosyntec, 2022), concentrations of barium in sediment and porewater collected from the BAP were roughly an order of magnitude lower than barium concentrations collected from monitoring well SP-10 (**Table 1**). An additional porewater sample was collected from the BAP on August 25, 2022. This porewater sample contained a large component of solids and was unable to be analyzed as an aqueous sample, although the solid component of this sample was separated and submitted for synthetic precipitation leaching procedure (SPLP) to evaluate the leachable component of barium in the solid phase. Leachable barium was reported as 0.22 mg/L from this sample (Attachment C), which is more than an order of magnitude less than the most recent concentration detected in SP-10 groundwater (7.59 mg/L) or the GWPS (2.60 mg/L). This result is consistent with the previously reported concentration of leachable barium in the BAP solids of 0.352 mg/L. Based on this result and previous samples collected from the BAP, the BAP does not appear to be the source for elevated barium concentrations in SP-10 groundwater.

The information above, as well as the information presented in previous ASDs (Geosyntec, 2019; Geosyntec, 2021a,b,c; Geosyntec, 2022), continue to support the position that barium, fluoride, and lithium concentrations are a result of natural variation in the underlying lithology, including the presence of shale lenses containing barium, fluoride, and lithium within the screened interval at SP-10. Therefore, no further action is warranted, and the BAP will remain in the assessment monitoring program. Certification of this ASD memorandum by a qualified professional engineer is in Attachment A.

Geosyntec Consultants, 2019. Alternative Source Demonstration. Bottom Ash Pond – Northeastern Power Station, Oologah, Oklahoma. April.

Geosyntec Consultants, 2021a. Alternative Source Demonstration. Bottom Ash Pond – Northeastern Power Station, Oologah, Oklahoma. January.

Geosyntec Consultants, 2021b. Alternative Source Demonstration. Bottom Ash Pond – Northeastern Power Station, Oologah, Oklahoma. May.

Geosyntec Consultants, 2021c. Alternative Source Demonstration. Bottom Ash Pond – Northeastern Power Station, Oologah, Oklahoma. October.

Geosyntec Consultants, 2022. Alternative Source Demonstration. Bottom Ash Pond – Northeastern Power Station, Oologah, Oklahoma. July.


Jill Parker-Witt
January 4, 2023
Page 4

Oklahoma Department of Environmental Quality. 2021. Alternate Source Demonstration for Fluoride and Lithium Exceedance – Bottom Ash Pond, Public Service Company of Oklahoma Northeastern Power Station, Rogers County. June 4.

Oklahoma Department of Environmental Quality, 2022. Alternative Source Demonstration for Barium, Fluoride, and Lithium Exceedances – Bottom Ash Pond, Public Service Company of Oklahoma - Northeastern Power Station, Rogers County. September 20.


FIGURES

Time Series



Constituent: Lithium Analysis Run 12/29/2022 9:00 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on

Sen's Slope Estimator



Constituent: Lithium Analysis Run 12/29/2022 9:28 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on

Lithium Time Series and Trend Test – SP-10


Northeastern Bottom Ash Pond

Geosyntec[®]
consultants




Figure
1

Time Series



Constituent: Fluoride Analysis Run 12/29/2022 9:00 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on

Sen's Slope Estimator



Constituent: Fluoride Analysis Run 12/29/2022 9:28 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on

Fluoride Time Series and Trend Test – SP-10


Northeastern Bottom Ash Pond

Geosyntec[®]
consultants

AMERICAN
ELECTRIC
POWER


Figure
2

Time Series



Constituent: Barium Analysis Run 12/29/2022 9:00 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on

Sen's Slope Estimator



Constituent: Barium Analysis Run 12/29/2022 9:28 AM
Oologah Client: AEP Data: AEP Concentration Sanitas Format 2018 on


Barium Time Series and Trend Test – SP-10

Northeastern Bottom Ash Pond

Geosyntec 
consultants

AMERICAN
ELECTRIC
POWER

Figure
3



internal info: path: dated revised author

Notes: Groundwater results from monitoring well SP-10 are displayed on the plot. Concentrations of all parameters are displayed in units of milliequivalents per liter (meq/L). The most recent sample, collected in June 2022, is displayed as the bold black line.

SP-10 Schoeller Diagram Northeastern Bottom Ash Pond

Geosyntec consultants

**AMERICAN
ELECTRIC
POWER**

Figure
4

Columbus, Ohio

January 2023

TABLES

Table 1: Summary of Key Analytical Data
Bottom Ash Pond - Northeastern Power Station

Sample	Sample Date	Lithium Concentration (mg/L)	Fluoride Concentration (mg/L)	Barium Concentration (mg/L)
SPLP Leachate of Bottom Ash	7/10/2019	0.001	0.458	0.352
	8/25/2022	< 0.5	NA	0.22
BAP Surface Water	2/5/2019	0.00874	0.37	0.315
BAP Pore Water	7/10/2019	0.003	< 0.83	0.083
SP-10 June 2022 Result	6/14/2022	0.289	6.3	7.59

Notes:

NA - not analyzed

mg/L - milligram per liter

BAP - Bottom Ash Pond

SPLP - Synthetic precipitation leaching procedure

Non-detect results are shown as less than the reporting limit.

ATTACHMENT A
Certification by Qualified Professional Engineer

CERTIFICATION BY A QUALIFIED PROFESSIONAL ENGINEER

I certify that the above described alternative source demonstration is appropriate for evaluating the groundwater monitoring data for the Bottom Ash Pond CCR management area at the Northeastern Power Station and that the requirements of OAC 252:517-9-6(g)(3)(B) have been met.

Beth Ann Gross

Printed Name of Licensed Professional Engineer

Beth Ann Gross

Signature



Geosyntec Consultants
2039 Centre Pointe Boulevard, Suite 103
Tallahassee, Florida 32308

Oklahoma Firm Certificate of
Authorization No. 1996
Exp. 6/30/2024

18167
License Number

Oklahoma
Licensing State

January 5, 2023
Date

* * * * *

ATTACHMENT B
Assessment Statistics Report
2022 First Semiannual Event

**STATISTICAL ANALYSIS SUMMARY
BOTTOM ASH POND
Northeastern Power Station
Oologah, Oklahoma**

Submitted to



1 Riverside Plaza
Columbus, Ohio 43215-2372

Submitted by

Geosyntec ▶
consultants

engineers | scientists | innovators

500 West Wilson Bridge Road
Suite 250
Worthington, Ohio 43085

October 7, 2022

CHA8500B

TABLE OF CONTENTS

SECTION 1 Executive Summary	1
SECTION 2 Bottom Ash Pond Evaluation.....	2-1
2.1 Data Validation & QA/QC	2-1
2.2 Statistical Analysis.....	2-1
2.2.1 Evaluation of Potential Appendix B SSLs	2-1
2.2.2 Evaluation of Potential Appendix A SSIs	2-2
2.3 Conclusions.....	2-3
SECTION 3 References	3-1

LIST OF TABLES

Table 1	Groundwater Data Summary
Table 2	Appendix B Groundwater Protection Standards
Table 3	Appendix A Data Summary

LIST OF ATTACHMENTS

Attachment A	Certification by Qualified Professional Engineer
Attachment B	Statistical Analysis Output

LIST OF ACRONYMS AND ABBREVIATIONS

AEP	American Electric Power
ASD	Alternative Source Demonstration
BAP	Bottom Ash Pond
CCR	Coal Combustion Residuals
CCV	Continuing Calibration Verification
GWPS	Groundwater Protection Standard
LCL	Lower Confidence Limit
LFB	Laboratory Fortified Blanks
LPL	Lower Prediction Limit
LRB	Laboratory Reagent Blanks
MCL	Maximum Contaminant Level
NELAP	National Environmental Laboratory Accreditation Program
NPS	Northeastern Power Station
ODEQ	Oklahoma Department of Environmental Quality
OAC	Oklahoma Administrative Code
QA	Quality Assurance
QC	Quality Control
SSI	Statistically Significant Increase
SSL	Statistically Significant Level
SU	Standard Units
TDS	Total Dissolved Solids
UPL	Upper Prediction Limit
UTL	Upper Tolerance Limit

SECTION 1

EXECUTIVE SUMMARY

In accordance with the Oklahoma Department of Environmental Quality (ODEQ) and Oklahoma administrative code (OAC) regarding the disposal of coal combustion residuals (CCR) in landfills and surface impoundments (OAC 252:517), groundwater monitoring has been conducted at the Bottom Ash Pond (BAP), an existing CCR unit at the Northeastern Power Station (NPS) located in Oologah, Oklahoma. Recent groundwater monitoring results were compared to site-specific groundwater protection standards (GWPSSs) to identify potential exceedances.

Based on detection monitoring conducted in 2017 and 2018, statistically significant increases (SSIs) over background were concluded for boron, chloride, fluoride, total dissolved solids (TDS), and sulfate at the BAP. Also, pH values below the lower prediction limit (LPL) resulted in SSIs below background as well. GWPSSs were set in accordance with OAC 252:517-9-6(h) and a statistical evaluation of the assessment monitoring data was conducted. An assessment monitoring event was conducted at the BAP in December 2021, in accordance with OAC 252:517-9-6(d). During the December 2021 assessment monitoring event, statistically significant levels (SSLs) were observed for barium, fluoride, and lithium (Geosyntec, 2022a). An alternative source demonstration (ASD) was successfully completed (Geosyntec, 2022b); thus the unit remained in assessment monitoring. One assessment monitoring event was conducted at the BAP in June 2022, in accordance with OAC 252:517-9-6(d). Results of this event are documented in this report.

Prior to conducting the statistical analyses, the groundwater data underwent several validation tests, including those for completeness, sample tracking accuracy, transcription errors, and consistent use of measurement units. No data quality issues were identified which would impact the usability of the data.

The monitoring data were submitted to Groundwater Stats Consulting, LLC for statistical analysis. Confidence intervals were calculated for Appendix B parameters at the compliance wells to assess whether SSLs for Appendix B parameters were present above previously calculated GWPSSs. SSLs were identified for barium, fluoride, and lithium. Thus, either the unit will move to an assessment of corrective measures or an ASD will be conducted to evaluate if the unit can remain in assessment monitoring. Certification of the selected statistical methods by a qualified professional engineer is documented in Attachment A. The statistical analysis and certification of the selected methods were completed within 90 days of obtaining the data.

SECTION 2

BOTTOM ASH POND EVALUATION

2.1 Data Validation & QA/QC

During the assessment monitoring program, one set of samples was collected in June 2022 for analysis from each upgradient and downgradient well to meet the requirements of OAC 252:517-9-6(d)(1). Samples from this sampling event were analyzed for both the Appendix A and Appendix B parameters. A summary of data collected during this assessment monitoring event may be found in Table 1.

Chemical analysis was completed by an analytical laboratory certified by the National Environmental Laboratory Accreditation Program (NELAP). Quality assurance and quality control (QA/QC) samples completed by the analytical laboratory included the use of laboratory reagent blanks (LRBs), continuing calibration verification (CCV) samples, and laboratory fortified blanks (LFBs).

The analytical data were imported into a Microsoft Access database, where checks were completed to assess the accuracy of sample location identification and analyte identification. Where necessary, unit conversions were applied to standardize reported units across all sampling events. Exported data files were created for use with the Sanitas™ v.9.6.33 statistics software. The export file was checked against the analytical data for transcription errors and completeness. While the TDS results were flagged for laboratory control sample results outside of the acceptance limits (Table 1), the results were similar to previous results and were retained in the dataset for statistical evaluation. Thus, no QA/QC issues were noted which would impact data usability.

2.2 Statistical Analysis

Statistical analyses for the BAP were conducted in accordance with the November 2021 *Statistical Analysis Plan* (Geosyntec, 2021) for the samples collected in June 2022. Time series plots and results for all completed statistical tests are provided in Attachment B.

The data obtained in June 2022 were screened for potential outliers. No outliers were identified for this event.

2.2.1 Evaluation of Potential Appendix B SSLs

A confidence interval was constructed for each Appendix B parameter at each compliance well. Confidence limits were generally calculated parametrically ($\alpha = 0.01$); however, non-parametric confidence limits were calculated in some cases (e.g., when the data did not appear to be normally distributed or when the non-detect frequency was too high). An SSL was concluded if the lower confidence limit (LCL) exceeded the GWPS (i.e., if the entire confidence interval exceeded the GWPS). Calculated confidence limits are shown in Attachment B. The calculated confidence

limits were compared to the GWPSs provided in Table 2. The GWPSs were established during a previous statistical analysis as either the greater value of the background concentration or the maximum contaminant level (MCL) and risk-based level specified in OAC 252:517-9-6(h) (Geosyntec, 2022).

The following SSLs were identified at the Northeastern BAP:

- The LCL for barium exceeded the GWPS of 2.60 mg/L at SP-10 (3.66 mg/L).
- The LCL for fluoride exceeded the GWPS of 4.39 mg/L at SP-10 (5.17 mg/L).
- The LCL for lithium exceeded the GWPS of 0.140 mg/L at SP-10 (0.240 mg/L).

ODEQ previously noted in a letter provided to the NPS that “If lithium and fluoride continue to exceed their relative GWPS in the future and conditions have not changed, NPS may refer to the October 29, 2019 ASD approval for lithium and June 4, 2021 approval for fluoride and continue assessment monitoring for the BAP in accordance with OAC 252:517-6(g)(3)(B)” (ODEQ, 2021). ODEQ provided a similar letter dated September 20, 2022 documenting ASD approval for a barium SSL at SP-10 which is applicable in the future if conditions do not change (ODEQ, 2022). Thus, an ASD will be submitted to ODEQ demonstrating that conditions at the BAP remain unchanged so that the unit will continue assessment monitoring.

2.2.2 Evaluation of Potential Appendix A SSIs

While SSLs were identified, a review of the Appendix A results was also completed to assess whether concentrations of Appendix A parameters at the compliance wells exceeded background concentrations.

Data collected during the June 2022 assessment monitoring event from each compliance well were compared to previously calculated prediction limits to evaluate results above background values. The results from this event and the prediction limits are summarized in Table 3. The following exceedances of the UPLs were noted:

- Boron concentrations exceeded the interwell UPL of 0.510 mg/L at SP-10 (1.04 mg/L) and SP-11 (0.627 mg/L).
- Chloride concentrations exceeded the interwell UPL of 802 mg/L at SP-2 (844 mg/L) and SP-10 (1,810 mg/L).
- Fluoride concentrations exceeded the interwell UPL of 4.39 mg/L at SP-10 (6.3 mg/L).
- Sulfate concentrations exceeded the interwell UPL of 90.0 mg/L at SP-11 (402 mg/L).
- TDS concentrations exceeded the interwell UPL of 1,570 mg/L at SP-2 (1,720 mg/L) and SP-10 (3,600 mg/L).

While the prediction limits were calculated for a one-of-two retesting procedure, SSIs were conservatively assumed if the June 2022 sample was above the UPL or below the LPL. Based on these results, boron, chloride, fluoride, sulfate, and TDS concentrations exceeded background levels at compliance wells at the Northeastern BAP during assessment monitoring.

2.3 Conclusions

A semi-annual assessment monitoring event was conducted in June 2022 in accordance with the CCR Rule. The laboratory and field data were reviewed prior to statistical analysis, with no QA/QC issues identified that impacted data usability. A review of outliers identified no potential outliers in the June 2022 data. A confidence interval was constructed at each compliance well for each Appendix B parameter; SSLs were concluded if the entire confidence interval exceeded the GWPSSs. SSLs were identified for barium, fluoride, and lithium. Appendix A parameters were compared to prediction limits, with exceedances identified for boron, chloride, fluoride, sulfate, and TDS.

Based on this evaluation, the Northeastern BAP CCR unit will either move to an assessment of corrective measures or an ASD will be conducted to evaluate if the unit can remain in assessment monitoring.

SECTION 3

REFERENCES

Geosyntec. 2021. Statistical Analysis Plan – Northeastern Power Station. Oologah, Oklahoma. November.

Geosyntec. 2022a. Statistical Analysis Summary – Bottom Ash Pond. Northeastern Power Station. Oologah, Oklahoma. April.

Geosyntec. 2022b. Alternative Source Demonstration Report – State CCR Rule. Northeastern Power Station – Bottom Ash Pond. Oologah, Oklahoma. July.

Oklahoma Department of Environmental Quality (ODEQ). 2021. Letter Transmittal – Alternate Source Demonstration for Fluoride and Lithium Exceedance – Bottom Ash Pond. Public Service Company of Oklahoma – Northeastern Power Station. June.

ODEQ. 2022. Letter Transmittal – Alternate Source Demonstration for Barium, Fluoride, and Lithium Exceedance – Bottom Ash Pond. Public Service Company of Oklahoma – Northeastern Power Station. September.

TABLES

Table 1 - Groundwater Data Summary
Northeastern Plant - Bottom Ash Pond

Well ID	SP-1	SP-2	SP-4	SP-5R	SP-10	SP-11
Well Classification	Compliance	Background	Background	Compliance	Compliance	Compliance
Parameter	Unit	6/14/2022	6/14/2022	6/14/2022	6/14/2022	6/14/2022
Antimony	µg/L	0.72	1.51	0.21	0.19	0.03 J1
Arsenic	µg/L	0.84	1.11	0.80	20.3	0.19
Barium	µg/L	161	1,070	246	2,010	7,590
Beryllium	µg/L	0.061	0.1 J1	0.04 J1	0.07 J1	2.5 U1
Boron	mg/L	0.176	0.228	0.367	0.209	1.04
Cadmium	µg/L	0.066	0.063	0.024	0.200	0.033
Calcium	mg/L	102	115	70.2	52.5	56.1
Chloride	mg/L	21.2	844	452	675	1,810
Chromium	µg/L	0.60	1.05	0.56	0.47	0.57
Cobalt	µg/L	1.14	0.791	0.159	0.699	0.216
Combined Radium	pCi/L	3.98	10.83	3.56	11.26	1.31
Fluoride	mg/L	0.78	3.08	3.25	3.09	6.3
Lead	µg/L	0.22	0.17 J1	0.10 J1	0.66	0.19 J1
Lithium	mg/L	0.00473	0.084	0.0571	0.0896	0.289
Mercury	µg/L	0.005 U1				
Molybdenum	µg/L	21.2	26.5	3.7	0.9	0.5
Selenium	µg/L	9.63	9.56	0.38 J1	0.1 J1	0.5 U1
Sulfate	mg/L	65.2	22.3	80.4	4.7	16.3
Thallium	µg/L	0.07 J1	0.07 J1	0.2 U1	0.2 U1	0.2 U1
Total Dissolved Solids	mg/L	430 L1	1,720 L1	1,160 L1	1,410 L1	3,600 L1
pH	SU	7.27	7.35	7.83	7.72	7.74
						7.34

Notes:

µg/L: micrograms per liter
 mg/L: milligrams per liter
 pCi/L: picocuries per liter
 SU: standard unit

U1: Non-detect value. For statistical analysis, parameters which were not detected were replaced with the reporting limit.

J1: Estimated value. Parameter was detected in concentrations below the reporting limit.

L1: The associated laboratory control sample (LCS) or laboratory control sample duplicate (LCSD) recovery was outside acceptance limits.
 -: Not analyzed

Table 2 - Appendix B Groundwater Protection Standards
Northeastern Plant - Bottom Ash Pond

Constituent Name	MCL	CCR Rule-Specified	Calculated UTL	GWPS
Antimony, Total (mg/L)	0.00600		0.00708	0.00708
Arsenic, Total (mg/L)	0.0100		0.0572	0.0572
Barium, Total (mg/L)	2.00		2.60	2.60
Beryllium, Total (mg/L)	0.00400		0.00212	0.00400
Cadmium, Total (mg/L)	0.00500		0.00247	0.00500
Chromium, Total (mg/L)	0.100		0.0418	0.100
Cobalt, Total (mg/L)	n/a	0.00600	0.0179	0.0179
Combined Radium, Total (pCi/L)	5.00		15.8	15.8
Fluoride, Total (mg/L)	4.00		4.39	4.39
Lead, Total (mg/L)	n/a	0.0150	0.0107	0.0150
Lithium, Total (mg/L)	n/a	0.0400	0.140	0.140
Mercury, Total (mg/L)	0.00200		0.0000300	0.00200
Molybdenum, Total (mg/L)	n/a	0.100	0.0100	0.100
Selenium, Total (mg/L)	0.0500		0.00499	0.0500
Thallium, Total (mg/L)	0.00200		0.00162	0.00200

Notes:

MCL = Maximum Contaminant Level

CCR = Coal Combustion Residual

GWPS = Groundwater Protection Standard

Calculated UTL (Upper Tolerance Limit) represents site-specific background values.
Grey cells indicate the GWPS is based on the calculated UTL, which is higher than the MCL or CCR Rule-specified value.

Table 3 - Appendix A Data Summary
Northeastern Plant - Bottom Ash Pond

Analyte	Unit	Description	SP-1	SP-2	SP-10	SP-11
Boron	mg/L	Interwell Background Value (UPL)	6/14/2022	6/14/2022	6/14/2022	6/14/2022
		Analytical Result	0.176	0.228	1.04	0.627
Calcium	mg/L	Intrawell Background Value (UPL)	144	176	227	1,460
		Analytical Result	102	115	56.1	113
Chloride	mg/L	Interwell Background Value (UPL)	802			
		Analytical Result	21.2	844	1,810	60.0
Fluoride	mg/L	Interwell Background Value (UPL)		4.39		
		Analytical Result	0.78	3.08	6.3	1.10
pH	SU	Interwell Background Value (UPL)		9.0		
		Interwell Background Value (LPL)		6.9		
Sulfate	mg/L	Interwell Background Value (UPL)	7.3	7.4	7.7	7.3
		Analytical Result		90.0		
Total Dissolved Solids	mg/L	Interwell Background Value (UPL)	65.2	22.3	16.3	402
		Analytical Result		1,570		

Notes:

UPL: Upper prediction limit

LPL: Lower prediction limit

Bold values exceed the background value.

Background values are shaded gray.

ATTACHMENT A

Certification by Qualified Professional Engineer

Certification by Qualified Professional Engineer

I certify that the selected and above described statistical method is appropriate for evaluating the groundwater monitoring data for the Northeastern Bottom Ash Pond CCR management area and that the requirements of OAC 252:517-9-4(g) have been met.

DAVID ANTHONY MILLER

Printed Name of Licensed Professional Engineer

David Anthony Miller

Signature

26057

License Number

OKLAHOMA

Licensing State

10-07-22


Date



ATTACHMENT B

Statistical Analysis Output

GROUNDWATER STATS
CONSULTING



August 31, 2022

Geosyntec Consultants
Attn: Ms. Allison Kreinberg
941 Chatham Lane, #103
Columbus, OH 43221

Re: Northeastern BAP (Bottom Ash Pond)
Assessment Monitoring Statistics –June 2022

Dear Ms. Kreinberg,

Groundwater Stats Consulting (GSC), formerly the statistical consulting division of Sanitas Technologies, is pleased to provide the June 2022 assessment monitoring analysis of groundwater data for American Electric Power Inc.'s Northeastern BAP. The analysis complies with the Oklahoma Administrative Code (OAC) as well as with the United States Environmental Protection Agency (USEPA) Unified Guidance (2009).

Sampling began at the site for the OAC program in 2017. The monitoring well network, as provided by Geosyntec Consultants, consists of the following:

- **Upgradient wells:** SP-4 and SP-5R
- **Downgradient wells:** SP-1, SP2, SP-10, and SP-11

Data were sent electronically, and the statistical analysis was conducted according to the Statistical Analysis Plan and screening evaluation prepared by GSC and approved by Dr. Kirk Cameron, PhD Statistician with MacStat Consulting, primary author of the USEPA Unified Guidance, and Senior Advisor to GSC. The analysis was reviewed by Andrew Collins, Project Manager of GSC.

The OAC program consists of the following constituents listed below. The terms "constituent" and "parameter" are interchangeable.

- **Appendix B** (Assessment Monitoring) – antimony, arsenic, barium, beryllium, cadmium, chromium, cobalt, combined radium 226 + 228, fluoride, lead, lithium, mercury, molybdenum, selenium, and thallium

For all constituents, a substitution of the most recent reporting limit is used for non-detect data. Time series and box plots are provided for all wells for the parameters listed above (Figures A & B). The time series plots display concentrations over time for each well while the box plots provide visual representation of variation within a given well and across all wells.

Summary of Background Screening

Outlier Screening

Data were re-evaluated for outliers using Tukey's outlier test during the background update performed in April 2022, and a summary of those findings was submitted with that report. No additional values were flagged during that screening; however, elevated concentrations earlier in the record for barium at well SP-10 were deselected to construct confidence intervals that are representative of present-day groundwater quality conditions for barium at this well. Values identified as outliers are flagged in the database with "o" and are deselected prior to construction of statistical limits. A list of all previously flagged outliers follows this letter (Figure C). Additionally, flagged data are displayed in a lighter font and as a disconnected symbol on the time series reports, as well as in a lighter font on the accompanying data pages. A list of well/constituent pairs using a truncated portion of their records follows this report (Date Ranges Table)

Evaluation of Appendix B Parameters – June 2022

For Appendix B parameters, confidence intervals for each downgradient well/constituent were compared against corresponding Groundwater Protection Standards (GWPS). GWPS were developed as described below. Downgradient well/constituent pairs that have 100% non-detects do not require analysis; however, no downgradient wells had 100% non-detects, and all well/constituent pairs were eligible for confidence intervals.

Interwell Upper Tolerance Limits

Interwell upper tolerance limits were used to calculate the site-specific background limits from pooled upgradient well data during the Fall 2021 analysis using data through December 2021 for Appendix B parameters (Figure D). These limits are updated on an annual basis and will be updated again during the Fall 2022 sample event. Parametric tolerance limits are calculated, with a target of 95% confidence and 95% coverage, when data follow a normal or transformed-normal distribution. When data contained greater than 50% non-detects or did not follow a normal or transformed-normal distribution, non-parametric tolerance limits were constructed using the highest background measurement. The confidence and coverage levels for nonparametric tolerance limits are dependent upon the number of background samples.

Groundwater Protection Standards

The upper tolerance limits were compared to the Maximum Contaminant Levels (MCLs) and background limits in the Groundwater Protection Standard (GWPS) table following this letter to determine the highest limit for use as the GWPS in the Confidence Interval comparisons (Figure E).


Confidence Intervals

Confidence intervals were then constructed on downgradient wells with data through June 2022 for each of the Appendix B parameters using the highest limit of the MCL or background limit as discussed above for the GWPS (Figure F). Only when the entire confidence interval is above a GWPS is the well/constituent pair considered to exceed its respective standard. A summary of the confidence interval results follows this letter. Exceedances were found for the following well/constituent pairs:

- Barium: SP-10
- Fluoride: SP-10
- Lithium: SP-10

Thank you for the opportunity to assist you in the statistical analysis of groundwater quality for the Northeastern BAP. If you have any questions or comments, please feel free to contact us.

For Groundwater Stats Consulting,



Tristan Clark
Groundwater Analyst



Andrew Collins
Project Manager

Date Ranges

Page 1

Date: 8/8/2022 3:09 PM

Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Barium (mg/L)

SP-10 overall:5/30/2018-6/14/2022


Calcium (mg/L)

SP-11 background:10/4/2017-6/30/2020

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Time Series




Constituent: Antimony Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG


Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Time Series



Constituent: Barium Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Time Series




Constituent: Arsenic Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG


Hollow symbols indicate censored values.

Time Series



Constituent: Cadmium Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Time Series




Santus™ v.9.6.33 Santus software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Constituent: Chromium Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Santus™ v.9.6.33 Santus software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Time Series




Santus™ v.9.6.33 Santus software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Time Series



Constituent: Lead Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Time Series




Constituent: Radium 226 + 228 Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Cadmium Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Chromium Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP





Time Series




Santars™ v.9.6.33 Santars software utilized by Groundwater Stats Consulting UG
Hollow symbols indicate censored values.

Constituent Lead Analysis Run 8/30/2022 2:18 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Time Series




Time Series




Time Series




Time Series




Time Series




Time Series




Box & Whiskers Plot




Box & Whiskers Plot



Box & Whiskers Plot




Box & Whiskers Plot



Constituent: Barium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Arsenic Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Box & Whiskers Plot




Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Chromium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Chromium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Box & Whiskers Plot





Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Cobalt Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Cobalt Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP




Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Combined Radium 226 + 228 Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Santist™ v.9.6.33 Santist software utilized by Groundwater Stats Consulting UG

Constituent: Combined Radium 226 + 228 Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Box & Whiskers Plot




Box & Whiskers Plot



Constituent: Lithium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Box & Whiskers Plot



Constituent: Nitrate Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Nitrite Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Box & Whiskers Plot



Constituent: Molybdenum Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Selenium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Box & Whiskers Plot



Constituent: Selenium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Thallium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Box & Whiskers Plot



Constituent: Thallium Analysis Run 8/30/2022 2:20 PM View: Appendix IV
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Outlier Summary

Northeastern BAP Client: Geosyntec Data: Northeastern BAP Printed 8/8/2022, 3:12 PM

	SP-4 Arsenic (mg/L)	SP-4 Barium (mg/L)	SP-4 Beryllium (mg/L)	SP-4 Cadmium (mg/L)	SP-10 Chromium (mg/L)	SP-4 Chromium (mg/L)	SP-4 Cobalt (mg/L)	SP-1 Combined Radium 226 + 228 (pCi/L)	SP-11 Combined Radium 226 + 228 (pCi/L)	SP-1 Fluoride (mg/L)
3/13/2017								4 (o)		
6/27/2017							14.29 (o)			
7/13/2017				0.11 (o)						
8/4/2017	0.04498 (o)	4.59 (o)	0.00497 (o)	0.00655 (o)		0.08415 (o)	0.04069 (o)	25.367 (o)		
6/20/2019										


	SP-4 Lead (mg/L)	SP-1 Lithium (mg/L)	SP-4 Mercury (mg/L)	SP-10 Molybdenum (mg/L)	SP-4 Thallium (mg/L)
3/13/2017					
6/27/2017					
7/13/2017			0.934 (o)		
8/4/2017	0.03663 (o)		5.8E-05 (o)		<0.0002 (o)
6/20/2019		0.03 (Jo)			

Upper Tolerance Limits Summary Table

Northeastern BAP Client: Geosyntec Data: Northeastern BAP Printed 3/22/2022, 10:42 AM

<u>Constituent</u>	<u>Well</u>	<u>Upper Lim.</u>	<u>Lower Lim.</u>	<u>Date</u>	<u>Observ.</u>	<u>Sig.</u>	<u>Bg N</u>	<u>Bg Mean</u>	<u>Std. Dev.</u>	<u>%NDs</u>	<u>ND Adj.</u>	<u>Transform</u>	<u>Alpha</u>	<u>Method</u>
Antimony (mg/L)	n/a	0.007084	n/a	n/a	n/a	n/a	46	-7.866	1.398	36.96	Kaplan-Meier	ln(x)	0.05	Inter
Arsenic (mg/L)	n/a	0.05715	n/a	n/a	n/a	n/a	45	0.2106	0.08347	6.667	None	x^(1/3)	0.05	Inter
Barium (mg/L)	n/a	2.6	n/a	n/a	n/a	n/a	45	n/a	n/a	0	n/a	n/a	0.09944	NP Inter(normality)
Beryllium (mg/L)	n/a	0.00212	n/a	n/a	n/a	n/a	45	n/a	n/a	22.22	n/a	n/a	0.09944	NP Inter(normality)
Cadmium (mg/L)	n/a	0.00247	n/a	n/a	n/a	n/a	45	n/a	n/a	46.67	n/a	n/a	0.09944	NP Inter(normality)
Chromium (mg/L)	n/a	0.04182	n/a	n/a	n/a	n/a	45	n/a	n/a	15.56	n/a	n/a	0.09944	NP Inter(normality)
Cobalt (mg/L)	n/a	0.01786	n/a	n/a	n/a	n/a	45	n/a	n/a	11.11	n/a	n/a	0.09944	NP Inter(normality)
Combined Radium 226 + 228 (pCi/L)	n/a	15.84	n/a	n/a	n/a	n/a	45	n/a	n/a	0	n/a	n/a	0.09944	NP Inter(normality)
Fluoride (mg/L)	n/a	4.39	n/a	n/a	n/a	n/a	48	n/a	n/a	2.083	n/a	n/a	0.08526	NP Inter(normality)
Lead (mg/L)	n/a	0.0107	n/a	n/a	n/a	n/a	45	n/a	n/a	28.89	n/a	n/a	0.09944	NP Inter(normality)
Lithium (mg/L)	n/a	0.1404	n/a	n/a	n/a	n/a	46	0.08976	0.02426	0	None	No	0.05	Inter
Mercury (mg/L)	n/a	0.00003	n/a	n/a	n/a	n/a	45	n/a	n/a	71.11	n/a	n/a	0.09944	NP Inter(NDs)
Molybdenum (mg/L)	n/a	0.01	n/a	n/a	n/a	n/a	46	n/a	n/a	36.96	n/a	n/a	0.09447	NP Inter(normality)
Selenium (mg/L)	n/a	0.00499	n/a	n/a	n/a	n/a	46	n/a	n/a	50	n/a	n/a	0.09447	NP Inter(normality)
Thallium (mg/L)	n/a	0.00162	n/a	n/a	n/a	n/a	45	n/a	n/a	91.11	n/a	n/a	0.09944	NP Inter(NDs)


Tolerance Limit
Interwell Parametric



95% coverage. Background Data Summary (based on natural log transformation) (after Kaplan-Meier Adjustment):
Mean=7.866, Std. Dev.=1.398, n=46, 36.96% NDs. Normality test: Shapiro Wilk @alpha = 0.01, calculated = 0.9381,
critical = 0.927. Report alpha = 0.05.


Constituent: Antimony Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 22.22% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 38.63% coverage at alpha=0.5. Report alpha = 0.09944.


Tolerance Limit
Interwell Parametric



95% coverage. Background Data Summary (based on cube root transformation): Mean=0.2106, Std. Dev.=0.08347,
n=45, 6.667% NDs. Normality test: Shapiro Wilk @alpha = 0.01, calculated = 0.9293, critical = 0.926. Report alpha
= 0.05.


Constituent: Arsenic Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 22.22% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 38.63% coverage at alpha=0.5. Report alpha = 0.09944.

Tolerance Limit
Interwell Parametric




95% coverage. Background Data Summary (based on cube root transformation): Mean=0.2106, Std. Dev.=0.08347,
n=45, 6.667% NDs. Normality test: Shapiro Wilk @alpha = 0.01, calculated = 0.9293, critical = 0.926. Report alpha
= 0.05.

Constituent: Beryllium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Barium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Beryllium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 46.67% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09944.

Constituent: Cobalt Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 11.11% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09944.

Constituent: Cobalt Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09944.

Constituent: Combined Radium 226 + 228 Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 48 background values. 2.083% NDs. 90.82% coverage at alpha=0.01; 93.95% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.08526.


Constituent: Fluoride Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Tolerance Limit
Interwell Parametric



95% coverage. Background Data Summary: Mean=0.08976, Std. Dev.=0.02426, n=46. Normality test: Shapiro Wilk @alpha = 0.01, calculated = 0.9416, critical = 0.927. Report alpha = 0.05.


Tolerance Limit
Interwell Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 45 background values. 28.89% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09944.

Constituent: Lead Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Tolerance Limit
Interwell Non-parametric




Non-parametric test used in lieu of parametric tolerance limit because censored data exceeded 50%. Limit is highest of 45 background values. 71.1% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09944.

Constituent: Lithium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Constituent: Mercury Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTls
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interval Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 46 background values. 36.36% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09447.

Constituent: Molybdenum Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


Tolerance Limit
Interval Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because censored data exceeded 50%. Limit is highest of 45 background values. 91.11% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.0944.

Constituent: Thallium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Tolerance Limit
Interval Non-parametric



Non-parametric test used in lieu of parametric tolerance limit because the Shapiro Wilk normality test showed the data to be non-normal at the 0.01 alpha level. Limit is highest of 46 background values. 50% NDs. 90.43% coverage at alpha=0.01; 93.55% coverage at alpha=0.05; 98.63% coverage at alpha=0.5. Report alpha = 0.09447.

Constituent: Selenium Analysis Run 3/22/2022 10:40 AM View: Appendix IV - UTLS
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

NORTHEASTERN BAP GWPS				
Constituent Name	MCL	CCR-Rule Specified Level	Background Limit	GWPS
Antimony, Total (mg/L)	0.006		0.0071	0.0071
Arsenic, Total (mg/L)	0.01		0.057	0.057
Barium, Total (mg/L)	2		2.6	2.6
Beryllium, Total (mg/L)	0.004		0.0021	0.004
Cadmium, Total (mg/L)	0.005		0.0025	0.005
Chromium, Total (mg/L)	0.1		0.042	0.1
Cobalt, Total (mg/L)	n/a	0.006	0.018	0.018
Combined Radium, Total (pCi/L)	5		15.84	15.84
Fluoride, Total (mg/L)	4		4.39	4.39
Lead, Total (mg/L)	n/a	0.015	0.011	0.015
Lithium, Total (mg/L)	n/a	0.04	0.14	0.14
Mercury, Total (mg/L)	0.002		0.00003	0.002
Molybdenum, Total (mg/L)	n/a	0.1	0.01	0.1
Selenium, Total (mg/L)	0.05		0.005	0.05
Thallium, Total (mg/L)	0.002		0.0016	0.002

*Grey cell indicates Background Limit is higher than MCL

*GWPS = Groundwater Protection Standard

*MCL = Maximum Contaminant Level

*CCR = Coal Combustion Residuals

Confidence Interval - Significant Results

Northeastern BAP Client: Geosyntec Data: Northeastern BAP Printed 8/30/2022, 2:23 PM


<u>Constituent</u>	<u>Well</u>	<u>Upper Lim.</u>	<u>Lower Lim.</u>	<u>Compliance</u>	<u>Sig.</u>	<u>N</u>	<u>%NDs</u>	<u>Transform</u>	<u>Alpha</u>	<u>Method</u>
Barium (mg/L)	SP-10	6.594	3.659	2.6	Yes	12	0	No	0.01	Param.
Fluoride (mg/L)	SP-10	7.254	5.171	4.39	Yes	22	13.64	x^2	0.01	Param.
Lithium (mg/L)	SP-10	0.2864	0.2404	0.14	Yes	20	0	No	0.01	Param.

Confidence Interval - All Results


Northeastern BAP Client: Geosyntec Data: Northeastern BAP Printed 8/30/2022, 2:23 PM

<u>Constituent</u>	<u>Well</u>	<u>Upper Lim.</u>	<u>Lower Lim.</u>	<u>Compliance</u>	<u>Sig.</u>	<u>N</u>	<u>%NDs</u>	<u>Transform</u>	<u>Alpha</u>	<u>Method</u>
Antimony (mg/L)	SP-1	0.00114	0.00058	0.0071	No	23	30.43	No	0.01	NP (normality)
Antimony (mg/L)	SP-10	0.00126	0.0002275	0.0071	No	20	20	sqrt(x)	0.01	Param.
Antimony (mg/L)	SP-11	0.002695	0.0004495	0.0071	No	20	15	x^(1/3)	0.01	Param.
Antimony (mg/L)	SP-2	0.00295	0.00114	0.0071	No	23	8.696	No	0.01	NP (normality)
Arsenic (mg/L)	SP-1	0.001272	0.0006887	0.057	No	23	34.78	ln(x)	0.01	Param.
Arsenic (mg/L)	SP-10	0.005835	0.001509	0.057	No	20	10	sqrt(x)	0.01	Param.
Arsenic (mg/L)	SP-11	0.005939	0.002519	0.057	No	20	5	No	0.01	Param.
Arsenic (mg/L)	SP-2	0.00254	0.00128	0.057	No	23	4.348	No	0.01	NP (normality)
Barium (mg/L)	SP-1	0.2066	0.1662	2.6	No	23	0	No	0.01	Param.
Barium (mg/L)	SP-10	6.594	3.659	2.6	Yes	12	0	No	0.01	Param.
Barium (mg/L)	SP-11	0.3698	0.1807	2.6	No	20	0	No	0.01	Param.
Barium (mg/L)	SP-2	1.386	0.9815	2.6	No	23	0	ln(x)	0.01	Param.
Beryllium (mg/L)	SP-1	0.00026	0.00005	0.004	No	23	21.74	No	0.01	NP (normality)
Beryllium (mg/L)	SP-10	0.0025	0.00003	0.004	No	20	35	No	0.01	NP (normality)
Beryllium (mg/L)	SP-11	0.0025	0.00003	0.004	No	20	35	No	0.01	NP (normality)
Beryllium (mg/L)	SP-2	0.0002	0.00007	0.004	No	23	17.39	No	0.01	NP (normality)
Cadmium (mg/L)	SP-1	0.0002	0.00008	0.005	No	23	43.48	No	0.01	NP (normality)
Cadmium (mg/L)	SP-10	0.0002	0.000021	0.005	No	20	55	No	0.01	NP (NDs)
Cadmium (mg/L)	SP-11	0.0003893	0.00005019	0.005	No	20	15	ln(x)	0.01	Param.
Cadmium (mg/L)	SP-2	0.0002	0.00006	0.005	No	23	43.48	No	0.01	NP (normality)
Chromium (mg/L)	SP-1	0.0009329	0.0004677	0.1	No	23	26.09	ln(x)	0.01	Param.
Chromium (mg/L)	SP-10	0.001107	0.000298	0.1	No	19	10.53	ln(x)	0.01	Param.
Chromium (mg/L)	SP-11	0.00472	0.000676	0.1	No	20	5	ln(x)	0.01	Param.
Chromium (mg/L)	SP-2	0.001537	0.0005699	0.1	No	23	13.04	sqrt(x)	0.01	Param.
Cobalt (mg/L)	SP-1	0.001281	0.0004727	0.018	No	23	13.04	x^(1/3)	0.01	Param.
Cobalt (mg/L)	SP-10	0.002317	0.0005156	0.018	No	20	10	sqrt(x)	0.01	Param.
Cobalt (mg/L)	SP-11	0.005575	0.001289	0.018	No	20	5	sqrt(x)	0.01	Param.
Cobalt (mg/L)	SP-2	0.001123	0.0004879	0.018	No	23	13.04	x^(1/3)	0.01	Param.
Combined Radium 226 + 228 (pCi/L)	SP-1	4.133	3.069	15.84	No	22	0	No	0.01	Param.
Combined Radium 226 + 228 (pCi/L)	SP-10	14.95	4.817	15.84	No	20	0	No	0.01	Param.
Combined Radium 226 + 228 (pCi/L)	SP-11	2.138	1.047	15.84	No	19	0	sqrt(x)	0.01	Param.
Combined Radium 226 + 228 (pCi/L)	SP-2	13.99	8.718	15.84	No	20	0	sqrt(x)	0.01	Param.
Fluoride (mg/L)	SP-1	0.9428	0.6622	4.39	No	23	8.696	No	0.01	Param.
Fluoride (mg/L)	SP-10	7.254	5.171	4.39	Yes	22	13.64	x^2	0.01	Param.
Fluoride (mg/L)	SP-11	3.358	2.339	4.39	No	22	0	No	0.01	Param.
Fluoride (mg/L)	SP-2	3.202	2.655	4.39	No	24	0	x^2	0.01	Param.
Lead (mg/L)	SP-1	0.002	0.000259	0.015	No	23	34.78	No	0.01	NP (normality)
Lead (mg/L)	SP-10	0.002	0.0001	0.015	No	20	45	No	0.01	NP (normality)
Lead (mg/L)	SP-11	0.002506	0.0004524	0.015	No	20	15	x^(1/3)	0.01	Param.
Lead (mg/L)	SP-2	0.002	0.000253	0.015	No	23	39.13	No	0.01	NP (normality)
Lithium (mg/L)	SP-1	0.006181	0.004477	0.14	No	22	0	No	0.01	Param.
Lithium (mg/L)	SP-10	0.2864	0.2404	0.14	Yes	20	0	No	0.01	Param.
Lithium (mg/L)	SP-11	0.0851	0.03925	0.14	No	20	0	No	0.01	Param.
Lithium (mg/L)	SP-2	0.08403	0.05715	0.14	No	23	0	No	0.01	Param.
Mercury (mg/L)	SP-1	0.000009	0.000005	0.002	No	23	82.61	No	0.01	NP (NDs)
Mercury (mg/L)	SP-10	0.000015	0.000005	0.002	No	20	50	No	0.01	NP (normality)
Mercury (mg/L)	SP-11	0.00001	0.000005	0.002	No	20	35	No	0.01	NP (normality)
Mercury (mg/L)	SP-2	0.000005	0.000005	0.002	No	23	82.61	No	0.01	NP (NDs)
Molybdenum (mg/L)	SP-1	0.01561	0.01082	0.1	No	23	0	No	0.01	Param.
Molybdenum (mg/L)	SP-10	0.0229	0.003682	0.1	No	19	5.263	x^(1/3)	0.01	Param.
Molybdenum (mg/L)	SP-11	0.0469	0.00215	0.1	No	20	5	No	0.01	NP (normality)
Molybdenum (mg/L)	SP-2	0.02929	0.02105	0.1	No	23	0	No	0.01	Param.
Selenium (mg/L)	SP-1	0.00645	0.003314	0.05	No	23	13.04	No	0.01	Param.
Selenium (mg/L)	SP-10	0.001805	0.0002167	0.05	No	20	35	x^(1/3)	0.01	Param.
Selenium (mg/L)	SP-11	0.001829	0.0004073	0.05	No	20	10	ln(x)	0.01	Param.
Selenium (mg/L)	SP-2	0.01074	0.003089	0.05	No	23	8.696	sqrt(x)	0.01	Param.
Thallium (mg/L)	SP-1	0.00089	0.0001	0.002	No	23	69.57	No	0.01	NP (NDs)
Thallium (mg/L)	SP-10	0.0002	0.00004	0.002	No	20	95	No	0.01	NP (NDs)
Thallium (mg/L)	SP-11	0.0002	0.00003	0.002	No	20	95	No	0.01	NP (NDs)
Thallium (mg/L)	SP-2	0.0002	0.0001	0.002	No	23	82.61	No	0.01	NP (NDs)


Parametric and Non-Parametric (NP) Confidence Interval




Parametric and Non-Parametric (NP) Confidence Interval




Parametric Confidence Interval



Non-Parametric Confidence Interval




Parametric and Non-Parametric (NP) Confidence Interval




Constituent: Cadmium Analysis Run 8/30/2022 2:21 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Parametric Confidence Interval




Constituent: Cobalt Analysis Run 8/30/2022 2:21 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Parametric Confidence Interval











Constituent: Chromium Analysis Run 8/30/2022 2:21 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

Parametric Confidence Interval




Constituent: Combined Radium 226 + 228 Analysis Run 8/30/2022 2:21 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP


 $n=23$ NP(normality) $n=20$ NP(normality) $n=23$ NP(normality) $n=24$ χ^2_2 $n=21$ χ^2_1 $n=20$ χ^2_2 $n=21$ χ^2_1 $n=20$ NP(normality) $n=21$ NP(normality)




Constituent: Molybdenum Analysis Run 8/30/2022 2:22 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP



Constituent: Thallium Analysis Run 8/30/2022 2:22 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP



Constituent: Selenium Analysis Run 8/30/2022 2:22 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP



Constituent: Arsenic Analysis Run 8/30/2022 2:22 PM View: Confidence Interval
Northeastern BAP Client: Geosyntec Data: Northeastern BAP

ATTACHMENT C
August 2022 BAP Sediment SPLP Analysis



Waste Analysis Report

Dolan Chemical Laboratory
4001 Bixby Road
Groveport, OH 43125
Phone: 614-836-4221
Audinet: 210-4221

Job ID: 222808

Customer: Northeastern 3&4 Power Stat

Date Reported: 09/26/2022

Lab Number: 222808-001

Preparation: SPLP per SW-846 1312-1994, Rev. 0

Customer Sample ID: BAP Pore Water

Date Collected: 08/25/2022

Customer Description:

Date Received: 08/31/2022

Parameter	USEPA Limit	Dilution	Result	Units	RL	MDL	Data Qualifiers	Analyst	Analysis Date	Method
Lithium		5	<0.5	mg/L	0.5	0.1		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Antimony		5	<0.25	mg/L	0.25	0.08		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Arsenic	5	5	<0.25	mg/L	0.25	0.03		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Barium	100	5	0.22	mg/L	0.10	0.01		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Beryllium	100	5	<0.010	mg/L	0.010	0.001		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Cadmium	1	5	<0.010	mg/L	0.010	0.003		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Chromium	5	5	<0.025	mg/L	0.025	0.005		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Cobalt	5	5	<0.025	mg/L	0.025	0.005		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Lead	5	5	<0.10	mg/L	0.10	0.03		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Molybdenum	5	5	<0.05	mg/L	0.05	0.01		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Selenium	1	5	<0.25	mg/L	0.25	0.04		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0
Thallium	1	5	<0.25	mg/L	0.25	0.05		SDW	09/22/2022	SW-846 6010D-2018, Rev. 5.0

Report Verification

This report and the above data have been confirmed by the following analyst.

Michael Ohlinger, Chemist

Email: msohlinger@aep.com

Phone: 614-836-4184

Audinet: 8-210-4184

THIS TEST REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT WRITTEN APPROVAL OF THE LABORATORY. ALL TEST RESULTS MEET ALL OF THE REQUIREMENTS OF THE ACCREDITING AUTHORITY, UNLESS OTHERWISE NOTED.



Waste Analysis Report

Dolan Chemical Laboratory
4001 Bixby Road
Groveport, OH 43125
Phone: 614-836-4221
Audinet: 210-4221

Job ID: 222808

Customer: Northeastern 3&4 Power Stati

Date Reported: 09/26/2022

Data Qualifier Legend

- B1 Analyte detected in method blank (MB) at or above the method criteria.
- B2 Analyte detected in initial calibration blank (ICB) at or above the method criteria.
- B3 Analyte detected in continuing calibration blank (CCB) at or above the method criteria.
- H1 Sample was received past holding time.
- H2 Sample analysis performed past holding time.
- J1 Concentration estimated. Analyte was detected between the method detection limit and the reporting limit.
- J2 Concentration estimated. Analyte exceeded calibration range.
- L1 The associated laboratory control sample (LCS) or labatory control sample duplicate (LCSD) recovery was outside acceptance limits.
- M1 The associated matrix spike (MS) or matrix spike duplicate (MSD) recovery was outside acceptance limits.
- M2 Analyzed by method of standard additions (MSA).
- P1 The precision between duplicate results was above acceptance limits.
- P2 The precision on the laboratory control sample duplicate (LCSD) was above acceptance limits.
- P3 The precision on the matrix spike duplicate (MSD) was above acceptance limits.
- Q1 Sample received in inappropriate sample container.
- Q2 Sample was received damaged. The sample was recoverable.
- Q3 Sample container was received damaged. Unable to recover the sample.
- Q4 Sample was received outside of thermal preservation range.
- Q5 Sample was received with improper chemical preservation.
- Q6 Insufficient sample was received by the laboratory to perform the requested analysis.
- Q7 Insufficient sample was received to meet method QC requirements.
- Q8 Sample was received with head space.
- Q9 Due to instrument malfunction, sample was invalidated.
- Q10 Analysis was performed by a contracted laboratory. See attached report.
- Q11 Sample contains free liquid.
- Q12 Sample does not contain free liquid.
- Q13 Sample did not ignite.
- Q14 This analyte and method are not included on the primary Laboratory Scope of TNI Accreditation.
- Q15 The reporting limit for oil and grease is directly affected by the collected sample volume.
- Q16 Analysis performed by a contract laboratory. See attached report.
- R1 Surrogate recovery was outside acceptance limits.
- R2 Carrier recovery was outside acceptance limits.
- R3 Internal standard recovery was outside acceptance limits.
- U1 Not detected at or above method detection limit (MDL).
- V1 The associated initial calibration verification (ICV) recovery was outside acceptance limits.
- V2 The associated continuing calibration verification (CCV) recovery was outside acceptance limits.