



An **AEP** Company

BOUNDLESS ENERGY™

## Northeastern Power Station

### Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standard (GWPS)

#### CCR Unit – Bottom Ash Pond

As required by OAC 252:517-9-6(g), this is a notification that on September 11, 2024, barium, fluoride, and lithium were detected as potential SSLs above the GWPS during the 1<sup>st</sup> semi-annual 2024 groundwater sampling event.

This notification is being placed in the plant's operating record, as required by OAC 252:517-19-1(h)(8).

BOUNDLESS ENERGY™