

Clinch River Plant

Notice of Statistically Significant Levels (SSLs) above the Groundwater Protection Standards (GPSs)

CCR Unit – Pond 1

As required by 40 CFR 257.95(g), this is a notification that on August 6, 2024, barium, cobalt, lithium, and molybdenum were detected as potential SSLs above the GPSs. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8).