

Welsh Power Plant

Notice of Initiating an Assessment Monitoring Program

Bottom Ash Storage Pond

On October 31, 2025, it was determined that Welsh Power Plant's Bottom Ash Storage Pond (BASP) had statistically significant increases over background for boron, calcium, chloride, sulfate and TDS. Alternative source demonstrations were not successful within the 90-day period, prompting the initiation of an assessment monitoring program, which was established on December 29, 2025, as required by §352.1421(d).