

# Emergency Action Plan

40 CFR 257.73(a)(3)

Ash Pond

Cabin Creek Site

Cabin Creek, WV

May, 2026

Prepared for: Appalachian Power Company

Prepared by: American Electric Power Service Corporation

1 Riverside Plaza

Columbus, OH 43215



# Cabin Creek Site – Ash Pond Emergency Action Plan

PREPARED BY \_\_\_\_\_ DATE \_\_\_\_\_  
Blake Arthur, P.E.

REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_  
Dan Murphy, P.E.

APPROVED BY David Anthony Miller DATE 04.24.2026  
David Anthony Miller, P.E.  
Director – Ash Management Services



I certify to the best of my knowledge, information, and belief the information contained in this report meets the requirements of 40 CFR § 257.73(a)(3).

## Contents

Introduction .....	4
Statement of Purpose .....	4
Project Description & Location .....	4
Emergency Action Plan (EAP).....	6
40 CFR 257.73 (a) (3) (i) Development of the plan.....	6
Notification Flowchart .....	10
40 CFR 257.73 (a) (3) (ii) Amendment of the plan. ....	11
40 CFR 257.73 (a) (3) (iii) Changes in hazard potential classification. ....	12
40 CFR 257.73 (a) (3) (v) Activation of the EAP. ....	12
Termination Responsibilities .....	12
Emergency Preparedness .....	12
Controlled Copy Distribution List .....	13
Log of Revisions .....	13

## List of Appendices

Appendix A – Inundation Map

Appendix B – Annual Meeting Documentation

Appendix C – Annual Review Form

Appendix D – EAP Activation Form

## Introduction

The “Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals From Electric Utilities; Legacy CCR Surface Impoundments”, 89 Fed. Reg. 38950 (May 8, 2024) (amending 40 C.F.R. §257) requires owners and operators of facilities with a legacy coal combustion residual (CCR) surface impoundment to prepare an Emergency Action Plan document for each legacy CCR surface impoundment at the facility that meet hazard potential requirements. The Ash Pond at the Cabin Creek Site is subjected to this rule.

## Statement of Purpose


An Emergency Action Plan (EAP) is a formal document that identifies potential emergency conditions at a dam and specifies preplanned actions to be followed to minimize property damage and loss of life, if applicable. The Legacy CCR rule does not require a specific format, so this EAP was generated to comply with the requirements of the rule and incorporate applicable elements from other EAPs, including Interagency Committee on Dam Safety (ICODS) format, State Dam Safety formats, and other AEP operating facilities. The scope may vary across the Legacy CCR sites depending on the complexity and risk of the individual facility.

## Project Description & Location

The Cabin Creek site is located near Chelyan, West Virginia, near the intersection of MacCorkle Ave SE and Cabin Creek Rd., Cabin Creek, WV 25035. The latitude/longitude of the facility is: 38°11'52"N / 81°29' 6" W. The facility address is: Intersection of MacCorkle Ave SE and Cabin Creek Rd., Cabin Creek, WV 25035.

The site can be reached from the North via I-64, taking exit 85 to WV-61 S/MacCorkle Ave in Chelyan. The site entrance is on the left (north) side of the road just past Go Mart.

From the South via I-64 take exit 79 to Cabin Creek Road. Go 4.6 miles to WV-61 S/MacCorkle Ave in Chelyan. At the intersection with MacCorkle Avenue, the site is across the street next to Go Mart.



*Figure 1: Site Vicinity Map*

The Cabin Creek site is located near Chelyan, West Virginia, near the intersection of MacCorkle Ave SE and Cabin Creek Rd., Cabin Creek, WV 25035. The latitude/longitude of the facility is: 38°11'52"N / 81°29' 6" W. The Ash Pond is approximately 19 acres. The Cabin Creek Power Plant was placed in service in 1914, stopped generating electricity in 1977, retired in 1981 and the site was razed in 1985-1987. The Ash Pond was constructed sometime around 1956.

The Ash Pond is located near the Kanawha River on the west side of the plant property. The Ash Pond was located on the west side of Cabin Creek, and the Power Plant was located on the East side of Cabin Creek.

According to the 1956 U.S. Army Corps Permit application, the ash pond was constructed by building a dike around Cabin Creek Island and filling the former river backchannel with dredged river sediments. To offset the loss of channel volume, approximately 200,000 cubic yards of compensatory dredging was completed adjacent to the Cabin Creek Island within the main river channel. The dike included a 650-foot-long southwest section reinforced with 35-foot-deep wood piling and rockfill, and a similarly long northeast section protecting the shoreline with riprap armor. The exterior slope of the dike was designed at

2H:1V and the interior slope was designed at 1.5H:1V. The 2H:1V slope extends below the navigational pool of the Marmet Lock and Dam (590 ft-msl) to an elevation of 575 ft-msl, 15 below the normal pool.

The former discharge structure is a pipe and riser type structure located at the western end of the Ash Pond. The riser structure is made of concrete and has grooves for receiving stop logs for controlling the pool level when the pond was active. The outlet pipe is a 24-inch-diameter reinforced concrete pipe. The discharge structure no longer functions, and the facility no longer impounds water.

## Emergency Action Plan (EAP)

### 40 CFR 257.73 (a) (3) (i) Development of the plan.

*40 CFR 257.73 (a) (3) (i) (A) Define the events or circumstances involving the CCR unit that represent a safety emergency, along with a description of the procedures that will be followed to detect a safety emergency in a timely manner;*

The preamble to the 2015 CCR final rule provides examples of potential indicators of structural weaknesses (Operating Criteria- Inspection Requirements for CCR Surface Impoundments Section). These signs of potential structural weaknesses may range from minor items that will be added to the routine maintenance plan to deficiencies that could have the potential to disrupt the operation and safety of the structure.

1. Excessive, turbid, or sediment-laden seepage
2. Signs of piping and other internal erosion
3. Transverse, longitudinal, and desiccation cracking
4. Slides, bulges, boils, sloughs, scarps, sinkholes, or depressions
5. Abnormally high or low pool levels
6. Excessive or lacking vegetative cover
7. Slope erosion
8. Debris

During normal operation of the facility inspections at least every 7 days. Facility inspections are reviewed along with instrumentation readings every 30 days. Annual inspections are performed by a professional engineer. These inspections ensure potential safety emergencies are detected in a timely manner.

This EAP will follow the alert levels as established by the Interagency Committee on Dam Safety Format. Specifically, three alert levels of increasing urgency are identified as 1- Monitor, 2- Watch and 3- Warning.

- Monitor = Unusual event, slowly developing, not an immediate threat to the dam.
- Watch = Unsafe situation that may lead to failure of the dam but not an immediate threat.
- Warning = Urgent situation. Failure is occurring or about to occur. Or, areas downstream are flooding due to spillway flow. Evacuation of downstream area necessary.

The alert level table included in this document can be used as a general guide to determining the proper alert level. Additional consultation with AEP Ash Management Services engineer for subject matter expertise.

<b>Alert Level Table</b>		
<b>Event</b>	<b>Situation</b>	<b>Alert Level</b>
Embankment Overtopping	No overtopping flow but water level in lake within 6 inches of crest or backflow through outlet structure.	Monitor
	Minor river overtopping/toe scour	Watch
	Major overtopping flow eroding the embankment slope	Warning
Seepage	New seepage areas in or near the dam with clear flow	Monitor
	New seepage areas with cloudy discharge or increasing flow rate	Watch
	Heavy seepage with active erosion. Muddy flow and/or sand boils.	Warning
Sinkholes	Observation of new sinkhole in reservoir area or on embankment.	Watch
	Rapidly enlarging sinkhole on the embankment with visible flow or whirlpool in the lake.	Warning
Embankment Cracking	New cracks in the embankment greater than 1/4-inch wide without seepage	Monitor
	Cracks in the embankment with seepage	Watch
Embankment Movement	Visual movement/slippage of the embankment slope	Monitor
Earthquake	Measurable earthquake felt or reported on or within 50 miles of the dam	Monitor
	Earthquake resulting in visible damage to the dam or appurtenances	Watch
	Earthquake resulting in uncontrolled release of water from the dam	Warning
Security Threat	Verified bomb threat that, if carried out, could result in damage to the dam	Watch
	Detonated bomb that has resulted in damage to the dam or appurtenances	Warning
Sabotage	Damage to dam or appurtenances with no impacts to the functioning of the dam	Monitor
	Damage to dam or appurtenances that has resulted in seepage flow	Watch
	Damage to dam or appurtenances that has resulted in uncontrolled water release	Warning

*40 CFR 257.73 (a) (3) (i) (B) Define responsible persons, their respective responsibilities, and notification procedures in the event of a safety emergency involving the CCR unit;*

<u>Action</u>	<u>Responsibility</u>
Alert level determination	AMS Engineer
Emergency notifications	AEP
Notify impacted residents	AEP, EMA, and Local Law Enforcement
Establish incident command	AEP, EMA
Traffic control and security	Local Law Enforcement
Evacuation	EMA

#### Notification Procedures

AEP will consult with subject matter experts in Ash Management Services to determine the alert level at the dam according to this EAP and notify emergency responders and AEP Stakeholders.

Notification chart is included within this emergency action plan.

*40 CFR 257.73 (a) (3) (i) (C) Provide contact information of emergency responders.*

See notification chart.

### Notification Flowchart


Watch or Warning Alert Level

Cabin Creek Site  
Ash Pond

AEP/Appalachian Power

Title	Name	Work Phone	Cell Phone	Email
Construction Coordinator	Laura Keeney		304-382-2483	lkkeeney@aep.com

*Note: Initial boxes after calling*



PERSONNEL SHOULD NOT DEVIATE FROM THIS SCRIPT TO PREVENT THE PASSAGE OF INCORRECT OR MISLEADING INFORMATION

**Use this script for notifications to emergency responders:** "This is \_\_\_\_ (name and position). A \_\_\_\_ (Watch or Warning) level situation exists involving a \_\_\_\_ (Describe Situation) of the (Specify the Dam Name and Type) at the Cabin Creek Site. We will advise when the situation is resolved or if conditions change. I can be contacted at the following number \_\_\_\_\_. My alternate phone number is \_\_\_\_\_.

(Select one):

We DO need offsite assistance, and this is what we need \_\_\_\_\_. Please relay this information to your Emergency Management Director as soon as possible." OR

We DO NOT need any offsite assistance at this time, we are just calling to keep you informed. However, please relay this information to your Emergency Management Director as soon as possible." Ask Operator to repeat message back for confirmation.

**Use this script for notifications to AEP Stakeholders:** "This is \_\_\_\_ (name and position). A \_\_\_\_ (Watch or Warning) level situation exists at \_\_\_\_ the Cabin Creek Site due to \_\_\_\_ (Describe Situation). A status call will occur at \_\_\_\_ (time and date). Please notify appropriate staff to join the call for additional information."

*40 CFR 257.73 (a) (3) (i) (D) Include a map which delineates the downstream area which would be affected in the event of a CCR unit failure and a physical description of the CCR unit; and*

See appendix A for inundation map. The Cabin Creek Ash Pond consists of dry ash that is bounded on the north by the Kanawha River, and the south by the town of Chelyan. The breach model assumes that the ash is saturated, flowable, and develops a full breach of the north or south dams. Inundation areas vary based on potential flow characteristics of the ash, resulting in different potential inundation areas. Model assumes no flood tailwater conditions.

*40 CFR 257.73 (a) (3) (i) (E) Include provisions for an annual face-to-face meeting or exercise between representatives of the owner or operator of the CCR unit and the local emergency responders.*

AEP is required to hold an annual face-to-face meeting with local responders or ensure their participation in an EAP exercise. To address this requirement, AEP will have documented annual meeting with local emergency responders. The form in Appendix B (CSED D.3) must be filled out to provide the necessary documentation of this annual meeting. The meeting could take the form of one of the following:

- Orientation Seminar
- Table top exercise
- Full- Scale exercise

#### 40 CFR 257.73 (a) (3) (ii) Amendment of the plan.

*(A) The owner or operator of a CCR unit subject to the requirements of [paragraph \(a\)\(3\)\(i\)](#) of this section may amend the written EAP at any time provided the revised plan is placed in the facility's operating record as required by [§ 257.105\(f\)\(6\)](#). The owner or operator must amend the written EAP whenever there is a change in conditions that would substantially affect the EAP in effect.*

*(B) The written EAP must be evaluated, at a minimum, every five years to ensure the information required in [paragraph \(a\)\(3\)\(i\)](#) of this section is accurate. As necessary, the EAP must be updated and a revised EAP placed in the facility's operating record as required by [§ 257.105\(f\)\(6\)](#).*

AEP is required to review and update the Emergency Action Plan. To address this requirement the Emergency Action Plan will be reviewed annually and documented by filling out the form in Appendix C.

#### 40 CFR 257.73 (a) (3) (iii) Changes in hazard potential classification.

If the hazard potential classification changes for this site, then the EAP will be updated accordingly.

#### 40 CFR 257.73 (a) (3) (v) Activation of the EAP.

*The EAP must be implemented once events or circumstances involving the CCR unit that represent a safety emergency are detected, including conditions identified during periodic structural stability assessments, annual inspections, and inspections by a qualified person.*

AEP will document any activation of the Emergency Action Plan using the form in Appendix D. The form will document any unusual or emergency events including any event progression or deescalation of the event.

#### Termination Responsibilities

When the impoundment is closed or hazard classification changes such that an EAP is no longer required, the operating record will be updated noting the change and termination of the EAP.

#### Emergency Preparedness

The following preparedness plan is a general starting point for emergency response at the site. Details may vary depending on the circumstances.

- Potential Emergency Response Contractors
  - United Construction Contractors Inc (UCCI) (304) 422-2141
- Construction Coordinator, AMS Engineer, and Environmental Representative for the site will provide coverage for necessary site surveillance.
- A TEAMS channel or similar will be established for file sharing, meeting setup, and general notifications of developments.
- An example daily meeting schedule could be:
  - 8:00 AM Internal call
  - 9:00 AM External call with emergency response or incident command
  - 10:00 AM Public/Media Briefing
- Emergency Resources available
  - Security Cameras – Stallion (480) 620-2307
  - Sand and gravel – Shamblin Stone (304) 542-6684
  - Riprap – Shamblin Stone (304) 542-6684
  - Sand bags – Sandbags To Go (866)-550-2247
  - Equipment rental – Sunbelt Rentals (304)342-5000

- Pumps – Sunbelt Rentals (304)342-5000
- Turbidity curtains – Ferguson Waterworks (740) 373-3456
- Concrete – Smith Concrete (304) 342-1930

### Controlled Copy Distribution List

- AEP
  - Laura Keeney- Construction Coordinator
  - David Miller, PE – Director Ash Management Services
  - Dan Murphy, PE – Geotechnical Engineer
  - Jon Webster- Environmental Engineer
  - Sammy Gray- Appalachian Power External Affairs
- Kanawha County EMA


### Log of Revisions

Date	Revision Number	Summary of Change
May 8, 2026	0	Initial publication

## **Appendix A – Inundation Map**

**CABIN CREEK DAM  
DAM FAILURE MAPPING  
KANAWHA COUNTY, WV**  
Panel 2 of 2

**PANEL LOCATOR**




**LEGEND**

- Dam Centerline
- Attenuation
- Sunny Day Breach - Clays
- Sunny Day Breach - Typical Soils
- Sunny Day Breach - Clear Water
- Design Storm - Non-Breach - Clear Water
- Design Storm - Breach - Clear Water
- NHD Flowline
- Apartment Building
- Camper
- Commercial
- Non-Occupied Structure
- Out Building
- Residential

Refer to Breach Model Report tables for detailed results at pertinent locations/road crossings.

The methods used to develop inundation zones and flood wave arrival times are approximate and should only be used as guidance for establishing evacuation zones. Actual areas inundated will depend on actual failure and pre-failure hydrologic conditions and may differ significantly from information shown on maps.



### Results of PMF Breach For Cabin Creek Dam

Location Number	Lowest Elevation of Impact (feet)	PMF Without Breach		PMF With Breach		Stage Increase Due to Breach (feet)	Time from Start of Breach Event (min)	Time to Peak**	Location Number	Lowest Elevation of Impact (feet)	PMF Without Breach		PMF With Breach		Stage Increase Due to Breach (feet)	Time from Start of Breach Event (min)	Time to Peak**
		Peak Elevation (feet)	Depth of Impact (feet)	Peak Elevation (feet)	Depth of Impact (feet)						Peak Elevation (feet)	Depth of Impact (feet)	Peak Elevation (feet)	Depth of Impact (feet)			
1	613.3	-	-	614.3	1.1	1.1	21		51	610.8	-	-	614.2	3.4	3.4	21	
2	610.2	-	-	614.3	4.1	4.1	21		52	610.4	-	-	614.2	3.9	3.9	21	
3	610.9	-	-	614.3	3.4	3.4	21		53	609.3	-	-	614.2	5	5	21	
4	607.8	-	-	614.3	6.5	6.5	21		54	601.8	-	-	614.2	12.4	12.4	21	
5	613.7	-	-	614.3	0.6	0.6	21		55	603.3	-	-	614.2	11	11	21	
6	614	-	-	614.3	0.3	0.3	21		56	603.8	-	-	614.2	10.4	10.4	21	
7	609	-	-	614.3	5.4	5.4	21		57	603.3	-	-	614.2	11	11	21	
8	606.3	-	-	614.3	8	8	21		58	606.8	-	-	614.2	7.4	7.4	21	
9	610.3	-	-	614.3	4	4	21		59	607.2	-	-	614.2	7	7	21	
10	610.5	-	-	614.3	3.8	3.8	21		60	609.7	-	-	614.2	4.5	4.5	21	
11	610.1	-	-	614.3	4.2	4.2	21		61	601.2	-	-	614.2	13.1	13.1	23	
12	610.4	-	-	614.3	3.9	3.9	21		62	603.2	-	-	614.2	11	11	21	
13	606.2	-	-	614.3	8.1	8.1	21		63	604.3	-	-	614.2	9.9	9.9	23	
14	608.8	-	-	614.3	5.5	5.5	21		64	607.2	-	-	614.2	7	7	23	
15	609.6	-	-	614.3	4.7	4.7	21		65	606.4	-	-	614.2	7.8	7.8	23	
16	611.8	-	-	614.3	2.5	2.5	21		66	606.8	-	-	614.2	7.5	7.5	23	
17	609.8	-	-	614.3	4.5	4.5	21		67	609.1	-	-	614.2	5.1	5.1	23	
18	606.9	-	-	614.3	7.4	7.4	21		68	609.6	-	-	614.2	4.6	4.6	23	
19	609.2	-	-	614.3	5.1	5.1	21		69	612.5	-	-	614.2	1.7	1.7	23	
20	610	-	-	614.3	4.3	4.3	21		70	614.3	-	-	614.3	0	0	22	
21	608.8	-	-	614.3	5.4	5.4	21		71	613.3	-	-	614.2	1	1	22	
22	607.8	-	-	614.3	6.5	6.5	21		72	609.8	-	-	614.3	4.5	4.5	22	
23	605.8	-	-	614.3	8.5	8.5	21		73	609.3	-	-	614.3	4.9	4.9	22	
24	603.1	-	-	614.3	11.2	11.2	21		74	610.8	-	-	614.2	3.5	3.5	21	
25	606.3	-	-	614.3	8	8	21		75	606.5	-	-	614.2	7.7	7.7	21	
26	608.8	-	-	614.3	5.5	5.5	21		76	606.3	-	-	614.2	7.9	7.9	21	
27	608.6	-	-	614.3	5.7	5.7	21		77	607.1	-	-	614.2	7.1	7.1	21	
28	603.9	-	-	614.3	10.4	10.4	21		78	609.7	-	-	614.2	4.5	4.5	21	
29	606	-	-	614.3	8.3	8.3	21		79	610.1	-	-	614.2	4.1	4.1	21	
30	606.8	-	-	614.3	7.5	7.5	21		80	607.3	-	-	614.2	6.9	6.9	21	
31	606.3	-	-	614.3	8	8	21		81	607.2	-	-	614.2	7	7	21	
32	607.1	-	-	614.3	7.1	7.1	21		82	606.8	-	-	614.2	7.4	7.4	23	
33	606.9	-	-	614.3	7.4	7.4	21		83	611.2	-	-	614.2	3	3	21	
34	604.9	-	-	614.3	9.3	9.3	21		84	611.1	-	-	614.2	3.2	3.2	23	
35	605.6	-	-	614.3	8.7	8.7	21		85	608.5	-	-	614.2	5.7	5.7	21	
36	610.1	-	-	614.3	4.2	4.2	21		86	611.1	-	-	614.2	3.1	3.1	21	
37	610.6	-	-	614.3	3.7	3.7	21		87	612.6	-	-	614.2	1.7	1.7	21	
38	613.3	-	-	614.3	1	1	21		88	614.4	-	-	614.2	-0.2	-0.2	NI	
39	606.9	-	-	614.3	7.4	7.4	21		89	612.8	-	-	614.2	1.4	1.4	21	
40	607	-	-	614.3	7.3	7.3	21		90	614.3	-	-	614.2	0	0	NI	
41	607.2	-	-	614.3	7.1	7.1	21		91	607.8	-	-	608.9	1.1	1.1	29	
42	606.1	-	-	614.3	8.2	8.2	21		92	607.5	-	-	609.1	1.6	1.6	29	
43	606.5	-	-	614.3	7.8	7.8	21		93	605.9	607.2	1.2	607.5	1.6	0.3	21	
44	606.6	-	-	614.3	7.6	7.6	21										
45	607.3	-	-	614.3	7	7	21										
46	605.7	-	-	614.3	8.6	8.6	21										
47	608.2	-	-	614.3	6.1	6.1	21										
48	602.2	-	-	614.2	12	12	21										
49	604.3	-	-	614.2	9.9	9.9	21										
50	604.1	-	-	614.2	10.1	10.1	21										

### Results of Sunny Day Breaches For Cabin Creek Dam

Location Number	Lowest Elevation of Impact (feet)	Sunny Day Breach		Time from Start of Breach Event (min)
		Muddy Flow		
		Peak Elevation (feet)	Peak Elevation (feet)	
7	609	610.4	610.4	25
8	606.3	610.7	610.7	15
18	606.9	610.7	610.7	25
19	609.2	610.2	610.2	49
23	605.8	611	611	21
24	603.1	611.1	611.1	20
25	606.3	610.7	610.7	26
26	608.8	610.2	610.2	40
31	606.3	610.7	610.7	50
32	607.1	609.3	609.3	60
39	606.9	607.2	607.2	1260
46	605.7	609.9	609.9	80
48	602.2	610.7	610.7	25
49	604.3	610.1	610.1	83
50	604.1	609.2	609.2	85
54	601.8	611.1	611.1	15
55	603.3	610.9	610.9	93
56	603.8	610.8	610.8	20
57	603.3	610.9	610.9	93
58	606.8	609.7	609.7	189
59	607.2	609	609	83
61	601.2	610.8	610.8	15
62	603.2	610.6	610.6	18
63	604.3	610	610	30
64	607.2	609.4	609.4	22
65	606.4	609.1	609.1	25
66	606.8	608.9	608.9	140
80	607.3	610.2	610.2	26
81	607.2	609.8	609.8	27
82	606.8	609.8	609.8	26

Location Number	Lowest Elevation of Impact (feet)	Sunny Day Breach		Time from Start of Breach Event (min)
		Muddy Flow		
		Peak Elevation (feet)	Depth of Impact (feet)	
8	606.3	609.7	3.4	11
18	606.9	609.4	2.6	13
23	605.8	610.9	5.1	10
24	603.1	611.1	8	10
25	606.3	609.8	3.4	11
31	606.3	609.3	2.9	25
48	602.2	609.2	7.1	16
49	604.3	606.7	2.4	67
54	601.8	610.6	8.8	10
55	603.3	609.7	6.5	10
56	603.8	609.4	5.5	11
57	603.3	609.7	6.5	13
61	601.2	609.7	8.5	12
62	603.2	608.6	5.4	13
63	604.3	606.7	2.4	13

Refer to Breach Model Report tables for detailed results at pertinent locations/road crossings.

The methods used to develop inundation zones and flood wave arrival times are approximate and should only be used as guidance for establishing evacuation zones. Actual areas inundated will depend on actual failure and pre-failure hydrologic conditions and may differ significantly from information shown on maps.

**Appendix B – Annual Meeting Documentation**

## **CCR Emergency Action Plan Annual Meeting Documentation**

Use this form to document the CCR Rule required annual face to face meeting.

Meeting was held to discuss the Emergency Action Plan for the following CCR unit(s): \_\_\_\_\_

Plant Personnel conducting the meeting: \_\_\_\_\_

Date: \_\_\_\_\_ Time Held: \_\_\_\_\_

Attending Organization: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Attending Organization: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Attending Organization: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Attending Organization: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Print Name: \_\_\_\_\_ Sign: \_\_\_\_\_

Use multiple pages to document additional organizations or attendees.

**Appendix C – Annual Review Form**

## **CCR Emergency Action Plan Annual Review**

CCR unit Emergency Action Plan designation: \_\_\_\_\_

\_\_\_\_\_

The Emergency Action Plan above was reviewed and there were no changes identified to any part of the Plan that required revision or modification to the Plan. This will serve as the operating record that such a review has been conducted for the year \_\_\_\_\_.

Date review was concluded: \_\_\_\_\_

Certified by: \_\_\_\_\_ Date: \_\_\_\_\_

Position Title: \_\_\_\_\_

**Appendix D – EAP Activation Form**

