

# INITIAL DESIGN FLOOD CONTROL PLAN

**40 CFR 257.82**

Bottom Ash Pond Complex

Kanawha River Site

Glasgow, WV

May, 2026

Prepared for: Appalachian Power Company

Prepared by: American Electric Power Service Corporation

1 Riverside Plaza

Columbus, OH 43215




Kanawha River Plant  
Bottom Ash Pond Complex  
Initial Design Flood Control Plan

PREPARED BY \_\_\_\_\_ DATE \_\_\_\_\_  
Dan Murphy, P.E.

REVIEWED BY \_\_\_\_\_ DATE \_\_\_\_\_  
Blake Arthur, P.E.

APPROVED BY David Anthony Miller DATE 04.23.2026  
David Anthony Miller, P.E.  
Director- Ash Management Services



I certify to the best of my knowledge, information, and belief that the information contained in this inflow design flood control plan meets the requirements of 40 CFR § 257.82

## Table of CONTENTS

<b>1.0 OBJECTIVE.....</b>	<b>4</b>
<b>2.0 DESCRIPTION OF THE CCR UNIT.....</b>	<b>4</b>
<b>3.0 INFLOW DESIGN FLOOD CONTROL PLAN 40 CFR § 257.82 .....</b>	<b>5</b>

### **Attachment A: Initial Inflow Design Flood Control Plan**

## **1.0 OBJECTIVE**

The “Hazardous and Solid Waste Management System: Disposal of Coal Combustion Residuals From Electric Utilities; Legacy CCR Surface Impoundments”, 89 Fed. Reg. 38950 (May 8, 2024) (amending 40 C.F.R. §257) requires owners and operators of facilities with a legacy coal combustion residual (CCR) surface impoundment to prepare an initial inflow design flood control plan for each legacy CCR surface impoundment at the facility.

The Bottom Ash Pond Complex at the Kanawha River Site is subjected to this rule.

## **2.0 DESCRIPTION OF THE CCR UNIT**

The Kanawha River Site is located approximately 0.5 miles southeast of Glasgow, West Virginia. The latitude/longitude of the Bottom Ash Pond Complex is: 38° 12' 33.34"N / 81° 25' 25.52"W. Construction of the Kanawha River Plant began in October of 1950 and the plant reached commercial operation in August of 1953. The Kanawha River Plant ceased operating in May 2015.

The BAP consists of the North Bottom Ash Pond, the South Bottom Ash Ponds, and the Clearwater Pond. The site is bounded by the Kanawha River on the west, the town of Glasgow on the North, and the railroad on the east.

The BAP is generally an incised surface impoundment with only the west portion of the Clearwater Pond contained by an 8-foot-tall dike built up above original grade. The water level of the Clearwater Pond is operated and maintained below the exterior toe. The exterior slope of the western Clearwater Pond dike is 2 Horizontal to 1 Vertical (2H: 1V) with interior slopes of 2.5H: 1V. The remainder of the pond complex is incised, with a surrounding ground elevation of 623 ft-msl. This grading scheme is a function of the powerplant grades being elevated for flood protection to elevation 623 ft-msl and the BAP area being a main borrow area, and the proximity of the western property line to the Clearwater Pond.

The BAP discharges through a concrete riser in the northwest corner of the Clearwater Pond (Outfall 001) that ties into a stormwater sewer which flows under the BAP.

### **3.0 INFLOW DESIGN FLOOD CONTROL PLAN 40 CFR § 257.82**

The Initial inflow design flood control plan was prepared by WSP USA Inc. and excerpts from that document are included as Attachment A.

The results of the inflow flood routing calculations demonstrate that the Kammer Ash Pond cannot adequately manage flow into and out of the CCR unit during the design flood. AEP is evaluating alternatives for flood control mitigations to address the deficiency.

**ATTACHMENT A**

**Initial Inflow Design Flood Control Plan**



**REPORT**

# Hazard Potential Classification Assessment and Inflow Design System Flood Control Plan

Bottom Ash Pond, Former Kanawha River Power Plant, Glasgow, West Virginia

Submitted to:

**Mr. Murphy**

American Electric Power Company, Inc.  
Project Manager  
1 Riverside Plaza,  
Columbus, OH 43215

Submitted by:

**WSP USA Inc.**

3348 Peachtree Road NE, Suite 1100, Atlanta, Georgia, 30326

+1 404 237 2115

US0041868.3860

April 3, 2026



# Distribution List

Benjamin J Hackett (bjhackett@aep.com)

Jane Petrie (jpetrie@aep.com)

# Table of Contents

**1 INTRODUCTION ..... 1**

**2 BACKGROUND ..... 2**

**3 HAZARD POTENTIAL CLASSIFICATION ASSESSMENT ..... 2**

**4 INFLOW DESIGN FLOOD CONTROL SYSTEM ..... 3**

    4.1 Existing Flood Control Infrastructure ..... 3

    4.2 Capacity Criteria ..... 3

**5 HYDROLOGIC ANALYSES ..... 3**

    5.1 Precipitation & Inflow Sources ..... 3

    5.2 Watershed Delineation ..... 4

    5.3 Runoff Volume Analyses ..... 4

    5.4 Stage Storage Curves ..... 5

    5.5 Inflows and Outflows During Design Storm Event ..... 6

**6 SUMMARY ..... 7**

**7 REFERENCES ..... 8**

## FIGURES

Figure 1: Site Location Plan

Figure 2: BAP Complex Site Conditions Plan and Drainage Basins

Figure 3: Potential Breach Inundation Zone

**APPENDICES**

**APPENDIX A**

BAP Complex Historical Drawings

**APPENDIX B**

Breach Study Analysis

**APPENDIX C**

Hydrology and Hydraulic Analysis

## CERTIFICATION

Professional Engineer Certification Statement [40 CFR §257.73(a) and 40 CFR §257.82(c)].

I hereby certify that, having reviewed the attached documentation and being familiar with the provisions of Title 40 of the Code of Federal Regulations Section §257.73 and Section §257.82 (40 CFR Part §257.73(a) and 40 CFR §257.82), I attest that this Hazard Potential Classification Assessment and Inflow Design Flood Control System Plan is accurate and has been prepared in accordance with good engineering practices, including the consideration of applicable industry standards, and with the requirements of 40 CFR Part §257.73(a) and 40 CFR §257.82.

**WSP USA Inc.**



\_\_\_\_\_  
Signature

\_\_\_\_\_  
April 3, 2026

Date of Report Certification

\_\_\_\_\_  
Steven J. Moeller, PE (AL, GA, NC, SC, TN, WV)

Name

\_\_\_\_\_  
27354

Professional Engineering Certification Number



# 1 INTRODUCTION

WSP USA Inc. (WSP) was retained by Appalachian Power Company, a subsidiary of American Electric Power Company, Inc. (AEP), to complete a Hazard Potential Classification Assessment, including a dam breach analysis, and prepare an Inflow Design Flood Control System Plan (Report) for the Bottom Ash Pond (BAP) complex, an inactive Coal Combustion Residuals (CCR) surface impoundment, located at the former Kanawha River Power Plant (Plant), Glasgow, WV. The site location is shown in Figure 1. The purpose of this Report is to provide a basis for the certification required by 40 Code of Federal Regulations (CFR) §257.73(a) Hazard Potential Classification Assessment and 40 CFR §257.82 Hydrologic and Hydraulic Capacity Requirements for CCR Surface Impoundments.

Section 40 CFR §257.73(a)2 requires the owner or operator of a CCR surface impoundment to conduct a hazard potential classification assessment of the CCR unit. The owner or operator must document the hazard potential classification of each CCR unit as either a high hazard potential CCR surface impoundment, a significant hazard potential CCR surface impoundment, or a low hazard potential CCR surface impoundment. The owner or operator must also document the basis for each hazard potential classification.

Section 40 CFR §257.82(a) requires the owner or operator of a CCR surface impoundment to design, construct, operate, and maintain an inflow flood control system as follows:

- Adequately manage the flow into the CCR unit during and following the peak discharge of the inflow design flood as required by the CCR unit hazard potential determined under 40 CFR §257.82(a)(3).
- Adequately manage the flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood as required by the CCR unit hazard potential determined under 40 CFR §257.82(a)(3).
- Handle discharge from the CCR unit in accordance with the surface water requirements under 40 CFR §257.3-3, which requires that:
  - a facility shall not cause a discharge of pollutants into waters of the United States that is in violation of the requirements of the National Pollutant Discharge Elimination System (NPDES) under section 402 of the Clean Water Act, as amended.
  - a facility shall not cause a discharge of dredged material or fill material to waters of the United States that is in violation of the requirements under section 404 of the Clean Water Act, as amended.
  - a facility or practice shall not cause non-point source pollution of waters of the United States that violates applicable legal requirements implementing an areawide or Statewide water quality management plan that has been approved by the Administrator under section 208 of the Clean Water Act, as amended.

Analyses completed for the hazard potential classification and hydrologic and hydraulic (H&H) assessment of the BAP complex are described in this Report. The data and analyses provided in the following sections are based on BAP complex design information obtained from historical drawings (included in APPENDIX A) and topographic survey information from the U.S. Geological Survey (USGS) National Map 3D Elevation Program (3DEP) 1-Meter Resolution DEM (USGS 1 Meter, 2018). Site features and topography are included in Figure 2. The analysis approach and results of the H&H analyses presented in the following sections were used to evaluate the capacity requirements of the BAP complex based on the requirements included in 40 CFR. §257.82.

## 2 BACKGROUND

The former Kanawha Power Station utilized multiple surface impoundments, the East Fly Ash (EFA) Pond and the Bottom Ash Pond (BAP) complex, to manage sluiced ash from the facility during its operating life. This Report evaluates the capacity requirements of the BAP complex based on the inflow design flood. The BAP complex is located west of the former Plant and is classified as a legacy CCR impoundment under the United States Environmental Protection Agency's (USEPA) Legacy CCR Final Rule (May 28, 2024), which established regulatory requirements for legacy CCR surface impoundments and CCR management units.

The Kanawha River Site is located approximately 0.5 miles southeast of Glasgow, West Virginia. Construction of the Kanawha River Plant began in October 1950, and the plant reached commercial operation in August 1953. The Kanawha River Plant ceased operating in May 2015. The BAP complex consists of the North BAP, the South BAP, and the Clearwater Pond. The site covers approximately 8 acres and is bounded by the Kanawha River on the west, the town of Glasgow on the North, and the railroad on the east.

The BAP complex is generally an incised surface impoundment with only the west portion of the Clearwater Pond contained by an approximate 7-foot-tall dike built up above original grade. The water level of the Clearwater Pond is operated and maintained below the downstream toe of the dike. The exterior slope of the western Clearwater Pond dike is approximately 2 Horizontal to 1 Vertical (2H: 1V). The remainder of the pond complex is incised, with a surrounding ground elevation of 623 feet mean sea level (MSL). The ponds are predominantly incised as the powerplant grades were elevated for flood protection to an elevation of 623 feet MSL, and the BAP area was used as a borrow source. The diked portion of the Clearwater Pond was constructed due to its proximity to the western property line.

The BAP complex discharges through concrete risers located within the Clearwater Pond and the North BAP that convey water to the South BAP riser structure, which discharges through a 36-inch concrete pipe at Outfall 001 into the Kanawha River. Figure 2 shows the hydraulic features associated with the BAP complex.

## 3 HAZARD POTENTIAL CLASSIFICATION ASSESSMENT

WSP conducted a breach analysis of the BAP complex according to the requirements of 40 CFR §257.73(a) using the 2-dimensional (2D) routines in the U.S. Army Corps of Engineers (USACE) Hydrologic Engineering Center's River Analysis System (HEC-RAS) Version 6.6 computer modeling program. The breach model includes the combined Clearwater Pond, North BAP, and South BAP with the most recent LiDAR obtained from the United States Geological Survey (USGS) National Map. A summary of the model inputs, calculations, and results is included in APPENDIX B. Figure 3 depicts the potential area of inundation in the event of a sunny-day, catastrophic failure of the BAP complex.

As shown in Figure 3, 118 potential properties with hazard impacts are located within the breach inundation zone. The residential building with the greatest potential for flooding may experience a flood depth up to 3.5 feet. Refer to APPENDIX B, which lists the potential flooding at all structures within the breach inundation zone. Due to the large number of potentially impacted structures and a peak flooding depth at a residential structure exceeding 2 feet, it is concluded that a failure of the BAP complex would likely result in a probable loss of human life. The BAP complex, therefore, meets the definition of a high-hazard potential CCR surface impoundment in accordance with the CCR Rule.

## 4 INFLOW DESIGN FLOOD CONTROL SYSTEM

In accordance with 40 CFR §257.82(a), the inflow design flood control system must be capable of adequately managing the flows into the CCR unit during and following the peak discharge of the inflow design flood, as well as managing the flows from the CCR unit to collect and control the peak discharge resulting from the inflow design flood. The following sections describe the flood control systems in place, present the analysis performed to evaluate the adequacy of the existing structures, and list any operational limitations required to maintain adequate flood control measures as required by 40 CFR §257.82(a).

### 4.1 Existing Flood Control Infrastructure

The BAP complex receives offsite runoff from the area northeast of the railroad tracks through two culvert pipes that collect water running off the upgradient hillside and convey the water beneath the railroad tracks into the concrete riser structures for the Clearwater Pond (Culvert 5) and the North BAP (Culvert 4) (see Figure 2). This water is conveyed through the ponds' outlet structures to the outlet structure for the South BAP (Manhole 3), where it is discharged through a 36-inch diameter concrete outlet pipe to the Kanawha River.

In addition, inflows to the system include precipitation falling directly into and around the ponds, as well as additional sources (such as sump pumps and drains) routed from the former facility area to the BAP complex. The Clearwater Pond, North BAP, and South BAP are hydraulically connected, and the water levels within these impoundments will seek equilibrium when the water surface elevation exceeds the invert elevation of the riser structures.

Outflow from each pond gravity drains through a concrete riser structure. The riser structure in the Clearwater Pond (Manhole 1) consists of a V-notch weir, while the riser structure (Manhole 2) in the North BAP consists of an open-top weir. The structures in the Clearwater Pond and North BAP discharge through gravity drainage pipes, which subsequently converge into a single pipe at Manhole 3 located within the South BAP. From Manhole 3, the outfall from the pond flows via gravity to the Kanawha River and discharges at Outfall 001.

### 4.2 Capacity Criteria

Flood control infrastructure must adequately manage flow entering the CCR unit during and following the design flood specified by the impoundment hazard potential classification. For the BAP complex, a high hazard potential classification assessment triggers the use of the Probable Maximum Precipitation (PMP) event in the inflow design flood control system plan under 40 CFR §257.82. Additionally, the CCR Unit must adequately manage flows exiting the impoundment during and following the design storm. This requirement is interpreted as the prevention of embankment overtopping, while maintaining appropriate freeboard, during the design storm.

## 5 HYDROLOGIC ANALYSES

WSP completed this H&H assessment of the BAP complex during a PMP event under 40 CFR §257.73. The analyses determine the precipitation inputs, watershed characteristics, runoff volumes, and inflow hydrographs used to assess the adequacy of the existing flood control system under the applicable design storm conditions.

### 5.1 Precipitation & Inflow Sources

The design storm rainfall depth was obtained from the USACE Hydrometeorological Report No. 51 (HMR-51) – *Probable Maximum Precipitation Estimates, United States East of the 105th Meridian*. The PMP for the 6-hour duration storm is 27.9 inches. The Natural Resources Conservation Service (NRCS) 6-hour storm distribution was applied to the PMP event.

Inflow sources to the BAP complex considered in the hydrologic analyses only include stormwater runoff from the upgradient drainage area northeast of the railroad that drains into the impoundments. Other potential inflow sources, including rainfall directly into the BAP complex, were conservatively ignored in the analysis, as the inflow design flood from this large drainage area during a PMP event is significantly greater than these other inflows.

## 5.2 Watershed Delineation

The drainage areas contributing runoff to the BAP complex were delineated using ESRI ArcGIS Pro based on topographic data derived from the USGS West Virginia Statewide 2018 LiDAR dataset. Two primary drainage basins, northeast of the railroad, contributing flow to the BAP complex were identified: the North subbasin and the South subbasin, as shown on Figure 2. The contributing drainage areas for the North and South subbasins are 166 acres and 76 acres, respectively. Other flows into the BAP complex were ignored as the associated runoff volumes are insignificant compared to the runoff generated from this upgradient hillside during the inflow design flood event.

An overall Soil Conservation Service (SCS) curve number for the contributing drainage areas was developed based on the National Engineering Handbook (NEH) Part 630, Chapter 9, which provides a breakdown of curve numbers for each soil type and land use combination. Soil data were obtained from the NRCS online soils database, and land use areas were delineated based on aerial imagery. The curve number (CN) is a measure of runoff potential and is based on the percent impervious and land use characteristics within the watershed area. These values are published by the Multi-Resolution Land Characteristics Consortium as part of their National Land Cover Database (NLCD). Refer to APPENDIX B for a comprehensive description of the watershed hydrology and parameter development. The CN for antecedent runoff condition II (ARC-II) was chosen based on the recommended CNs given in Tables 9-1, 9-2, and 9-5 of the NEH Part 630. A CN of 65 and 66 was selected for the North and South drainage basin areas, respectively.

## 5.3 Runoff Volume Analyses

The BAP complex system was modeled by importing the information provided in the preceding sections into a hydrologic model developed using the Autodesk Storm and Sanitary Analysis (SSA), Version 2022. A detailed memorandum outlining the runoff volume analysis of the stormwater system is provided in APPENDIX C. The total runoff volumes for the North and South subbasins are 309.4 acre-feet and 144.0 acre-feet, respectively, with the total inflow volume of 453.4 acre-feet from the two subbasins. The inflow hydrographs for the North and South subbasins are presented in Chart 1.




Chart 1: Inflow Hydrograph for the North and South Subbasins

Stormwater runoff from the two subbasins during the PMP event upstream of the railroad tracks results in a peak inflow rate into the BAP complex of approximately 3,800 cubic feet per second and a total inflow volume of approximately 453 acre-feet.

### 5.4 Stage Storage Curves

WSP developed the reservoir stage-storage relationship using topography derived from the USGS West Virginia Statewide 2018 LiDAR dataset. The reservoir areas were extrapolated beneath the water level, assuming a pond bottom elevation of 602.0 feet and side slopes of approximately 3 horizontal to 1 vertical (3H:1V) side slope as indicated in the historical drawings. Chart 2 provides the combined staged-storage curve for the combined BAP complex. Individual staged-storage curves for each impoundment within the BAP complex are provided in APPENDIX C .

As shown in Chart 2, the total combined staged storage for the BAP complex is 73.5 acre-feet at elevation 623 feet MSL.




Chart 2: Combined Stage Storage Curve for the BAP Complex

### 5.5 Inflows and Outflows During Design Storm Event

The total available storage volume for the BAP complex is less than the reservoir capacity required to contain the inflow design flood during the PMP event. This assessment assumes that all runoff from the North and South subbasins that is not routed through the 36-inch diameter outlet pipe to the Kanawha River will flow into the impoundments. However, as the two culverts beneath the railroad tracks are insufficient to convey water to the BAP complex during a PMP event, the stormwater inflows from the North and South subbasins would overtop the railroad and partially flow into the ponds.

To evaluate the extent of flow into the BAP complex, WSP routed runoff from the North and South subbasins during the PMP 6-hour event using the HEC-RAS program, Version 6.6. The downstream boundary condition was set to the 100-year flood elevation of 610 feet MSL in the Kanawha River. The analysis considered overland flow routing based on existing topography and did not incorporate the conveyance structures. Image 1 below illustrates the resulting inundation extent and flow directions during the PMP 6-hour event.




Image 1: Inundation Extents and Flow Direction during the PMP 6-hour Event

From this analysis, WSP estimates that approximately 313 acre-feet of inflow would be conveyed from the North and South subbasins into the BAP complex at a maximum flow rate of approximately 2,760 cubic feet per second.

## 6 SUMMARY

WSP conducted a Hazard Potential Classification Assessment and prepared an Inflow Design Flood Control System Plan for the BAP complex in accordance with the requirements of 40 CFR §257.73(a) and 40 CFR §257.82. The assessment included a dam breach analysis to evaluate downstream consequences associated with a hypothetical failure of the impoundment system, as well as H&H analyses to evaluate the adequacy of the existing flood control infrastructure under the applicable inflow design flood conditions.

The dam breach analysis indicates that a failure of the BAP complex would result in inundation of numerous downstream properties with peak flood depths at residential structures exceeding 2 feet, which would result in a probable loss of human life. Based on these findings, the BAP complex meets the definition of a high hazard potential CCR surface impoundment under the CCR Rule.

Based on site observations, review of available information, and the H&H analyses described herein (including associated calculations provided in APPENDIX C), the subject ponds in the BAP complex have flood control systems that are not adequate to manage flow into and from the units under the applicable inflow design flood.

Hydrologic analyses performed using the PMP event demonstrate that routing runoff from the North and South subbasins will direct approximately 313 acre-feet of stormwater into the BAP complex over an approximate 5-hour period. This inflow into the BAP complex far exceeds the existing capacity of the complex, which is approximately 73 acre-feet.

Although conveyance limitations beneath the railroad tracks reduce the total volume of runoff entering the impoundments through these conveyance pipes, routing analyses indicate that the outflows from the North and South subbasins would overtop the railroad during the design storm and flow into the BAP complex, exceeding the available stage-storage capacity. As a result, the BAP complex would overtop and convey stormwater into the adjacent neighborhood located north of the BAP complex. The CCR unit cannot adequately manage flow following the peak discharge of the inflow design flood as required by the CCR Rule.

WSP recommends evaluating alternative flood control measures, such as bypassing the flow from the North and South subbasins or modifying the outlet works from the BAP complex. Modifying the outlet works could include adding additional conveyance piping or the addition of alternative spillway capacity (e.g., an open-channel spillway), to provide sufficient discharge capacity and convey flow from the BAP complex to the Kanawha River in accordance with applicable CCR Rule requirements.

## 7 REFERENCES

USEPA, 2015. 40 CFR Parts §257, Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule. April 17, 2015.

Schreiner, L. C., & Riedel, J. T. (1978). Hydrometeorological Report No. 51: Probable Maximum Precipitation Estimates, United States East of the 105th Meridian. U.S. Department of Commerce, National Oceanic and Atmospheric Administration, and U.S. Department of the Army, Corps of Engineers.

US Department of Agriculture (USDA), Natural Resources Conservation Service (NRCS), National Engineering Handbook Part 630 Hydrology.

U.S. Geological Survey, 20231201, USGS 1 Meter 17 x46y423 WV\_FEMAR3\_Southcentral\_2018\_D19.

# Signature Page

WSP is pleased to have provided this Hazard Potential Classification Assessment and Inflow Design Flood Control System Plan for the Bottom Ash Pond at the former Kanawha River Power Plant. Any questions concerning this document should be directed to the undersigned.

## WSP USA Inc.



Yong Cheng Soo, PE (GA, SC)  
*Senior Consultant, Water Resources Engineer*






Naveen Kumar Ganji, PE (GA, TN, TX, VA)  
*Senior Consultant, Geotechnical Engineer*



Steven J. Moeller, PE (AL, GA, NC, SC, TN, WV)  
*Senior Vice President*

YC/NG/SM/yc

Figures



1000 0 1000 2000 FT  
 REFERENCES:  
 USGS 7.5 MINUTE QUADRANGLE, CEDAR GROVE, 2023.

DATE	NO.	DESCRIPTION	APPD.

**REVISIONS**

THIS DRAWING IS CLASSIFIED AS:

REFERENCE AEP'S CORPORATE INFORMATION SECURITY POLICY

THIS DRAWING IS THE PROPERTY OF THE **AMERICAN ELECTRIC POWER SERVICE CORP.** AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE **AEP SERVICE CORP.** OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.


APPALACHIAN POWER COMPANY  
**BOTTOM ASH POND**  
**FORMER KANAWHA RIVER POWER PLANT**  
 GLASGOW WEST VIRGINIA

**SITE LOCATION PLAN**

UNIT: FEET	DRAWING NUMBER: 1 OF 2	REV: -
SCALE:	APPROVED BY	
DR: CCP		
CH: NG		
SUP: NG		
ENG: SJM		
DATE: 01/05/2026		


3348 Peachtree Road NE  
 Suite 1100  
 Atlanta, GA 30326

**AEP SERVICE CORP.**  
 1 RIVERSIDE PLAZA  
 COLUMBUS, OH 43215



- LEGEND**
- CULVERT
  - ▲ OUTFALL
  - RISER
  - SUBBASIN

**REFERENCE**  
 1. MAPPING IS BASED ON ELEVATION PRODUCT: U.S. GEOLOGICAL SURVEY, 2018.



CLIENT  
 APPALACHIAN POWER COMPANY  
 FORMER KANAWHA RIVER POWER PLANT

PROJECT  
 BOTTOM ASH POND COMPLEX

**TITLE**  
**BAP COMPLEX SITE CONDITIONS PLAN AND DRAINAGE BASINS**

CONSULTANT	YYYY-MM-DD	2026-03-04
	PREPARED	YCS
	DESIGN	YCS
	CHECKED	XXX
	REVIEWED/APPROVED	SJM

PROJECT No.  
 US0041868.3860

Rev.  
 0





























FIGURE  
**2**

Path: C:\Users\USV97012\ANWD\0368\AEP\KAWAHA\_River\_CCR\_Library\Utility\_Engineering\_Support\_Documents\Technical\_Drawings\Scale\KAWAHA\_AEP\KAWAHA\_AEP.dwg

IF THIS MEASUREMENT DOES NOT MATCH WHAT IS SHOWN, THE SHEET HAS BEEN MODIFIED FROM ANS B

**APPENDIX A**

**BAP Complex Historical Drawings**



**EXCAVATION**

CINDER AREA	162,000 cu yd
CUT AREAS TO EL 625	65,000
CUT RIVER BANK FOR COAL DUMP	9,000
PLANT EXCAVATION 1 <sup>st</sup> STEP	125,000
PLANT EXCAVATION 2 <sup>nd</sup> STEP	43,000
<b>TOTAL</b>	<b>404,000 cu yd</b>

**FILL**

FILL AREA TO EL 625 GRADE	55,000 cu yd
FILL AREA TO EL 625 GRADE	167,000
PLANT BACK FILL (to EL 625)	165,000
<b>TOTAL</b>	<b>387,000 cu yd</b>

**NOTE:**  
The above quantities are for the area West of Matchline. Quantities of earthwork East of Matchline are shown on Drawing S-3344-3356 which shows cut and fill work for the 14th year. The amount of cut will balance the amount of fill if the quantities shown on this drawing and drawing S-3344-3356.

Additional material required to grade this area to EL 625 from first yard station shown on Dwg S-3344-3356.

Earth work and Drains by Bosco & Ritchie Inc.

DRAINAGE (MANHOLES) DWG S-3344-3357  
PLANT EXCAVATION - FIRST STEP  
SEE DWG S-3344-3355  
BORING DATA DWG S-3344-3356  
BORING LOCATION PLAN S-3344-3354

NO.	REVISION	DATE	BY	CHKD.
1	Revised Disposal Area			
2	Plant work changes			
3	Dimensions Changed			
4	Dimensions Changed			
5	Dimensions Changed			
6	Dimensions Changed			
7	Dimensions Changed			
8	Dimensions Changed			
9	Dimensions Changed			
10	Dimensions Changed			
11	Dimensions Changed			
12	Dimensions Changed			
13	Dimensions Changed			
14	Dimensions Changed			
15	Dimensions Changed			
16	Dimensions Changed			
17	Dimensions Changed			
18	Dimensions Changed			
19	Dimensions Changed			
20	Dimensions Changed			

**REVISIONS**

NO.	REVISION	DATE	BY	CHKD.
1	Headwall 3 Revised			
2	Grading to EL 625 added			
3	Quantity of earth handling revised			
4	Quantity of earth handling revised			
5	Quantity of earth handling revised			
6	Quantity of earth handling revised			
7	Quantity of earth handling revised			
8	Quantity of earth handling revised			
9	Quantity of earth handling revised			
10	Quantity of earth handling revised			
11	Quantity of earth handling revised			
12	Quantity of earth handling revised			
13	Quantity of earth handling revised			
14	Quantity of earth handling revised			
15	Quantity of earth handling revised			
16	Quantity of earth handling revised			
17	Quantity of earth handling revised			
18	Quantity of earth handling revised			
19	Quantity of earth handling revised			
20	Quantity of earth handling revised			

**AMERICAN GAS & ELECTRIC SERVICE CORPORATION**  
30 CHURCH STREET NEW YORK


**EXCAVATION & GRADING PLAN**

**APPALACHIAN ELECTRIC POWER CO.**  
KANAWHA RIVER PLANT  
GLASGOW, WEST VIRGINIA

SCALE: 1" = 50'-0"

DATE: 12/15/37

DR. NO. S-3344-3356



**GENERAL NOTES**  
 PERMEABILITY OF THE BOTTOM ASH IS  $5 \times 10^{-3}$  CM/SEC.  
**REFERENCE DWGS**  
 EXCAVATION/GRADING PLAN S-3344-3807  
 UNDER YARD DR. STRUCTURES S-3344-3368  
 BOTTOM STORAGE AREA SECTS - S-3344-3851  
 FOR ADDITIONAL REF DWGS SEE 12-11341-3851  
 12-11341-3852 - OVERFLOW STRUCTURE  
 3 SUPPORTS FOR DISTRIBUTION LINE  
 12-11341-3853 - TROUGH SUPPORTS FOR OVERFLOW STRUCTURE


DATE	NO.	DESCRIPTION	APPR.
<b>REVISIONS</b>			

"THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED FROM CONSIDER THAT IT IS NOT TO BE REPRODUCED OR COPIED, IS WHOLE OR IN PART, OR USED FOR PUBLISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE A.E.P. SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST."


APPALACHIAN POWER CO.  
 KANAWHA RIVER PLANT  
 GLASGOW WEST VA.

BOTTOM ASH STORAGE AREA  
 MODIFICATION

DR. NO. 12-11341-3850			
ARCH.	ELEC.	MECH.	CIV.
SCALE: 1"=40'	DESIGNED BY: <i>[Signature]</i>		
DR. LEN	CHECKED BY: <i>[Signature]</i>		
DATE: 4/11/77	AMERICAN ELECTRIC POWER SERVICE CORP.		



SECTION A-A



SECTION B-B

DATE	NO.	DESCRIPTION	APPR.
REVISIONS			

"THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST."

APPALACHIAN POWER CO.  
KANAWHA RIVER PLANT  
GLASGOW WEST VA.

BOTTOM ASH STORAGE AREA  
MODIFICATION  
SECTIONS

DR. NO. 12-11341-3851

ARCH.	ELEC.	MECH.	STR.
SCALE: 3/4" = 1'	ENGINEERING DIV.		
DR. LEN	DESIGNED BY: <i>[Signature]</i>		
CH.	CHECKED BY: <i>[Signature]</i>		
SO. LDR. M.E.	DATE: 4/11/77		

AMERICAN ELECTRIC POWER SERVICE CORP.



**APPENDIX C**

**Hydrology and Hydraulic Analysis**

Subject:	H&H ANALYSIS		
Date:	March 4, 2026	Made By:	YCS
Project No.:	US0041868.3860	Checked By:	MT
Project Short	AEP/ Ash Pond/ WV	Reviewed By:	SJM

**OBJECTIVE**

The objective of this report is to demonstrate engineering calculations for the hydraulic capacity of the Bottom Ash Pond (BAP) complex as required by the United States Environmental Protection Agency’s final rule for Disposal of CCR from Electric Utilities. The BAP Complex, owned by American Electric Power Company, Inc. (AEP), is located along West Virginia State Route 60, adjacent to the Kanawha River. Figure below shows the drainage basins at the BAP complex.





Subject: H&H ANALYSIS  
 Date: March 4, 2026 Made By: YCS  
 Project No.: US0041868.3860 Checked By: MT  
 Project Short AEP/ Ash Pond/ WV Reviewed By: SJM

**TOTAL INFLOW VOLUME**

Total drainage areas (North Subbasin & South Subbasin) were delineated using U.S. Geological Survey National Map 3D Elevation Program (3DEP) 1-Meter Resolution DEM (USGS 1 Meter, 2018). Runoff characteristics were developed based on the Soil Conservation Service (SCS) methodologies as outlined in TR-55. Time of Concentration calculations were developed using the Technical Paper 55 Urban Hydrology for Small Watersheds (TR-55) method for computation of travel time and time of concentration.

	North	South	
Drainage Basin Area	166	76	acres
Curve Number	65	66	
Time of Concentration (Tc)	0.4	0.3	hours
Time of Concentration (Tc)	27	18	minutes

**Rainfall**

A summary of the design storm parameters and rainfall distribution methodology for these calculations is summarized below

Event	Depth (inches)	Temporal Distribution	Depth Source
PMP, 6-Hour	27.94	NRCS 6-Hour	HMR-51

**Curve Number**

The curve number (CN) for antecedent runoff condition II (ARC-II) was chosen based on the recommended curve numbers given in Tables 9-1, 9-2, and 9-5 of the National Engineering Handbook (NEH) Part 630. Soil types were obtained from the Natural Resources Conservation Service's online soils database. Land use areas were delineated based on aerial imagery.

Soil Group	Type	CN	North		South	
			Area (acres)	CN*Area	Area (acres)	CN*Area
B	Woods	60	127.1	7,628	52.7	3,160
	Developed, Open Space	69	14.4	991	4.8	332
	Developed, Medium Intensity	85	0.0	0	6.9	583
	Developed, High Intensity	92	11.8	1,085	0.0	0
C	Woods	73	5.4	391	5.4	393
	Developed, Open Space	79	0.0	0	3.9	307
	Developed, Medium Intensity	90	5.4	482	0.0	0
D	Developed, Low Intensity	86	0.0	0	2.8	244
	Developed, Medium Intensity	92	1.9	171	0.0	0
			165.9	10,748	76.5	5,020
CN = S(CN*Area)/S(Area)			CN	65	CN	66

**Subject:** H&H ANALYSIS  
**Date:** March 4, 2026 **Made By:** YCS  
**Project No.:** US0041868.3860 **Checked By:** MT  
**Project Short:** AEP/ Ash Pond/ WV **Reviewed By:** SJM

**Time of Concentration**

The time of concentration is calculated using the Watershed Lag Method from the National Engineering Handbook Part 630, Chapter 15. The slope is estimated in ArcGIS based on the Lidar dataset dated 2018, and the soil data from USDA SSURGO Database.

	North	South	
Watershed Flow Length ( $\ell$ ) =	4,487	2,820	feet
Average Watershed Slope (Y) =	36.00	36.50	%
Maximum Potential Retention (S) =	5.43	5.23	inches
Lag (L) =	0.27	0.18	hours
<b>Time of Concentration (<math>T_c</math>) =</b>	<b>0.45</b>	<b>0.30</b>	<b>hours</b>
<b>Time of Concentration (<math>T_c</math>) =</b>	<b>27</b>	<b>18</b>	<b>minutes</b>

$$\ell = 209A^{0.6}$$

$$S = \frac{1000}{cn'} - 10$$

$$L = \frac{\ell^{0.8}(S + 1)^{0.7}}{1900Y^{0.5}}$$


$$T_c = 0.6L$$

**Runoff Volume**

Runoff values were determined by importing the characteristics developed above into a hydrologic model with the Autodesk Storm and Sanitary Analysis 2022 program.

Total Runoff Volume from North Subbasin (N)	309.4	acre-ft
Total Runoff Volume from South Subbasin (S)	144.0	acre-ft
Total Inflow Volume (N+S)	453.4	acre-ft

**INFLOW HYDROGRAPH**



Subject: H&H ANALYSIS

Date: March 4, 2026

Made By: YCS

Project No.: US0041868.3860


Checked By: MT

Project Short AEP/ Ash Pond/ WV

Reviewed By: SJM

**TOTAL OUTFLOW VOLUME**

Water from impoundments exits the flood control system through a 36-inch reinforced concrete pipe (RCP). The pipe conveys flows by gravity to the Kanawha River via Outfall 001. The max discharge of the RCP was estimated considering a full pool at 623 ft-msl in the impoundments.




Full Pool Elevation	623	ft-msl
Pipe Diameter	36	inch
Pipe Length	675	feet
Pipe Inlet Invert Elevation	593	feet
Pipe Outlet Invert Elevation	591	feet
100-Year Flood Elevation	610	feet

Max Pipe Discharge	108	cfs	(free)
Max Pipe Discharge @ 100-Yr Flood	72	cfs	

**Subject:** H&H ANALYSIS  
**Date:** March 4, 2026 **Made By:** YCS  
**Project No.:** US0041868.3860 **Checked By:** MT  
**Project Short:** AEP/ Ash Pond/ WV **Reviewed By:** SJM

**RESERVOIR CAPACITY REQUIRED DURING PMP EVENT**

Reservoir capacity required during the PMP event was determined using the SSA. The inflow and outflow hydrograph of the BAP complex is shown as below.



Required Reservoir Capacity,  $V_R$  **402.8** acre-ft

**BAP COMPLEX STORAGE VOLUME**

Total Clearwater Pond Volume (A)	26.3	acre-ft
Total North Pond Volume (B)	21.3	acre-ft
Total South Pond Volume (C)	26.1	acre-ft
Total Storage Volume, $V_s$ (A+B+C)	<b>73.6</b>	acre-ft

$V_s < V_R$


The total storage volume for BAP complex is less than the required reservoir capacity during the PMP event. This assumes that all water from the North and South Subbasins that is not routed through the 36-inch outlet pipe will flow into the impoundments.

Subject: H&H ANALYSIS  
 Date: March 4, 2026  
 Project No.: US0041868.3860  
 Project Short: AEP/ Ash Pond/ WV

Made By: YCS  
 Checked By: MT  
 Reviewed By: SJM


**STAGE STORAGE CURVE**

**CLEARWATER POND**



Elevation Volume		
(feet-msl)	(acre-feet)	
602	0.0	Pond Bottom
604	1.4	
606	3.1	
608	4.9	
610	6.9	
612	9.2	
613	10.5	Normal Pool
614	11.8	
616	14.5	
618	17.5	
620	20.8	
622	24.4	
623	26.3	Top of Dam

**NORTH POND**




Elevation Volume		
(feet-msl)	(acre-feet)	
602	0.0	Pond Bottom
604	0.4	
606	1.1	
608	2.1	
610	3.4	
612	5.1	
614	7.2	
616	9.7	
617	11.0	Normal Pool
618	12.5	
620	15.7	
622	19.3	Top of Dam
623	21.3	



Subject: H&H ANALYSIS  
Date: March 4, 2026 Made By: YCS  
Project No.: US0041868.3860 Checked By: MT  
Project Short AEP/ Ash Pond/ WV Reviewed By: SJM

SOUTH POND




Elevation Volume		
(feet-msl)	(acre-feet)	
602	0.0	Pond Bottom
604	0.6	
606	1.5	
608	2.8	
610	4.5	
612	6.7	
614	9.3	
616	12.4	
617	14.0	Normal Pool
618	15.8	
620	19.6	
622	23.8	Top of Dam
623	26.1	

Subject: H&H ANALYSIS  
 Date: March 4, 2026  
 Project No.: US0041868.3860  
 Project Short: AEP/ Ash Pond/ WV

Made By: YCS  
 Checked By: MT  
 Reviewed By: SJM

**MODEL RESULTS**

Runoff from the North and South subbasins during the PMP 6-hour event was routed using the Army Corps of Engineers HEC-RAS program Version 6.6. The downstream boundary condition was set to the 100-year flood elevation of 610 feet-msl in the Kanawha River. The analysis considered overland flow routing based on topography without incorporating conveyance structures. Figure below illustrates the resulting inundation extent and flow directions during the PMP 6-hour event.



Subbasin	Inflow	Profile 1	Profile 2	Profile 3
	Peak flow (cfs)	3834	412	2760
Volume (acre-ft)	453	60	313	73

The above analysis shows that routing the outflow from the North and South Subbasins combined will direct approximately 313 acre-ft of stormwater into the BAP complex over an approximate 5-hour period. This inflow into the BAP complex far exceeds the existing capacity of the complex which is 73.6 acre-ft. Thus, the BAP complex would overtop and convey stormwater into the adjacent neighborhood located to the north of the complex. The CCR unit cannot adequately manage flow following the peak discharge of the inflow design flood as required by the CCR Rule.

