

Indiana Michigan Power Co.
Rockport Plant
West Bottom Ash Pond
Hazard Potential Classification Assessment

AEP has performed an evaluation to classify the above CCR Surface Impoundment in accordance with FEMA's Hazard Potential Classification System for Dams. These guidelines evaluate the consequences of a potential failure not the likelihood of a failure. Guidelines that were developed and utilized are included below.

Hazard Potential Classification Systems (from FEMA 333, April 2004)

1. Low Hazard Potential

Dams assigned the Low Hazard potential classification are those where failure or mis-operation results in no probable loss of human life and low economic and/or environmental losses. Losses are principally limited to the owner's property.

2. Significant Hazard Potential

Dams assigned the Significant Hazard potential classification are those dams where failure or mis-operation results in no probable loss of human life but can cause economic loss, environmental damage, disruption of lifeline facilities, or can impact other concerns. Significant hazard potential classification dams are often located in predominantly rural or agricultural areas but could be located in areas with population and significant infrastructure.

3. High Hazard Potential

Dams assigned the High Hazard potential classification are those where failure or mis-operation will probably cause loss of human life.

The West Bottom Ash Pond is located at the Rockport Plant and approximately 4000 feet from the Ohio River, in Spencer County near the City of Rockport. A review of downstream conditions indicates that the impact of the failure or mis-operation of the West Bottom Ash Pond would likely result in minor economic losses and limited environmental impacts on company property but would not be expected to cause a loss of human life. The West Bottom Ash Pond is not classified by IDNR. The US EPA CCR Impoundment Assessment Report listed this ash pond as Low Hazard.


Furthermore, there has been no changes in classification by IDNR Dam Safety nor has there been any other physical changes that would warrant a change in the classification.

Based on the FEMA Hazard Potential Classification Systems for Dams and on the discussion above, West Bottom Ash Pond is classified as a **Low Hazard Potential Dam**.

Professional Engineer's Certification:

I certify that this Hazard Potential Classification Assessment is in accordance with the requirements of section 40 CFR 257.73 (a)(2)(i).

Daniel W. Pizzino, P.E.



7-21-2026

