Periodic Inflow Design Flood Control Plan

Date:	September 18, 2026
Document:	Periodic Inflow Design Flood Control Plan – 40 CFR 257.82 & 30 TAC§ 352.821
Plant:	Pirkey Power Plant
Unit:	West Bottom Ash Pond

As of May 5, 2023, the Pirkey Power Plant – West Bottom Ash Pond was closed by removal in accordance with 40 CFR 257.102(c)(1) and 30 TAC §352.1221(a) and the facility's Written Closure Plan.

Since closure by removal is complete, the facility no longer meets the definition of a CCR surface impoundment, and therefore the Inflow Design Flood Control Plan required under 40 CFR 257.82 and 30 TAC §352.821 is no longer applicable.

The Closure Completion Notification for Closure by Removal is attached for reference. This posting constitutes the final publication of this document; no further postings will be made.

Closure Completion Notification for Closure by Removal

May 5, 2023
Closure Completion Notification
Henry W. Pirkey Plant
West Bottom Ash Pond

On May 5, 2023, the Henry W. Pirkey, West Bottom Ash Pond was closed by removal in accordance with 40 CFR 257.102 and the most recent Written Closure Plan. This notification is being placed in the operating record in accordance with 40 CFR 257.102(h). This notification being made to demonstrate compliance with 40 CFR 257.103(f)(2) which allowed Pirkey West Bottom Ash Pond to receive CCR and non-CCR wastestreams after April 11,2021.

The State of Texas received partial delegation from USEPA on June 1, 2021. Parts of 40 CFR 257.103 were subsequently modified by USEPA Rulemaking and were not included. Thus, these provision remains under USEPA jurisdiction. However, 40 CRF 257.102 Criteria for Conduction the Closure and Retrofit of CCR Units has been delegated. Therefore, final review and approval of closure will be determined by TCEQ.

CLOSURE CERTIFICATION BY QUALIFIED PROFESSIONAL ENGINEER

I certify that the Pirkey Power Plant's West Bottom Ash Pond has been closed in accordance with the most recent written closure plan specified by paragraph 40 CFR §257.102(b) and 30 TAC §352.1221, and the requirements of section 40 CFR §257.102 and 30 TAC §352.1221.



David Anthony Miller

Printed Name of Licensed Professional Engineer

David Anthony Miller

Signature

112498	Texas	05.05.2023
License Number	Licensing State	Date

West Bottom Ash Pond CCR Removal Certification
H.W. Pirkey Power Plant

The CCR Removal Certification for the H.W. Pirkey Power Plant West Bottom Ash Pond was prepared by Akron Consulting, LLC (TBPE Firm #14014). This Certification/Statement of Professional Opinion is limited to the information available to Akron at the time the report was written. On the basis of and subject to the foregoing, it is my professional opinion as a Professional Engineer licensed in the State of Texas, that the report has been prepared in accordance with good and accepted engineering practices as exercised by other engineers practicing in the same discipline(s), under similar circumstances and at the time and in the same locale. It is my professional opinion that the removal of the CCR material in the West Bottom Ash Pond was performed in accordance with the current requirements of 40 CFR § 257.102 (30 TAC 352.1221) and Section 4.0 of the most recent written Closure Plan.

The use of the words "certification" and/or "certify" in this document shall be interpreted and construed as a Statement of Professional Opinion, and is not and shall not be interpreted or construed as a guarantee, warranty or legal opinion. This certification in no way relieves the Owner or Operator of the facility of his/her duty to fully implement the other requirements outlined in the entire section of 40 CFR § 257.

Engineer: Lane D. Roberts

Registration Number: 105135

State: Texas

Date: 12/30/2022



AKRON CONSULTING, LLC
431 N. CENTER ST.
LONGVIEW, TX 75601
TBPE Firm Reg. # 14014
(O) 903-236-9744
(F) 903-236-9745
www.akron-consulting.com

INFLOW DESIGN FLOOD CONTROL PLAN
PERIODIC 5-YEAR REVIEW

30 TAC 352.821 (40 CFR 257.82)

East and West Bottom Ash Pond

Pirkey Power Plant
Hallsville, Texas

October, 2021

Prepared for: Southwest Electric Power Company – Pirkey Power Plant

Hallsville, Texas

Prepared by: American Electric Power Service Corporation

1 Riverside Plaza

Columbus, OH 43215


GERS – 21 – 052

INFLOW DESIGN FLOOD CONTROL PLAN
PERIODIC 5-YEAR REVIEW
CFR 257.82
PIRKEY POWER PLANT
EAST AND WEST BOTTOM ASH POND

PREPARED BY Brett A. Dreger DATE 10/5/2021
Brett A. Dreger, P.E.

REVIEWED BY _____ DATE 10-05-2021
Shahriyar S. Baig, P.E.

APPROVED BY Gary F. Zych DATE 10/6/2021
Gary F. Zych, P.E.
Manager – AEP Geotechnical Engineering



I certify to the best of my knowledge, information, and belief that the information contained in this Inflow Design Flood Control Plan meets the requirements of 40 CFR § 257.82

Table of CONTENTS

1.0 OBJECTIVE 1

2.0 DESCRIPTION OF THE CCR UNIT 1

3.0 INFLOW DESIGN FLOOD 257.82(a)(3) 1

4.0 FLOOD CONTROL PLAN 257.82(c) 1

Attachment A: Hydrology and Hydraulic Report East and West bottom Ash Ponds

1.0 OBJECTIVE

This report was prepared by AEP- Geotechnical Engineering Services (GES) section to fulfill requirements of 30 TAC 352.821 (40 CFR 257.82) for the hydrologic and hydraulic evaluation of CCR surface impoundments. This report is a summary of the periodic 5-year review of the initial evaluation.

2.0 DESCRIPTION OF THE CCR UNIT

The Henry W. Pirkey Power Station is located at 2400 FM 3251 and south of Hallsville, Texas.
It is owned and operated by Southwest Electric Power Company (SWEPCO). The facility operates two surface impoundments for storing CCR materials called the East Bottom Ash Pond (East BAP) and the West Bottom Ash Pond (West BAP).

The East BAP is located directly adjacent to and east of the West BAP. The East BAP receives sluiced bottom ash and has a surface area of 30.9 acres and a storage capacity of 188 acre-feet. The pond is almost entirely incised, with a reported maximum embankment height of 4 feet.

The West BAP, which also receives sluiced bottom ash, is located northwest of the main plant buildings and shares its eastern border with the western border of the East BAP. The West BAP receives sluiced bottom ash and has a surface area of 30 acres and a storage capacity of 188 acre-feet. The maximum embankment height is 25 feet. The main upstream embankment slopes are 3 feet horizontal to 1 foot vertical (3:1 H:V); while the main downstream slopes area 2.5:1 H:V.

3.0 INFLOW DESIGN FLOOD 257.82(a)(3)

The facility is classified as a Low Hazard Potential Dam. This classification has not changed since the initial evaluation. The Inflow Design Flood is the 100-year storm event which is 10.3 inches during a 24 hour period.

4.0 FLOOD CONTROL PLAN 257.82(c)

The only inflows from the inflow design flood is the direct rainfall within the ponds dikes. The design to safely pass the inflow design flood without overtopping the crest of the dam is based on the normal pool being at maximum normal operating pool and utilizing the principal spillway and emergency spillway to handle the 100-year design storm without overtopping the crest of the dike.

The analysis in Attachment A includes related excerpts from the 2015 Pirkey H&H Analysis report that provides the description of the spillway system, flood storage capacity, inflow peak discharge and volume, peak discharge from the facility and maximum pool elevation.

There has not been any changes to spillway system, flood storage capacity or rainfall estimates that would change the results presented in Attachment A.

The calculations show that the facility has the capacity to manage the inflow design flood, as well as large flood events.

ATTACHMENT A

Hydrology and Hydraulic Report

East and West Ash Ponds

H.W. Pirkey Power Plant

HYDROLOGY & HYDRAULIC REPORT

EAST & WEST ASH PONDS

H.W. PIRKEY POWER PLANT – HALLSVILLE, TX

December 2015

Prepared for:

H.W. Pirkey Power Plant
2400 FM 3251
Hallsville, Texas 75650

Prepared by:

Akron Consulting, LLC
431 N. Center St.
Longview, Texas 75601
TBPE Firm # 14014



12/15/15

TABLE OF CONTENTS

HYDROLOGY & HYDRAULIC REPORT

Page No.

Introduction 1

Hydrologic Methodology 1

Hydraulic Methodology 1

East Ash Pond 2

West Ash Pond 3

Summary 3

LIST OF TABLES

Table 1 Runoff Curve Numbers for Hydrologic Soil-Cover Complexes 4
Table 2 East Ash Pond Elevation-Area-Storage Table 5
Table 3 West Ash Pond Elevation-Area-Storage Table 6

LIST OF FIGURES

Figure 1 100-year, 24-hour Runoff Depth 7

Figure 2 25-year, 24-hour Runoff Depth .. 8

HYDROLOGIC & HYDRAULIC CALCULATIONS

100-Year, 24-Hour Rainfall Event
25-Year, 24-Hour Rainfall Event

APPENDIX - A

Exhibits

Introduction

H.W. Pirkey Power Plant which is located in Hallsville, Texas is a subsidiary of American Electric Power. Plant operation requires a series of water impoundments utilized in the process of power generation, including the bottom ash ponds. The purpose of this report is to analyze and document the Hydrologic & Hydraulic characteristics of the East and West Bottom Ash Ponds at Pirkey Power Plant.

Hydrologic Methodology

This section describes the general outline of the hydrologic methodologies used to evaluate the total runoff tributary to the ponds. Specific characteristics of each pond are discussed under individual subheadings later in this report.

The East & West Ash Ponds are total containment ponds. Watershed areas contributing to the flow into these ponds are the ponds and berms/access roads themselves; in other words, these ponds have no additional runoff areas tributary to them. Therefore, a conservative approach is to adopt a curve number 100 and to consider that every inch of rainfall will directly increase the water surface elevation.

According to Natural Resource Conservation Service (formerly SCS) Technical Release 55, the peak flow is calculated using the formula:

$Q = (P-0.2S)^2 / (P+0.8S)$

where,

Q = runoff (inches)

P = rainfall (inches)

S = potential maximum retention after runoff begins (inches) = (1000/curve number) – 10

Applying a curve number of 100 to the formula above will ultimately result in Q = P (because S=0); which implies that the total runoff contributing to the flow in each of the ponds is directly a function of the rainfall event.

Hydraulic Methodology

This section describes the general outline of the hydraulic methodologies used to analyze the storage capacity of the ponds. Specific characteristics of each pond are discussed under individual subheadings later in this report.

The plant's CCR rules require that the ponds be able to accommodate the rainfall volume from a

100 year 24 hour storm without over topping. The normal operating level for each pond is established by other regulations, and it is set to 3 feet below the top of the embankment. Using actual field survey data, an elevation-area-storage table was developed for the ponds and is included in the tables section of this report. Hydraflow Hydrographs was utilized to evaluate storage capacity and the water surface elevations in each pond during the 100 year 24 hour rainfall event. The 25 year 24 hour rainfall event was analyzed as well.

Detailed Hydrologic & Hydraulic characteristics of the ponds are discussed below.

EAST ASH POND:

The East Ash Pond is located to the east of the rail road track and north of the Pirkey Power Plant. This is a coal combustion waste pond used to settle bottom ash that has been sluiced from the plant boiler. Field survey of the embankment around the impoundment indicates that the top of the embankment is at a minimum elevation of 357.0msl, which is consistent with original design drawings. Therefore, based on this top of embankment elevation, the normal operating level was established at 354.0msl. The watershed area contributing to the flow into this pond was estimated to be 29.63 acres.

The storage capacity for each pond was analyzed for a 100-yr, 24-hr rainfall event, which is 10.3 inches. Multiplying the acreage times the inches, the calculated volume of the rainfall event is 1,107,836 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,142,455 cf.

The storage capacity was also analyzed for a 25-yr, 24-hr rainfall event, which is 8.2 inches. The calculated volume of the rainfall event is 881,967 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 909,528 cf.

Water surface elevation was then calculated for the 100-yr, 24-hr rainfall event with a normal operating level (354.0msl) as the baseline elevation. Results from Hydraflow Hydrograph indicates that the water surface elevation during the 100-yr, 24-hr rainfall will be 354.99msl which is less than 357.0msl (embankment top). Results from the 25-yr, 24-hr rainfall event indicate the water surface elevation will be 354.79msl which is also less than 357.0msl (embankment top).

WEST ASH POND:

The West Ash Pond is located to the west of the rail road track and adjacent to the east ash pond. This is a coal combustion waste pond used to settle bottom ash that has been sluiced from the plant boiler. Field survey of the embankment around the impoundment indicates that the top of the embankment is at a minimum elevation of 357.0msl, which is consistent with original design drawings. Therefore, based on this top of embankment elevation, the normal operating level was established at 354.0msl. The watershed area contributing to the flow into this pond was estimated to be 33.44 acres.

As mentioned earlier the storage capacity for each pond was analyzed for a 100-yr, 24-hr rainfall event, which is 10.3 inches. Multiplying the acreage times the inches, the calculated volume of the rainfall event is 1,250,228 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,289,360 cf.

The storage capacity was also analyzed for a 25-yr, 24-hr rainfall event, which is 8.2 inches. The calculated volume of the rainfall event is 995,376 cf of water. When this rainfall event was modeled in Hydraflow Hydrographs, it generated a more conservative rainfall volume of 1,026,480 cf.

Water surface elevation was then calculated for the 100-yr, 24-hr rainfall event with a normal operating level (354.0msl) as the baseline elevation. Results from Hydraflow Hydrograph indicates that the water surface elevation during the 100-yr, 24-hr rainfall will be 355.01msl which is less than 357.0msl (embankment top). Results from the 25-yr, 24-hr rainfall event indicate the water surface elevation will be 354.81msl which is also less than 357.0msl (embankment top).

Summary

Water surface elevations calculated from Hydraflow Hydrographs are tabulated below:

SUMMARY OF POND HYDRAULIC CHARACTERISTICS				
	TOP OF EMBANKMENT	OPERATING LEVEL	100YR-24HR WSEL	25YR-24HR WSEL
EAST ASH POND	357.0	354.0	354.99	354.79
WEST ASH POND	357.0	354.0	355.01	354.81

As evident from the table above, it is the opinion of Akron Consulting that the East & West Ash Ponds will serve to adequately contain the calculated rainfall events.

TABLE 1

Runoff Curve Numbers for Hydrologic Soil-Cover Complexes
(Antecedent Moisture Condition II, and Ia= 0.2 S)
(Adapted from NRCS Technical Release 55)

Land Use	Treatment or Practice	Hydrologic Condition	Hydrologic Soil Group A	B	C	D
Fallow	Straight Row	----	77	86	91	94
Row Crops	Straight Row	Poor	72	81	88	91
	Straight Row	Good	67	78	85	89
	Contoured	Poor	70	79	84	88
	Contoured	Good	65	75	82	86
	Contoured and Terraced	Poor	66	74	80	82
	Contoured and Terraced	Good	62	71	78	81
Small Grain	Straight Row	Poor	65	76	84	88
	Straight Row	Good	63	75	83	87
	Contoured	Poor	63	74	82	85
	Contoured	Good	61	73	81	84
	Contoured and Terraced	Poor	61	72	79	82
	Contoured and Terraced	Good	59	70	78	81
Close-Seeded, Legumes, Rotation Meadow	Straight Row	Poor	66	77	85	89
	Straight Row	Good	58	72	81	85
	Contoured	Poor	64	75	83	85
	Contoured	Good	55	69	78	83
	Contoured and Terraced	Poor	63	73	80	83
	Contoured and Terraced	Good	51	67	76	80
Pasture Or Range		Poor	68	79	86	89
		Fair	49	69	79	84
		Good	39	61	74	80
Meadow		Good	30	58	71	78
Woods		Poor	45	66	77	83
		Fair	36	60	73	79
		Good	25	55	70	77
Farmsteads		----	59	74	82	86
Roads/Facilites		----	74	84	90	92

TABLE 2
EAST ASH POND ELEVATION-AREA-STORAGE TABLE
H.W. PIRKEY POWER PLANT
EXISTING CONDITION
NORMAL OPERATING POOL AT 354.0

ELEVATION (ft)	AREA (Acres)	STORAGE (Ac-Ft)	STORAGE (Cubic Feet)	STORAGE (Million Gallons)
352.00	25.70	na	na	na
353.00	25.99	na	na	na
354.00	26.29	0.00	0	0.00
355.00	26.59	26.44	1,151,730	232.61
356.00	26.88	53.18	2,316,300	467.82
357.00	27.19	80.21	3,493,950	705.67






TABLE 3
WEST ASH POND ELEVATION-AREA-STORAGE TABLE
H.W. PIRKEY POWER PLANT
EXISTING CONDITION
NORMAL OPERATING POOL AT 354.0

ELEVATION (ft)	AREA (Acres)	STORAGE (Ac-Ft)	STORAGE (Cubic Feet)	STORAGE (Million Gallons)
352.00	28.43	na	na	na
353.00	28.74	na	na	na
354.00	29.05	0.00	0	0.00
355.00	29.36	29.21	1,272,170	256.94
356.00	29.67	58.72	2,557,840	516.61
357.00	30.47	88.79	3,867,690	781.16




100-YEAR 24-HOUR RAINFALL (INCHES)



56

25-YEAR 24-HOUR RAINFALL (INCHES)




Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 3, 2015

Hyd. No. 1

East Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 310.73 cfs
Storm frequency	= 100 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,142,455 cuft
Drainage area	= 29.630 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 10.30 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 3, 2015

Hyd. No. 2

East Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 100 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - East Ash Pond	Max. Elevation	= 354.99 ft
Reservoir name	= East Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.




Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 3, 2015

Hyd. No. 1

West Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 350.69 cfs
Storm frequency	= 100 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,289,360 cuft
Drainage area	= 33.440 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 10.30 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 3, 2015

Hyd. No. 2

West Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 100 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - West Ash Pond	Max. Elevation	= 355.01 ft
Reservoir name	= West Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.




Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 15, 2015

Hyd. No. 1

East Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 247.38 cfs
Storm frequency	= 25 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 909,528 cuft
Drainage area	= 29.630 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 8.20 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 15, 2015

Hyd. No. 2

East Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 25 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - East Ash Pond	Max. Elevatioo	= 354.79 ft
Reservoir name	= East Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.




Hydrograph Report

Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 15, 2015

Hyd. No. 1

West Ash Pond

Hydrograph type	= SCS Runoff	Peak discharge	= 279.19 cfs
Storm frequency	= 25 yrs	Time to peak	= 12.07 hrs
Time interval	= 1 min	Hyd. volume	= 1,026,480 cuft
Drainage area	= 33.440 ac	Curve number	= 100
Basin Slope	= 0.0 %	Hydraulic length	= 0 ft
Tc method	= User	Time of conc. (Tc)	= 5.00 min
Total precip.	= 8.20 in	Distribution	= Type III
Storm duration	= 24 hrs	Shape factor	= 484



Hydrograph Report


Hydraflow Hydrographs Extension for AutoCAD® Civil 3D® 2012 by Autodesk, Inc. v9 Tuesday, 00 15, 2015

Hyd. No. 2

West Ash Pond

Hydrograph type	= Reservoir	Peak discharge	= 0.000 cfs
Storm frequency	= 25 yrs	Time to peak	= n/a
Time interval	= 1 min	Hyd. volume	= 0 cuft
Inflow hyd. No.	= 1 - West Ash Pond	Max. Elevation	= 354.81 ft
Reservoir name	= West Ash Pond		

Storage Indication method used. Wet pond routing start elevation = 354.00 ft.






PLAN VIEW
SCALE: 1"=200'

0 300' 600'
1"=300'

N

LEGEND

WATERSHED BOUNDARY



SECTION A-A
HORIZ. SCALE: 1"=300'
VERT. SCALE: 1"=30'

LEGEND

TOP OF EMBANKMENT
ELEV.= 357.00

100 YEAR 24 HOUR WSEL
ELEV.= 354.99

25 YEAR 24 HOUR WSEL
ELEV.= 354.79

NORMAL OPERATING LEVEL= 354.00

AKRON CONSULTING, LLC.
431 N. CENTER ST.
LONGVIEW, TX 75601
TBPE Firm Reg. # 14014
(O) 903-236-9744
(F) 903-236-9745
www.akron-consulting.com

EAST ASH POND WATER SURFACE EXHIBIT




PLAN VIEW
SCALE: 1"=300'

0 300' 600'
1"=300'

N

LEGEND

WATERSHED BOUNDARY



SECTION B-B
HORIZ. SCALE: 1"=300'
VERT. SCALE: 1"=30'

LEGEND

- TOP OF EMBANKMENT ELEV.= 357.00
- 100 YEAR 24 HOUR WSEL ELEV.= 355.01
- 25 YEAR 24 HOUR WSEL ELEV.= 354.81
- NORMAL OPERATING LEVEL= 354.00

AKRON CONSULTING, LLC.
431 N. CENTER ST.
LONGVIEW, TX 75601
TBPE Firm Reg. # 14014
(O) 903-236-9744
(F) 903-236-9745
www.akron-consulting.com

WEST ASH POND WATER SURFACE EXHIBIT